

N
FLOOR PLAN

1/4"

WALL LEGEND

- EXISTING EXTERIOR WALL CONSTRUCTION TO REMAIN
ADD 5/8" TYPE 'X' GYP BD ON INTERIOR FACE
PROVIDE INSULATION PER TITLE 24
- EXISTING STOREFRONT TO REMAIN
- 3 5/8" 20 GA METAL STUDS AT 16" O.C. WITH 5/8" GYP BOARD EACH SIDE TO THE UNDERSIDE OF EXISTING ROOF STRUCTURE WITH INSULATION FOR SOUND (NON-RATED) SEE DETAIL 1, SHEET A-5.0
- 3 5/8" 20 GA METAL STUDS AT 16" O.C. WITH 5/8" GYP BOARD ON INTERIOR FACE TO 6" ABOVE ADJACENT CEILING WITH INSULATION
- 6" 20 GA METAL STUDS AT 16" O.C. WITH 5/8" GYP BOARD EACH SIDE TO THE UNDERSIDE OF EXISTING ROOF STRUCTURE WITH INSULATION FOR SOUND (NON-RATED) SEE DETAIL 1, SHEET A-5.0
- PARTIAL HEIGHT WALL (DASHED DENOTES BELOW COUNTER) WITH 3 5/8" 24 GA METAL STUDS AT 16" O.C. AND 5/8" GYP BOARD EACH SIDE-
- INSULATED WALL FOR FREEZER (PROVIDED BY VENDOR)

KEYNOTES

- 5X5 HC ACCESSIBILITY SIGNAGE
- HC EXIT SIGN WITH BRAILLE
- RESTROOM HC ACCESSIBILITY SIGNAGE
- POST "MAXIMUM OCCUPANTS" SIGN(S) IN A CONSPICUOUS PLACE, NEAR THE MAIN EXIT OR EXIT ACCESS DOORWAY FROM THE ROOM OR SPACE IN AN APPROVED LEGIBLE PERMANENT DESIGN PER CBC SECTION 1004.3
- 18" DEEP COUNTER 42" AFF- PROVIDED BY VENDOR
- 30" DEEP SERVICE COUNTER 34" AFF TALL- PROVIDED BY VENDOR
- STAINLESS STEEL WALL PANELS AS PART OF THE COMMERCIAL HOOD, 3" GAP BETWEEN THE STAINLESS STEEL AND THE WALL
- 5'-0"x5'-0" CLEAR LEVEL LANDING WITH CROSS SLOPE NOT TO EXCEED 2%
- TRASH RECEPTACLE BY OWNER
- SURFACE MOUNTED FIRE EXTINGUISHER CABINET PER CITY OF BAKERSFIELD REQUIREMENTS
- SEATING BY OWNER
- BENCH SEATING BY OWNER
- ELECTRICAL PANELS
- PROVIDE COMMERCIAL APPROVED SOAP AND PAPER TOWEL DISPENSER AT HAND WASH SINK
- BEVERAGE COUNTER PROVIDED BY VENDOR - 40" AFF OPERABLE PARTS
- ACCESSIBLE COUNTER TOP @ 34" O.C.
- EXISTING STOREFRONT TO REMAIN
- EXISTING STOREFRONT TO REMAIN PROVIDE DARK TINT
- EXISTING DRIVE THRU WINDOW


DOOR SCHEDULE

- EXISTING STOREFRONT DOOR WITH 10" MINIMUM KICKPLATES AND ENTRANCE HARDWARE TO REMAIN - TEMPERED GLASS VERIFY EXISTING CORRECT AS NECESSARY
- EXISTING 3'-0"x 7'-0" DOOR
- 3'-0"x 7'-0" SOLID CORE DOOR LAMINATE FINISH
- 3'-0"x 7'-0" INSULATED DOOR PROVIDED BY REFRIGERATION VENDOR
- 3'-0"x 3'-6" DOUBLE SWING DOOR
- PAIR 2'-0"x 7'-0" SOLID CORE DOOR WITH LAMINATE FINISH

HARDWARE SCHEDULE


INTERIOR HARDWARE TO BE CLEAR ANODIZED ALUMINUM

- EXISTING HARDWARE - REKEY
- 1/2 PAIR HINGES LOCK SET CLOSER DOOR STOP 4 1/2"x4 1/2" #BB1214 BY "HAGAR" PRIVACY LOCK #AL405 BY "SCHLAGE" #460 BY "LCN" WALL MOUNTED BY "QUALITY"
- 1/2 PAIR HINGES LOCK SET FLUSH BOLT DOOR STOP 4 1/2"x4 1/2" #BB1214 BY "HAGAR" STORAGE LOCK #ALB0PD BY "SCHLAGE" FB31T BY "IVES" WALL MOUNTED BY "QUALITY"
- 1/2 PAIR HINGES LOCK SET CLOSER DOOR STOP 4 1/2"x4 1/2" #BB1214 BY "HAGAR" PASSAGE LATCH #AL105 BY "SCHLAGE" #460 BY "LCN" WALL MOUNTED BY "QUALITY"



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE, SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (805) 328-8936
FACSIMILE: (805) 328-8937

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor assigned to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS
Written dimensions on these drawings shall take precedence over scaled dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT FOR



1946 WEST AVE L
LANCASTER, CA

DATE	ISSUED FOR
6-20-11	BUILDING DEPT SUBMITTAL

NO. REVISIONS


1	
2	
3	
4	

FLOOR PLAN

FILE NAME: 2366A1-0

SHEET

A-1.0



LEGEND

- 2x2 SUSPENDED CEILING GRID WITH 'ARMSTRONG ULTIMA HEALTH ZONE #1445' SQUARE EDGE ; PRELUDE ML WHITE EXPOSED TEE 15/16" GRID SEE DETAIL 546/A-5.0
- GYP BD CEILING SYSTEM WITH USG 5/8" TYPE 'X' GYP BD SEE DETAIL 7/A-5.0
- NEW 2x4 RECESSED MOUNTED LED LIGHT FIXTURE WITH ACRYLIC PRISMATIC LENS
- 1x4 RECESSED MOUNTED LED LIGHT FIXTURE CENTER IN ROOM - UNO.
- RECESSED MOUNTED DOWN LIGHT - CENTER IN SOFFIT EACH MAY UNLESS NOTED OTHERWISE
- PENDANT LIGHT FIXTURE
- DRUM SHADE LIGHT FIXTURE
- HOT LAMP
- TRACK LIGHTING

CEILING PLAN NOTES

- ALL CEILING GRIDS SHALL BE CENTERED IN ROOMS AS SHOWN UNLESS NOTED OTHERWISE
- BRACE ALL NEW AND RELOCATED LIGHT FIXTURES AND MECHANICAL DUCTS TO STRUCTURE PER CBC, CEC, AND CMG REQUIREMENTS
- EXISTING FLOOR CEILING ASSEMBLY IS EXISTING 1-HR RATED PER BUILDING SHELL. THE ASSEMBLY IS USGA #FC540T


CEILING JOIST SPAN TABLE - 6" METAL STUDS			
THICKNESS	13 PSF - MIDSPAN		
	12" O.C.	16" O.C.	24" O.C.
25 GA	9'-0"	7'-8"	6'-7"
22 GA	10'-4"	9'-8"	8'-3"
20 GA	11'-4"	10'-4"	9'-2"
18 GA	12'-10"	11'-4"	10'-4"

CEILING KEYNOTES

- GYP. BD SOFFIT. REFER TO A-102 FOR ATTACHMENT DETAILS.
- LINE OF GYPSUM BOARD SOFFIT ABOVE
- LINE OF HOOD. EXTEND FACE OF STAINLESS STEEL ABOVE HOOD TO 6" MINIMUM ABOVE A.C.T. HOOD FURNISHED BY KITCHEN VENDOR, INSTALLED BY G.C.
- GRAPHIC MESSAGE ON FACE OF SOFFIT. COORDINATE LOCATION WITH GRAPHICS VENDOR.
- LIGHTING BUILT IN TO FREEZER AND COOLER UNITS. G.C. TO COORDINATE INSTALLATION WITH KITCHEN VENDOR AND ELECTRICAL DRAWINGS
- STARTING POINT OF A.C.T.
- ALL ITEMS ABOVE STOREFRONT VISIBLE FROM DINING AREA, INCLUDING TRUSSES, TO BE PAINTED
- TRIM PANELS PROVIDED BY KITCHEN VENDOR TO EXTEND ABOVE FREEZER/COOLER TO 6" ABOVE A.C.T. MINIMUM.
- HEAT LAMPS BY KITCHEN DESIGNER; CENTER MIDDLE LIGHT ABOVE 3'-0" SECTION OF COUNTER BELOW 16" ABOVE COUNTER.
- MENU BOARDS- REFER TO GRAPHIC PACKAGE - INSTALLED BY SIGN VENDOR
- AIR CURTAIN


GENERAL NOTES:

- CEILING TILES TO BE CENTERED BOTH WAYS IN EACH ROOM OR SPACE UNLESS DIMENSIONED OTHERWISE.
- ALL DIMENSIONS ARE TO THE CENTER OF LIGHT FIXTURE, UNO.
- FIXTURES LOCATED WITHIN THE CEILING GRID, ARE NOT NECESSARILY CENTERED IN EACH CEILING TILE. FOLLOW DIMENSIONS ON PLAN. IF NO DIMENSION IS PRESENT CONTACT ARCHITECT TO VERIFY LOCATION.
- LIGHT FIXTURES TO BE LOCATED AS INDICATED ON THIS PLAN. REFER TO ELECTRICAL DRAWINGS FOR EXACT NUMBER AND TYPE OF LIGHT FIXTURE. CONTACT ARCHITECT/ENGINEER IMMEDIATELY IF THERE ARE ANY DISCREPANCIES.
- REFER TO MECHANICAL DRAWINGS FOR MECHANICAL DUCT DISTRIBUTION SYSTEM. THE G.C. SHALL SET ALL CEILING AND SOFFITS USING A LASER LEVEL TO ACHIEVE A CEILING THAT IS PLUMB, LEVEL, AND SQUARE TO ALL WALLS AND SOFFITS.
- ALL NOTED CEILING DIMENSIONS ARE INDICATED AS CLEAR ABOVE FINISHED FLOOR DIMENSIONS. VERIFY THICKNESS OF FLOOR CONSTRUCTION WITH FLOOR SUBCONTRACTOR PRIOR TO THE INSTALLATION OF ANY NEW CEILING CONSTRUCTION IN ORDER TO ACHIEVE NOTED REQUIRED DIMENSIONS.
- ALL SOFFIT DIMENSIONS ARE TO FINISH FACE, UNO.
- ALL EXTERIOR DIMENSIONS ARE TO THE FACE OF EXTERIOR FINISH, UNO.
- G.C. TO PROVIDE ADEQUATE CLEARANCES FOR FIXTURES, DUCTS, CEILING AND PERTINENT ITEMS NECESSARY TO MAINTAIN THE SPECIFIC HEIGHTS ABOVE FINISH FLOOR. COORDINATE MECHANICAL, ELECTRICAL AND PLUMBING AS REQUIRED.
- ADDITIONAL HANGER AND SAFETY WIRES FOR LIGHT FIXTURES, SPEAKERS, AND AIR SUPPLY/RETURN DIFFUSERS AS REQUIRED BY LOCAL CODES TO BE 'CEILING GRADE' AS CONCURRENT WITH ELECTRICAL CODE ADOPTED FOR JURISDICTION OF PROJECT.
- G.C. TO COORDINATE DUCTWORK INSTALLATION WITH TRUSS INSTALLATION TO MAXIMIZE LENGTH OF DUCTWORK ABLE TO BE USED THROUGH TRUSSES.



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE, SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (805) 328-8936
FACSIMILE: (805) 328-8837

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor assigned to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS
Written dimensions on these drawings shall take precedence over scaled dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT FOR



1946 WEST AVE L
LANCASTER, CA

DATE	ISSUED FOR
6-20-19	BUILDING DEPT SUBMITTAL

NO.	REVISIONS
1	
2	
3	
4	

CEILING PLAN

FILE NAME: 2366A2-0

SHEET

A-20

GENERAL NOTES:


1. **XX** INDICATES TYPICAL FINISHES WITHIN ROOM UON. SEE SHEET A-60 FOR MATERIAL AND COLOR SCHEDULE.
2. ALL FLOOR COVERING MATERIALS TO BE INSTALLED PER MANUFACTURER'S STANDARD DETAILS AND SPECIFICATIONS. VERIFY W/ MANUFACTURER PRIOR TO INSTALLATION.
3. THE GC IS RESPONSIBLE FOR PROVIDING A SMOOTH LEVEL FLOOR SURFACE THAT MEETS THE MANUFACTURER'S INSTALLATION SPECIFICATIONS PRIOR TO THE INSTALLATION OF ALL FLOORING MATERIALS. UON'S ARE TO BE PLACING UNIT TILE AND CARPET AREAS PER SPECIFICATIONS. PATCH/SHIM ALL AREAS AS NECESSARY SO THAT NEW FLOORING MEETS LEVEL WITH ALL OTHER FLOORING SURFACES MAX. SLOPE OF 1:20.
4. THE FLOORING SUB-CONTRACTOR IS RESPONSIBLE FOR VERIFYING THAT THE CONDITION OF THE BASE FLOOR MEETS THE INSTALLATION SPECIFICATIONS PRIOR TO THE INSTALLATION OF THE NEW FLOORING MATERIAL.
5. ALL MATERIAL TRANSITIONS AT DOOR THRESHOLDS TO TAKE PLACE AT DOOR CENTERLINE UON.
6. ALL DIMENSIONS ARE TO CENTERLINE OF TRANSITION BETWEEN FLOORING MATERIALS OR FINISH MATERIALS. IF SANDING DO NOT SHOW ANY TRANSITION AT ANY OF SAME MATERIALS. CONTRACTOR TO START TILES AT POINT AS INDICATED ON PLANS.

KEY NOTES:

- ① START POINT FOR TILE; ALIGN WITH THE FACE OF POS COUNTER
- ② STAINLESS STEEL WALL FINISH PROVIDED BY KITCHEN VENDOR TO EXTEND 18" BEYOND HOOD WIDTH, AS APPLICABLE. COORDINATE WITH HOODS
- ③ GRAPHIC INSTALLED ON P-2 PAINT ABOVE STOREFRONT.
- ④ GRAPHIC WRAPS AROUND TO CORNER.
- ⑤ RESTROOM DOORS AND FRAME TO BE PAINTED P-4, FRONT AND BACK.


FINISH LEGEND: X # - FINISH (REFER TO FINISH LEGEND ON SHEET A-60)				
KEY	ITEM	DESCRIPTION	COLOR	REMARKS
B-1	BASE	4" ALUMINUM WALL BASE	WILSONART SATIN BRUSHED NATURAL ALUMINUM #6251 (4H)	
B-2	BASE	ROPPE OR KYDEX, TRADITIONAL VINYL WALL BASE	#100 BLACK, 4" COVE (COIL)	
B-3	BASE	DAL TILE COVERED WALL BASE	8"X8" OT03 ASHEN GRAY	
B-3	BASE	DAL TILE COVERED WALL BASE	DB VOLUME LO 6X12 BASE P-36C4TB AMPLIFY BLACK STD	
FRP-1	FIBERGLASS REINFORCED PANELS	MARLITE WALL SYSTEMS, STANDARD FRP	9100 WHITE, PEBBLED SURFACE	KITCHEN
P-1	PAINT	BENJAMIN MOORE, AURA INTERIOR PAINT	2B3-10 ONYX	WALLS: SATIN FINISH; CEILING: FLAT DOORS & TRIM: SEMIGLOSS
P-2	PAINT	BENJAMIN MOORE, AURA INTERIOR PAINT	2B3-30 DAY'S END	CEILING ONLY: FLAT
P-3	PAINT	BENJAMIN MOORE, AURA INTERIOR PAINT	200H0 RUBY RED	WALLS: SATIN FINISH; CEILING: FLAT DOORS & TRIM: SEMIGLOSS
P-4	PAINT	SHERWIN WILLIAMS, ACRYLIC LATEX EMERALD	5N 1004 SNOWBOUND	WALLS: SATIN FINISH; CEILING: FLAT DOORS & TRIM: SEMIGLOSS
PL-4	PLASTIC LAMINATE	WILSONART, HIGH PRESSURE LAMINATE	4878-60 PEXTER MESH	
PL-7	PLASTIC LAMINATE	WILSONART, HIGH PRESSURE LAMINATE	4623-60 GRAPHIC NEBULA	
SF-3	SPECIAL FINISH	KOROGARD, WALL PROTECTION SYSTEM	VAPOR	
SF-4	SPECIAL FINISH	KOROGARD, WALL PROTECTION SYSTEM	BLACK	
T-1	TILE	DAL TILE, PORCELAIN TILE	DB VOLUME LO 12X24 FLOOR VL70 AMPLIFY BLACK STD	GROUT TO BE ULTRAFLEX GRAY THIN SET AT DINING ROOM AND RESTROOM
T-2	TILE	DAL TILE, PORCELAIN TILE	DB VOLUME LO 12X24 FLOOR VL71 DEGREES SILVER STD	GROUT TO BE ULTRAFLEX GRAY THIN SET AT DINING ROOM AND RESTROOM
T-3	TILE	DAL TILE, PORCELAIN TILE	8"X8" OT03 ASHEN GRAY	GROUT TO BE ULTRAFLEX GRAY THIN SET AT DINING ROOM AND RESTROOM
T-4	TILE	DAL TILE, PORCELAIN TILE	Q140 ARCTIC WHITE SEMIGLOSS MODERN DIMENSION 4 1/2"X 12 7/8" TILE	KITCHEN WALLS BEHIND SERVICE COUNTER, USE DAL TILE TRIM PIECES S4C9 MOD 040 ARCTIC WHITE AND A34C1 4X12 C/B 040 ARCTIC WHITE
T-5	TILE	DAL TILE, PORCELAIN TILE	K11 BLACK SEMIGLOSS MODERN DIMENSION 4 1/2"X 12 7/8" TILE	KITCHEN WALLS BEHIND SERVICE COUNTER, USE DAL TILE TRIM PIECES S4C9 MOD K11 BLACK AND A34C1 4X12 C/B K11 BLACK
WC-1	WALLCOVERING	AGI	-	VINYL GRAPHIC, 54" WIDE, INSTALL DIRECTLY ONTO DRYWALL
WC-2	WALLCOVERING	AGI	-	VINYL GRAPHIC, GRAND ENTRANCE WASHABLE SURFACE - PRINTED

DRIVE THRU WINDOW




FINISH FLOOR PLAN

1/4"




TYPICAL RESTROOM



RESTROOM PLAN


INTERIOR ELEVATION NOTES

1. ALL COUNTER TOPS SHALL BE BRACED AS REQUIRED WITH DIAGONAL SUPPORTS. MATERIAL AND FINISH SHALL MATCH ADJACENT CABINERY.
2. WRAP ALL SINK DRAINING WITH INSULATION AS REQUIRED.
3. AT LEAST ONE OF EACH TYPE OF ACCESSORY SHALL BE INSTALLED WITH ALL OPERABLE PARTS WITHIN 40" FROM THE FINISHED FLOOR.
4. ALL CABINETS, FIXTURES AND ACCESSORIES SHALL BE CONSTRUCTED AND INSTALLED PER APPLICABLE CODES.
5. FORCE REQUIRED TO ACTIVATE ALL FIXTURES SHALL BE NO GREATER THAN 5 LBF.
6. FAUCET CONTROLS AND OPERATING MECHANISMS SHALL BE OPERABLE WITH ONE HAND AND SHALL NOT REQUIRE TIGHT GRASPING OR TWISTING OF THE WRIST. THE FORCE REQUIRED TO ACTIVATE CONTROLS SHALL NOT BE GREATER THAN 5 LBF.
7. FAUCETS ON SELF-CLOSING FAUCET CONTROL VALVES, IF USED, SHALL REMAIN OPEN FOR AT LEAST 10 SECONDS.
8. EACH ACCESSIBLE SINK SHALL BE A MAXIMUM OF 6 1/2" DEEP. SINKS SHALL BE MOUNTED WITH THE COUNTER OR RIM NO HIGHER THAN 34" ABOVE THE FINISHED FLOOR. KNEE CLEARANCE THAT IS AT 27" HIGH, 30" WIDE AND 27" DEEP WITH NO OBSTACLES.
9. ALL FLOOR FINISHES TO BE NON-ABSORBENT MATERIAL SUCH AS CERAMIC TILE OR SHEET VINYL. BASE IS TO BE COVERED WITH TILE TO BE 48" ON THE FACE OF THE WALL AND TO BE OF NON-ABSORBENT MATERIAL SUCH AS CERAMIC TILE OR SHEET VINYL.



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE., SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (881) 326-8836
FACSIMILE: (881) 328-8837

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor assigned to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS
Written dimensions on these drawings shall take precedence over scaled dimensions. Contractors shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT
FOR



1966 WEST AVE L
LANCASTER, CA

DATE	ISSUED FOR
6-28-19	BUILDING DEPT SUBMITTAL

NO.	REVISIONS
-----	-----------

FINISH PLAN

FILE NAME: 2366A3-0

SHEET

A-3.C

GENERAL NOTES:

1. G.G. TO COORDINATE WITH MILLWORKER FOR LOCATION OF BLOCKING AS REQUIRED.
2. GENERAL CONTRACTOR TO COORDINATE FINAL LOCATIONS OF FIXTURES AND/OR FURNITURE WITH OWNER BEFORE INSTALLATION, INCLUDING COORDINATING POWER, FIXTURE ANCHOR SLEEVES, AND/OR FIXTURES. SEE ELECTRICAL DRAWINGS FOR ADDITIONAL POWER/DATA INFORMATION.
3. G.G. TO COORDINATE AND VERIFY ALL FIXTURE AND/OR FURNITURE QUANTITIES AND INSTALLATION WITH FIXTURE FABRICATOR AND OWNER.
4. LOCATE FIXTURES AND FURNISHINGS AS TO MAINTAIN 36" CLEAR BETWEEN AND A 44" WIDE EGRESS PATH TO EXIT DOORS.
5. REFER TO GRAPHICS PACKAGE FOR PLACEMENT OF INTERIOR GRAPHICS


- ① KITCHEN LAYOUT, INCLUDING ALL EQUIPMENT AND FURNITURE SHOWN FOR REFERENCE ONLY. SEE KITCHEN AND MEP DRAWINGS FOR ADDITIONAL SPECIFICATIONS, POWER, DRAINAGE, PLUMBING, SINK, DRAINS AND VENTILATION AS REQUIRED.
- ② GRAPHIC FOCAL WALL. REFER TO GRAPHICS PACKAGE FOR ADDITIONAL INFORMATION AND BLOCKING REQUIREMENTS.
- ③ AUTOMATIC PAPER TONER ROLL DISPENSER
- ④ SAFE UNDER MANAGER'S DESK PROVIDED BY KITCHEN VENDOR. SEE KITCHEN SHEETS FOR MORE INFORMATION
- ⑤ FIRE EXTINGUISHER LOCATION. GC TO VERIFY FINAL LOCATION WITH AUTHORITY. HAVING JURISDICTION AFTER EQUIPMENT INSTALLATION
- ⑥ MANAGER'S DESK, SHELVES AND CABINET ABOVE BY KITCHEN VENDOR. SEE KITCHEN SHEETS FOR MORE INFORMATION
- ⑦ COORDINATE POWER/DATA REQUIREMENTS WITH ELECTRICAL DRAWINGS AND FIXTURE FABRICATOR.
- ⑧ HIGH CHAIRS BY OWNER.
- ⑨ COUNTER HEIGHT GAGE INCLUDED IN MILL/NOON PACKAGE

ACCESSIBILITY REQUIREMENTS:
73 SEATING
REQUIRED: 5% TOTAL SEATING (4 SEATS)
PROVIDED: 4 ACCESSIBLE TABLES INTERIOR

MILLWORK SCHEDULE			
ITEM	DESCRIPTION	QTY	NOTE
LF-10	COMMUNAL TABLE	1	
LF-20	BEVERAGE AND CONDIMENT STATION	1	
LF-30	TRASH BIN	1	
LF-40	BENCH	1	
LF-50	BAR TABLE	1	
LF-60	POS	1	
LF-61	POS	1	
LF-70	POS & PICK UP COUNTER	1	

FURNISHING SCHEDULE			
ITEM	DESCRIPTION	QTY	NOTE
FN-1	LOW CHAIR	52	
FN-2	BARSTOOL	17	
FN-3	2 TOP TABLE	10	
FN-6	4 TOP ADA TABLE	4	

FURNISHING SCHEDULE			
ITEM	DESCRIPTION	QTY	NOTE
FE-1	FIRE EXTINGUISHER (X2)	1	
FE-2	FIRE EXTINGUISHER (TYPE K)-(X3)	1	
FE-3	RECESSED FIRE EXTINGUISHER (X2)	1	



1/4"

G.C. TO COORDINATE WITH KITCHEN VENDOR
THE LEAD TIMES OF ALL KITCHEN EQUIPMENT
BEFORE DEVELOPING A MASTER SCHEDULE



Professional Seal of Paul Dhanens, Licensed Architect, State of California, No. C-23843, Renewal.

CONSULTANT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor assigned to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

**TENANT IMPROVEMENT
FOR**




NO.	REVISIONS
-----	-----------


FILE NAME: 2366A4-1

SHEET


A-4.C




1 FULL HEIGHT WALL SECTION 3"




5 SEISMIC BRACING NS




9 HEADER DETAIL 1"




14 CLEARANCE BAR 1"




2 TACTILE RESTROOM SIGN NS




6 SEISMIC BRACING NS




10 HANGING SOFFIT 1"




14 CLEARANCE BAR 1"




3 TACTILE EXIT SIGN NS




7 CEILING FRAMING NS




11 DRIVE THRU TIMER LOOP NS




16 MENU BOARD 1"




4 TACTILE DIRECTIONAL SIGN NS



8 SOFFIT DETAIL @ CEILING FIXTURE 1"



12 SOFFIT DETAIL @ CEILING FIXTURE 1"



16 MENU BOARD 1"

PAUL DHANENS • ARCHITECT

ARCHITECT

5100 CALIFORNIA AVE, SUITE 107
 BAKERSFIELD, CALIFORNIA 93309
 TELEPHONE: (805) 328-8836
 FACSIMILE: (805) 328-8837

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor assigned to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS
 Written dimensions on these drawings shall take precedence over scaled dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT FOR

1946 WEST AVE L
 LANCASTER, CA

DATE	ISSUED FOR
6-20-11	BUILDING DEPT SUBMITTAL




NO.	REVISIONS
1	
2	
3	
4	

DETAILS

FILE NAME: 2366A5-0

SHEET

A-5.0

	
PAUL DHANENS • ARCHITECT	
ARCHITECT	
	
3100 CALIFORNIA AVE, SUITE 107 BAKERSFIELD, CALIFORNIA 93309 TELEPHONE: (805) 326-8636 FACSIMILE: (805) 326-8637	
CONSULTANT	
COPYRIGHT	
<p>PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor assigned to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.</p> <p>NOTICE TO CONTRACTORS Written alterations or these drawings shall take precedence over printed dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.</p>	
PROJECT	
TENANT IMPROVEMENT FOR	
	
1966 WEST AVE. I LANCASTER, CA	
DATE	ISSUED FOR
6-28-91	BUILDING DEPT SUBMITTAL
NO.	REVISIONS
△	
△	
△	
△	
SPECIFICATION	
FILE NAME:	2366A6-0
SHEET	
A-60	

22 SHEATHING

A. WOOD SHEATHING

1. ALL WOOD SHEATHING SHALL BE MANUFACTURED BY A MEMBER COMPANY OF APA - THE ENGINEERED WOOD ASSOCIATION, AND EACH PANEL SHALL BEAR THE APA TRADEMARK INDICATING ITS UNIQUE MATERIAL PROPERTIES. ALL PLYWOOD USED ON EXTERIOR SURFACES SHALL CONFORM TO THE REQUIREMENTS OF THE LATEST EDITION OF VOLUNTARY PRODUCT STANDARD PS-1 (STRUCTURAL PLYWOOD); BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY (NIST). ALL OTHER WOOD SHEATHING SHALL CONFORM TO THE REQUIREMENTS OF THE LATEST EDITION OF VOLUNTARY PRODUCT STANDARD PS-2, "PERFORMANCE STANDARD FOR WOOD-BASED STRUCTURAL-USE PANELS," BY NIST.

2. WHERE EXPOSURE RATINGS OR SPAN RATINGS IS NOT GIVEN IN THE CONTRACT DRAWINGS, PROVIDE EXPOSURE 1 AND RATINGS REQUIRED TO SUT SUPPORT MEMBER SPACINGS INDICATED ON DRAWINGS.

3. PROVIDE PANELS WITH TONGUE AND GROOVE EDGES WHERE SPECIFIED IN THE CONTRACT DRAWINGS.

4. EXTERIOR WOOD SHEATHING: PANELS SHALL BE EXPOSURE 1 WITH THICKNESS AS SPECIFIED IN THE CONTRACT DRAWINGS.

5. ROOFS AND OTHER EXTERIOR HORIZONTAL OR SLOPED SURFACES: 5-PLY PLYWOOD WITH GRADE AND SPAN RATINGS AS SPECIFIED IN THE CONTRACT DRAWINGS. WHERE MULTIPLE LAYERS OF PLYWOOD NO THICKER THAN 3/8 INCH ARE USED TO SHEATH CURVED SURFACES, PANELS SHALL BE MINIMUM 3-PLY.

6. WALLS: STRUCTURAL-USE WALL PANELS COVERED IN VOLUNTARY PRODUCT STANDARD PS 2.

7. SHEATHING TO BE TREATED WITH PRESERVATIVE OR FIRE-RETARDANT CHEMICALS SHALL CONFORM TO THE REQUIREMENTS OF SECTION 25. WOOD TREATMENT; AND SHALL BE USED ONLY WHERE SPECIFIED IN THE CONTRACT DRAWINGS.

8. WATER-RESISTANT CORE GYPSUM SHEATHING BOARD, ASTM C174, THICKNESS AS INDICATED ON DRAWINGS, 24 OR 48 INCH WIDTH, MAXIMUM PERMISSIBLE LENGTH, ENDS STRAIGHT AND SOLID, EDGES SQUARE. WATER-RESISTANT CORE GYPSUM SHEATHING TO HAVE A WATER-RESISTANT MATERIAL INCORPORATED IN THE CORE. SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE ONE OF THE FOLLOWING:

1. GYTEX, AMERICAN GYPSUM SHEATHING; GYTEX, AMERICAN GYPSUM CO.
2. HYPOLOC GYPSUM SHEATHING; DOMSTAR GYPSUM CO.
3. 15-P GYPSUM SHEATHING; GEORGIA-PACIFIC CORP.
4. GOLD BOND GYPSUM SHEATHING; GOLD BOND BUILDING PRODUCTS DIV, NATIONAL GYPSUM CO.
5. 156 GYPSUM SHEATHING; UNITED STATES GYPSUM CO.

23 ACCESSORIES

A. FASTENERS: PROVIDE MANUFACTURERS RECOMMENDED POWER TOOLS FOR EACH TYPE OF FASTENER.

1. NAILS, SPIKES AND STAPLES: ASTM A28, GALVANIZED FOR EXTERIOR LOCATIONS, HIGH HUMIDITY AREAS, AND TREATED WOOD. PLAN FINISH FOR OTHER INTERIOR LOCATIONS, SIZE AND TYPE TO SUT APPLICATION, UNLESS OTHERWISE NOTED.

2. BOLTS, NUTS, WASHERS, LAG SCREWS, AND WOOD SCREWS: ASTM A307, MEDIUM CARBON STEEL, SIZE AND TYPE TO SUT APPLICATION, GALVANIZED FOR EXTERIOR LOCATIONS, HIGH HUMIDITY AREAS, AND TREATED WOOD. PLAN FINISH FOR OTHER INTERIOR LOCATIONS, OF SIZE AND TYPE TO SUT APPLICATION, UNLESS OTHERWISE NOTED.

3. EXPANSION SHIELD FASTENERS: FOR ANCHORAGE OF NON-STRUCTURAL ITEMS TO SUT MASONRY AND CONCRETE.

4. POWDER OR PNEUMATICALLY ACTIVATED FASTENERS: FOR ANCHORAGE OF NON-STRUCTURAL ITEMS TO STEEL.

B. ROOF SHEATHING FASTENERS: GALVANIZED FOR EXTERIOR, HIGH HUMIDITY, AND TREATED WOOD LOCATIONS, PLAN FINISH ELSEWHERE, SIZE AND TYPE TO SUT CONDITION UNLESS OTHERWISE NOTED ON CONTRACT DOCUMENTS.

24 WOOD TREATMENT

A. PRESERVATIVE PRESURE-TREATED LUMBER

1. MANUFACTURERS: A. TREATED PRESURE-TREATED WOOD, HOLMAN CGA TYPE C, BY HICKSON CORPORATION, ATLANTA, GA, (404) 804-6600.

2. CGA PRESURE TREATED LUMBER TYPE C, BY HOOVER TREATED WOOD PRODUCTS INC., THOMSON, GA, (800) 882-4668.

3. MERGATE LUMBER WITH PRESERVATIVE TREATMENT CONFORMING TO ANPA STANDARD Q1 AND PS, APPLY THE PRESERVATIVE IN A CLOSED CYLINDER BY PRESSURE PROCESS IN ACCORDANCE WITH ANPA STANDARD C8.

4. RETENTION OF DRY SALTS.

5. MODERATE SERVICE CONDITIONS (WEATHER EXPOSURE): 0.25 POUNDS PER CUBIC FOOT (OXIDE BASE).

6. SEVERE CONDITIONS (CONSTANT CONTACT WITH GROUND OR WATER): 0.40 POUNDS PER CUBIC FOOT (OXIDE BASE).

7. REMOVE EXCESS MOISTURE: WHERE SHINKAGE IS A SERIOUS FAULT OR WHERE TREATED LUMBER WILL BE IN CONTACT WITH PLASTER, OR EPS AND WHERE WATER-BORNE TREATED LUMBER IS TO BE PAINTED OR STAINED.

8. LUMBER SHALL BE DRIED TO 5-8 PERCENT MOISTURE CONTENT AFTER TREATMENT, AND MATERIAL TO BE PAINTED OR STAINED SHALL HAVE KNOTS AND PITCH STREAKS SEALED AS WITH UNTREATED WOOD.

9. LIBERALLY BRUSH FRESHLY CUT SURFACES, BOLT HOLES AND MACHINED AREAS WITH THE SAME PRESERVATIVE IN ACCORDANCE WITH ANPA STANDARD M4.

B. WOOD REQUIRING PRESURE-TREATMENT

1. LUMBER, PRESERVATIVE TREATED: NAILS, BLOCKING, STRIPPING, AND SIMILAR ITEMS IN CONNECTION WITH ROOFING, FLASHING, AND OTHER CONSTRUCTION. SILL PLATES, BLOCKING, FURRING, STRIPPING, SLEEPERS AND SIMILAR ITEMS IN CONTACT WITH CONCRETE.

C. FIRE-RETARDANT TREATED LUMBER

1. MANUFACTURERS: A. TROCON FIRE RETARDANT TREATED WOOD, BY ARCH WOOD PROTECTION INC., SMITHDA, GEORGIA, (666) 878-3784.

2. WOOD REQUIRING FIRE RETARDANT TREATMENT

1. DIMENSION LUMBER OR PANELS ONLY AS SPECIFIED IN THE CONTRACT DRAWINGS.

PART 3 EXECUTION

31 EXAMINATION

A. EXAMINE AREAS TO RECEIVE ROUGH CARPENTRY WORK AND VERIFY FOLLOWING:

1. THAT INSTALLATION OF BUILDING COMPONENTS TO RECEIVE ROUGH CARPENTRY WORK IS COMPLETE.
2. THAT SURFACE AREAS ARE SATISFACTORY TO RECEIVE WORK.
3. THAT SPACING, DIRECTION AND DETAILS OF SUPPORTS ARE CORRECT TO ACCOMMODATE INSTALLATION OF BLOCKING, BACKING, STRIPPING, FURRING AND NAILING STRIPS.

32 SITE TREATMENT OF WOOD MATERIALS

A. RETREAT SITE SAWN ENDS WITH BRUSH APPLICATION ACCORDING TO MANUFACTURERS INSTRUCTIONS. ALLOW PRESERVATIVE TO CURE PRIOR TO PLACING MEMBERS.

33 INSTALLATION

A. INSTALL MISCELLANEOUS BLOCKING, NAILING STRIPS, FRAMING, AND SHEATHING AS DETAILED ON DRAWINGS. COORDINATE TO ALLOW PROPER ATTACHMENT OF WORK OF OTHER SECTIONS.

1. SECURE WOOD BLOCKING, CANTS, WALERS, IN PLACE USING FASTENERS SPECIFIED. USE ONLY RECOMMENDED POWER TOOLS FOR PLACEMENT OF FASTENERS.

2. RECESS HEADS OF FASTENERS BELOW SURFACE OF WOOD MEMBERS.

B. INSTALL MEMBERS TRUE TO LINE, PLUMB, AND LEVEL.

C. SECURE IN PLACE WITH APPROPRIATE FASTENERS. USE FASTENERS OF CORRECT SIZE THAT WILL NOT PENETRATE MEMBERS WHERE OPPOSITE SIDE WILL BE EXPOSED TO VENT OR REQUIRE FINISHING. DO NOT SPILT WOOD WITH FASTENERS; SET PANEL PRODUCTS TO ALLOW EXPANSION AT JOINTS.

D. DO NOT SPLICE STRUCTURAL MEMBERS BETWEEN SUPPORTS.

E. CONSTRUCT MEMBERS OF CONTINUOUS PIECES OF LONGEST POSSIBLE LENGTHS.

F. PLACE PLYWOOD ROOF SHEATHING AS SHOWN ON DRAWINGS. SECURE SHEETS OVER FRIED BEARING. PANEL END JOINTS SHALL OCCUR OVER FRAMING. ALLOW 1/8 INCH SPACING AT PANEL ENDS AND PANEL EDGES UNLESS OTHERWISE RECOMMENDED BY PANEL MANUFACTURER.

34 FIELD QUALITY CONTROL

A. SECTION 0400 - QUALITY CONTROL: PROCEDURES FOR INSPECTION OF WORK.

B. FRAMING INSPECTION: 1. INSPECT WOOD FRAMING INSTALLATION AND CONNECTIONS AT COMPLETION OF EACH PHASE OF WOOD CONSTRUCTION FOR CORRECT INSTALLATION, NAILING, CONNECTIONS, AND FASTENERS.

2. INSPECT AND VERIFY THAT TYPES AND SPACING OF FASTENERS ARE INSTALLED IN LOCATIONS SPECIFIED OR INDICATED ON DRAWINGS.

3. INSPECT TYPES, LOCATIONS, AND FASTENERS FOR STRUCTURAL METAL FRAMING CONNECTORS.

4. INSPECT WOOD TO STEEL BEAM CONNECTIONS.

C. CORRECT DEFICIENCIES IN WORK IF INSPECTION INDICATES WORK IS NOT IN COMPLIANCE WITH CONTRACT DOCUMENTS.

SECTION 06200 - FINISH CARPENTRY

B. DESCRIPTION OF SYSTEMS

SEE "RESPONSIBILITY SCHEDULE" FOR ITEMS FURNISHED BY OWNER AND INSTALLED BY CONTRACTOR (FOC).

C. CODES AND STANDARDS

AM, QUALITY-STANDARDS AND GUIDE SPECIFICATIONS MANUAL.

D. ROUGH LUMBER AND PLYWOOD

LUMBER HAVING MODULUS OF ELASTICITY OF NOT LESS THAN 1600000 PSI AND ALLOWABLE FIBER STRESS OF MORE THAN 4000 PSI, IN STANDARD DIMENSIONS, MOISTURE CONTENT NOT MORE THAN 19%, FIRE TREATMENT OF ALL ROUGH LUMBER AND PLYWOOD IS AS FOLLOWS:

1. ROUGH LUMBER TREATED WITH PRESSURE FIRE RETARDANT PER AMERICAN WOOD PRESERVERS ASSOCIATION STANDARD ANPA C20, EACH PIECE TO BEAR UL LABEL, TR-S.

2. PLYWOOD TREATED WITH PRESSURE FIRE RETARDANT PER AMERICAN WOOD PRESERVERS ASSOCIATION STANDARD ANPA C21, EACH PIECE TO BEAR UL LABEL, CLASS 1 PLYWOOD CONCEALED FROM VIEW ONLY.

D. FINISHED LUMBER

1. INTERIOR STAIN GRADE WOOD: POPLAR, CONFORM TO AM QUALITY STANDARDS, TECHNOLOGY GRADE, AM GRADE 1.

2. MOISTURE CONTENT, KLN DRIED, NOT MORE THAN 9% WHEN DELIVERED.

3. FLAME SPREAD RATINGS AS NOTED ON DRAWINGS OR AS REQUIRED BY CODE.

E. PLYWOOD

1. PLANT GRADE PLYWOOD GROUP 1, GRADE A-C EXTERIOR PLYWOOD.

2. FLAME SPREAD RATINGS AS NOTED ON DRAWINGS OR AS REQUIRED BY CODE.

F. PARTICLE BOARD

1. INDUSTRIAL GRADE PARTICLE BOARD, 40-45 LB. DENSITY WESTERN GRADE PREFERRED.

G. INSTALLATION

1. INSTALL ALL MATERIAL WITH TIGHT JOINTS.

2. EASE ALL EXTERNAL CORNERS.

3. ALL RUNNING TRIM ONE PIECE UP TO 10'-0". MATCH GRAIN AND COLOR PIECE TO PIECE.

4. USE FINISH NAILS EXCEPT WHERE SCREWS INDICATED. SET FASTENERS FLUSH FOR PUTTY APPLICATION.

SECTION 06400 - ARCHITECTURAL WOODWORK

A. ALL WORK IS TO BE PERFORMED IN COMPLIANCE WITH "ARCHITECTURAL WOODWORK QUALITY STANDARDS, GUIDE SPECIFICATIONS AND QUALITY CERTIFICATION PROGRAM" CUSTOM GRADE, AS PUBLISHED BY THE ARCHITECTURAL WOODWORK INSTITUTE. ANY QUESTIONS CONCERNING APPLICATION OF THESE STANDARDS SHALL BE REFERRED TO THE ARCHITECT.

B. GC, TO PROVIDE AND INSTALL WOODWORK AS INDICATED ON THE PLANS.

SECTION - 07200 - THERMAL AND MOISTURE PROTECTION

A. MATERIALS

1. R-4 THERMAL BATT INSULATION: PREFORMED GLASS FIBER BATT WITH FSK-25 REFLECTIVE MEMBRANE ON ONE SIDE.

2. TAPES TO MATCH FOIL SORM KRAFT FACE, 2 INCH WIDTH.

3. R-10 RSD PERIMETER INSULATION UNDER SLABS ON GRADE.

B. INSTALLATION

1. INSTALL INSULATION IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS AND AS INDICATED.

2. TRIM INSULATION NEATLY TO FIT SPACES. INSTALL WITHOUT GAPS OR Voids.

3. INSTALLATION OF THERMAL BATT INSULATION

3.1. INSTALL INSULATION WITH VAPOR BARRIER TOWARD WARM SIDE OF BUILDING SPACES. VAPOR BARRIER SHALL BE CONTINUOUS. TAPE SEAL TEARS OR CUTS IN VAPOR BARRIER.

3.2. PACK BATT INSULATION IN SHIM SPACES AT PERIMETER OF WINDOW ASSEMBLY TO MAINTAIN CONTINUITY OF THERMAL BARRIER.

3.3. MECHANICAL FASTENING

3.3.1. AT LOCATIONS WHERE NO FRAMING IS PRESENT TO SUPPORT THE INSULATION, PROVIDE METAL INFILTRATING RING AND RETAINERS TO HOLD THE INSULATION FIRMLY IN PLACE.

3.3.2. MECHANICALLY OR ADHESIVELY BOND THE RETAINING RING TO THE SUBSTRATE IN ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATIONS.

3.3.3. SPACE RING AT MAXIMUM 24 INCHES ON CENTER ALONG THE EDGES AND WITHIN THE FIELD OF THE BLANKET. PLACE EDGE RING WITHIN 6 INCHES FROM THE EDGE OF THE BATT.

4. INSTALLATION OF RSD PERIMETER INSULATION: INSTALL INSULATION FROM TOP OF FOOTING TO UNDERSIDE OF SLAB AND BENEATH THE SLAB HORIZONTALLY 24" FROM THE INTERIOR FACE OF THE FOOTING.

C. R-VALUE SCHEDULES

1. PROVIDE INSULATION IN SUFFICIENT THICKNESS TO PROVIDE THE FOLLOWING R-VALUES:

II. VERTICAL ASSEMBLIES WITH HORIZONTAL HEAT FLOW: R205.

12. THE ABOVE R-VALUES ARE REQUIRED FOR THE TOTAL INSULATION IN THE ASSEMBLY. THE BATT INSULATION MAY BE COMBINED WITH OTHER INSULATION IN THE ASSEMBLY TO OBTAIN THE TOTAL R-VALUE REQUIRED. THE R-VALUE IS FOR THE INSULATION ONLY AND MAY NOT INCLUDE AIR FILM VALUES, AND R-VALUES FOR OTHER MATERIALS IN THE ASSEMBLY SUCH AS CONCRETE AND GYPSUM BOARD.

2. THE PERIMETER RSD INSULATION SHALL BE OF R-VALUE 10.

SECTION 07240 - EXTERIOR INSULATION AND FINISH SYSTEMS - CLASS PB

II. GENERAL

A. DEFINITIONS: SYSTEMS REFER TO CLASS PB EXTERIOR INSULATION AND FINISH SYSTEM (EPS) THAT IS DEFINED BY ASTM PS 44 AS A NONLOAD BEARING, EXTERIOR WALL CLADDING SYSTEM THAT CONSISTS OF AN INSULATION BOARD ATTACHED EITHER ADHESIVELY, MECHANICALLY, OR BOTH TO THE SUBSTRATE, AN INTERNALLY REINFORCED BASE COAT, AND A TEXTURE PROTECTIVE FINISH COAT. SYSTEM MANUFACTURER REFERS TO EPS MANUFACTURER.

B. THIS SECTION COVERS APPLICATIONS OVER PROPRIETARY PLAYWOOD SHEATHING.

C. PHYSICAL PROPERTIES: EPS COMPLYING WITH PERFORMANCE CHARACTERISTICS IN "BMA GUIDELINE SPECIFICATION FOR EXTERIOR INSULATION AND FINISH SYSTEMS, CLASS PB" INCLUDING WIND LOAD PER ASTM E 330 AS INDICATED AND IMPACT CLASSIFICATION AND RANGE PER BMA 1026 AS FOLLOWS.

STANDARD IMPACT RESISTANCE: 25-41 INCH LB

1. MEDIUM IMPACT RESISTANCE: 50-84 INCH LB.

2. HIGH IMPACT RESISTANCE: 10-60 INCH LB (0.21 J).

3. ULTRA-HIGH IMPACT RESISTANCE: MORE THAN 80 INCH LB (1 J).

B. SUBMITTALS: IN ADDITION TO PRODUCT DATA, SUBMIT THE FOLLOWING:

1. SHOP DRAWINGS: SHOW FABRICATION AND INSTALLATION OF SYSTEM INCLUDING PLANS, ELEVATIONS, SECTIONS, DETAILS OF COMPONENTS, JOINT LOCATIONS AND CONFIGURATIONS WITH SYSTEM AND BETWEEN SYSTEM AND CONSTRUCTION PENETRATING IT, TERMINATION DETAILS, AND ATTACHMENTS TO CONSTRUCTION BEHIND SYSTEM.

a. FOR INSTALLED PRODUCTS INDICATED TO COMPLY WITH CERTAIN DESIGN LOADS, INCLUDE STRUCTURAL ANALYSIS DATA SEALED AND SIGNED BY THE QUALIFIED PROFESSIONAL ENGINEER WHO WAS RESPONSIBLE FOR THEIR PREPARATION.

2. SAMPLES FOR EACH FINISH, COLOR, TEXTURE, AND PATTERN SPECIFIED.

3. INSTALLER CERTIFICATES: SIGNED BY SYSTEM MANUFACTURER CERTIFYING THAT INSTALLERS COMPLY WITH SPECIFIED REQUIREMENTS.

4. MATERIAL CERTIFICATES: SIGNED BY MANUFACTURERS OR A THIRD-PARTY AGENCY APPROVED BY SYSTEM MANUFACTURER CERTIFYING THAT INSULATION AND JOINT SEALANTS COMPLY WITH PROJECT REQUIREMENTS. INCLUDE JOINT SEALANT MANUFACTURERS INTERPRETATION OF TEST RESULTS RELATIVE TO SEALANT PERFORMANCE AND RECOMMENDATIONS FOR PRIMER AND SUBSTRATE PREPARATION NEEDED TO OBTAIN ADHESION. VERIFY COMPATIBILITY WITH ADJACENT MATERIALS, SUBSTRATES AND CONSTRUCTION.

5. PARTICLE BOARD.

1. INDUSTRIAL GRADE PARTICLE BOARD, 40-45 LB. DENSITY WESTERN GRADE PREFERRED.

2. PREPARE SURFACE FOR FIRE RETARDANT COATINGS.

G. INSTALLATION

1. INSTALL ALL MATERIAL WITH TIGHT JOINTS.

2. EASE ALL EXTERNAL CORNERS.

3. ALL RUNNING TRIM ONE PIECE UP TO 10'-0". MATCH GRAIN AND COLOR PIECE TO PIECE.

4. USE FINISH NAILS EXCEPT WHERE SCREWS INDICATED. SET FASTENERS FLUSH FOR PUTTY APPLICATION.

SECTION 06400 - ARCHITECTURAL WOODWORK

A. ALL WORK IS TO BE PERFORMED IN COMPLIANCE WITH "ARCHITECTURAL WOODWORK QUALITY STANDARDS, GUIDE SPECIFICATIONS AND QUALITY CERTIFICATION PROGRAM" CUSTOM GRADE, AS PUBLISHED BY THE ARCHITECTURAL WOODWORK INSTITUTE. ANY QUESTIONS CONCERNING APPLICATION OF THESE STANDARDS SHALL BE REFERRED TO THE ARCHITECT.

B. GC, TO PROVIDE AND INSTALL WOODWORK AS INDICATED ON THE PLANS.

SECTION - 07200 - THERMAL AND MOISTURE PROTECTION

A. MATERIALS

1. R-4 THERMAL BATT INSULATION: PREFORMED GLASS FIBER BATT WITH FSK-25 REFLECTIVE MEMBRANE ON ONE SIDE.

2. TAPES TO MATCH FOIL SORM KRAFT FACE, 2 INCH WIDTH.

3. R-10 RSD PERIMETER INSULATION UNDER SLABS ON GRADE.

B. INSTALLATION

1. INSTALL INSULATION IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS AND AS INDICATED.

2. TRIM INSULATION NEATLY TO FIT SPACES. INSTALL WITHOUT GAPS OR Voids.

B. EPS INDUSTRY MEMBERS ASSOCIATION STANDARDS AND PUBLICATIONS

1. 1026 - STANDARD TEST METHOD FOR FREEZE-THAW RESISTANCE OF EXTERIOR INSULATION FINISHING SYSTEMS (EPS), CLASS PB (MODIFIED ASTM C-671).

2. 1022 - STANDARD TEST METHOD FOR RESISTANCE TO WATER PENETRATION OF EXTERIOR INSULATION FINISHING SYSTEMS (EPS), CLASS PB (MODIFIED ASTM E 330).

3. 1028 - STANDARD TEST METHOD FOR DETERMINING TENSILE ADHESION STRENGTH OF EXTERIOR INSULATION FINISHING SYSTEMS (EPS), CLASS PB (MODIFIED ASTM C-271).

4. 1026 - STANDARD TEST METHOD FOR RESISTANCE OF EXTERIOR INSULATION FINISHING SYSTEMS (EPS) TO THE EFFECTS OF RAPID DEFORMATION (IMPACT).

6. 10501 - STANDARD TEST METHOD FOR ALKALI RESISTANCE OF GLASS FIBER REINFORCING MESH FOR USE IN EXTERIOR INSULATION FINISHING SYSTEMS.

7. 30001 - STANDARD TEST METHOD FOR DETERMINING TENSILE ADHESION PROPERTIES OF SEALANTS WHEN USED WITH EXTERIOR INSULATION FINISHING SYSTEMS.

8. BMA GUIDE FOR USE OF SEALANTS WITH EXTERIOR INSULATION FINISHING SYSTEMS.

9. BMA GUIDELINE SPECIFICATION FOR EXTERIOR INSULATION FINISHING SYSTEMS.

II. QUALITY ASSURANCE

A. MANUFACTURER QUALIFICATIONS: FIRM WITH MINIMUM 5 YEARS EXPERIENCE IN MANUFACTURING SYSTEMS SIMILAR TO THOSE INDICATED FOR THIS PROJECT AND THAT HAVE A RECORD OF SUCCESSFUL IN-SERVICE PERFORMANCE, WHO IS A CURRENT MEMBER OF THE BMA.

B. INSTALLER QUALIFICATIONS: EXPERIENCED INSTALLER WHO IS CERTIFIED IN WRITING BY SYSTEM MANUFACTURER AS QUALIFIED TO INSTALL MANUFACTURERS SYSTEM.

C. SINGLE SOURCE RESPONSIBILITY: OBTAIN MATERIALS FOR A SYSTEM FROM ONE SOURCE AND BY A SINGLE MANUFACTURER, OR BY MANUFACTURERS APPROVED BY THE SYSTEM MANUFACTURER AS COMPATIBLE WITH OTHER SYSTEM COMPONENTS.

D. PREINSTALLATION CONFERENCE: CONDUCT CONFERENCE AT PROJECT SITE WITH PARTIES ASSOCIATED WITH THE WORK.

12. COORDINATION AND STORAGE

A. ENVIRONMENTAL CONDITIONS: DO NOT INSTALL SYSTEM WHEN AMBIENT OUTDOOR AIR AND SUBSTRATE TEMPERATURES ARE 40 DEGREES F AND FALLING UNLESS TEMPORARY PROTECTION AND HEAT ARE PROVIDED TO MAINTAIN AMBIENT TEMPERATURES ABOVE 40 DEGREES F DURING THE INSTALLATION OF NET MATERIALS AND UNTIL THEY HAVE DRIED THOROUGHLY AND BECOME WEATHER RESISTANT, BUT NOT LESS THAN 24 HOURS AFTER INSTALLATION.

B. PROVIDE PROTECTION OF SURROUNDING AREAS AND ADJACENT CONSTRUCTION.

C. COORDINATE INSTALLATION OF SYSTEM WITH RELATED UNITS OF WORK SPECIFIED IN OTHER SECTIONS TO ENSURE THAT WALL ASSEMBLIES, INCLUDING SHEATHING, FLASHING, TRIM AND JOINT SEALERS ARE PROTECTED AGAINST DAMAGE FROM AFFECTS OF WEATHER, AGE, CORROSION AND OTHER CAUSES.

D. SELECTION OF MATERIALS: PROVIDE MATERIALS THAT COMPLY WITH THE FOLLOWING REQUIREMENTS:

1. FACTORY-MIXED FORMULATION DESIGNED FOR ADHESIVE ATTACHMENT OF INSULATION TO SUBSTRATES OF TYPE INDICATED, AS RECOMMENDED BY SYSTEM MANUFACTURER.

2. MOLDED-POLYSTYRENE BOARD INSULATION: COMPLY WITH SYSTEM MANUFACTURERS REQUIREMENTS, ASTM C 578 FOR TYPE I AND "BMA GUIDELINE SPECIFICATION FOR EXPANDED POLYSTYRENE (EPS) INSULATION BOARD" FOR MORE STRINGENT REQUIREMENTS, APPROVED BY SYSTEM MANUFACTURER FOR MATERIAL QUALITIES, INCLUDING CORNER SQUARENESS, OTHER DIMENSIONAL TOLERANCES, AND THE FOLLOWING:

1. SIZE BOARDS NOT MORE THAN 24 BY 48 INCHES AND IN THICKNESS INDICATED BUT NOT MORE THAN 4 INCHES OR LESS THAN THAT ALLOWED BY THE SYSTEM MANUFACTURER.

2. AGE INSULATION IN BLOCK FORM PRIOR TO CUTTING AND SHIPPING BY AIR DRYING FOR NOT LESS THAN 6 WEEKS OR BY ANOTHER METHOD APPROVED BY SYSTEM MANUFACTURER THAT PRODUCES EQUIVALENT RESULTS.

3. NOMINAL DENSITY: 10 PCF FOR EACH BOARD.

4. THERMAL RESISTANCE: MINIMUM R-40 AT 40 DEGREES F, 36 AT 75 DEGREES F WHEN TESTED IN ACCORDANCE WITH ASTM C 385.

5. PROVIDE SHAPES AND DENSITIES REQUIRED TO MAINTAIN SPECIAL SHAPES, IF REQUIRED.

6. REINFORCING MESH: BALANCED, ALKALI-RESISTANT, OPEN-WEAVE GLASS-FIBER MESH TREATED FOR COMPATIBILITY WITH OTHER SYSTEM MATERIALS, MADE FROM CONTINUOUS MULTIDIRECTIONAL STRANDED WITH RETAINED MESH TENSILE STRENGTH OF NOT LESS THAN 145 LBF/IN, AND 50 LBS IN WARP AND FILL DIRECTIONS PER ASTM D 5033, COMPLYING WITH ASTM D 578 AND THE FOLLOWING REQUIREMENTS FOR MINIMUM WEIGHT:

1. STANDARD REINFORCING MESH: NOT LESS THAN 0.4 OZ/SQ. YD. (36 G/SQ. M).

2. DETAIL REINFORCING MESH: NOT LESS THAN 0.4 OZ/SQ. YD. (36 G/SQ. M).

3. CORNER REINFORCING MESH: NOT LESS THAN 12 OZ/SQ. YD. (244 G/SQ. M).

K. BASE-COAT MATERIALS: SYSTEM MANUFACTURERS STANDARD MIXTURE COMPLYING WITH THE FOLLOWING REQUIREMENTS:

1. FACTORY-MIXED FORMULATION OF POLYMER-EMULSION ADHESIVE AND FIBER FILLERS THAT IS READY TO USE WITHOUT ADDING OTHER MATERIALS.

2. PRIMER: SYSTEM MANUFACTURERS STANDARD FACTORY-MIXED ELASTOMERIC-POLYMER PRIMER FOR PREPARING BASE-COAT SURFACE FOR APPLICATION OF FINISH COAT.

3. FINISH-COAT MATERIALS: SYSTEM MANUFACTURERS STANDARD FACTORY-MIXED FORMULATION OF POLYMER-EMULSION BINDER, COLORFAST MINERAL PIGMENTS, SOUND STONE PARTICLES, AND FILLERS AND SILENCE ENHANCED FINISH.

4. PHYSICAL PROPERTIES: PROVIDE EXTERIOR FINISH AND INSULATION SYSTEMS WHOSE PHYSICAL PROPERTIES AND STRUCTURAL PERFORMANCE COMPLY WITH THE FOLLOWING REQUIREMENTS WHEN TESTED PER METHOD REFERENCED:

1. ACCELERATED WEATHERING CHARACTERISTICS: SAMPLE OF SIZE SUITABLE FOR TEST EQUIPMENT AND CONSISTING OF 1 INCH THICK EXTERIOR INSULATION SYSTEM MOUNTED ON 1 INCH THICK GYPSUM BOARD, CURED FOR 28 DAYS, SHOWS NO WATER PENETRATION INTO THE PLANE OF THE INTERJOINT FACE OF THE TEST SPECIMEN UNDER 226 PSF OF AIR PRESSURE DIFFERENCE ACROSS THE SPECIMEN DURING A 5 MINUTE TEST PERIOD WHEN TESTED PER ASTM E 331.

2. WATER PENETRATION: SAMPLE CONSISTING OF 1 INCH THICK EXTERIOR INSULATION AND FINISH SYSTEM MOUNTED ON 1 INCH THICK GYPSUM BOARD, CURED FOR 28 DAYS, SHOWS NO WATER PENETRATION INTO THE PLANE OF THE INTERJOINT FACE OF THE TEST SPECIMEN UNDER 226 PSF OF AIR PRESSURE DIFFERENCE ACROSS THE SPECIMEN DURING A 5 MINUTE TEST PERIOD WHEN TESTED PER ASTM E 331.

3. IMPACT RESISTANCE: SAMPLE CONSISTING OF 1 INCH THICK EXTERIOR INSULATION AND FINISH SYSTEM MOUNTED ON 1 INCH THICK GYPSUM BOARD, CURED FOR 28 DAYS, SHOWS NO DESTRUCTIVE EFFECTS AFTER TESTING FOR 1000 HOURS PER METHOD 1 OF ASTM C 271.

4. TENSILE ADHESION: SAMPLE CONSISTING OF 1 INCH THICK EXTERIOR INSULATION AND FINISH SYSTEM MOUNTED ON 1 INCH THICK GYPSUM BOARD, CURED FOR 28 DAYS, SHOWS NO DESTRUCTIVE EFFECTS AFTER TESTING FOR 1000 HOURS PER METHOD 1 OF ASTM C 271.

5. TENSILE ADHESION: SAMPLE CONSISTING OF 1 INCH THICK EXTERIOR INSULATION AND FINISH SYSTEM MOUNTED ON 1 INCH THICK GYPSUM BOARD, CURED FOR 28 DAYS, SHOWS NO DESTRUCTIVE EFFECTS AFTER TESTING FOR 1000 HOURS PER METHOD 1 OF ASTM C 271.

6. TENSILE ADHESION: SAMPLE CONSISTING OF 1 INCH THICK EXTERIOR INSULATION AND FINISH SYSTEM MOUNTED ON 1 INCH THICK GYPSUM BOARD, CURED FOR 28 DAYS, SHOWS NO DESTRUCTIVE EFFECTS AFTER TESTING FOR 1000 HOURS PER METHOD 1 OF ASTM C 271.

7. TENSILE ADHESION: SAMPLE CONSISTING

6. CONTRACTOR MUST DISPOSE OF ALL DEBRIS IN AN APPROVED FACILITY IN ACCORDANCE WITH ALL LOCAL, STATE, AND FEDERAL REGULATIONS.

H. CONTRACTOR TO INSTALL THE MEMBRANE SYSTEM PER ALL LOCAL, STATE AND FEDERAL CODES AND REGULATIONS.

102 WARRANTY

A. ROOF TO HAVE DURO-LAST, INC.'S STANDARD WRITTEN FULL ROOFING SYSTEM REPAIR AND/OR REPLACEMENT 5-YEAR WARRANTY AT NO ADDITIONAL WARRANTY SHALL BE A NO-DOLLAR LIMIT THE CHARGE, COVERING MATERIALS AND LABOR, ISSUED BY THE ORIGINAL MANUFACTURER OF THE ROOFING MEMBRANE AND WARRANTY INCLUDE ALL ACCESSORIES SUPPLIED BY THE ROOFING MANUFACTURER. WARRANTY INCLUDES THE REPAIR OR REPLACEMENT OF MEMBRANE AND MATERIALS AND THE COST OF/ OR TURNKEYS OF LABOR AT THE CONTRACTOR LIST PRICE WHICH IS IN EFFECT AT THE TIME OF REPAIR. WARRANTY SHALL INCLUDE LOSS OF CONSEQUENTIAL DAMAGES DUE TO FAILURE OF THE ROOF SYSTEM AND CONTAIN NO EXCLUSIONS FOR PONDED WATER OR BIOLOGICAL GROWTH. NO PRIVATE LABEL PRODUCTS SHALL BE ACCEPTED. UPON WARRANTY INSPECTION AND ACCEPTANCE OF THE ROOF, THE WARRANTY SHALL BE TURNED OVER TO THE CONTRACTOR BY A DURO-LAST QUALITY ASSURANCE SPECIALIST.

103 HEIGHT REQUIREMENTS

A. THE TOTAL HEIGHT OF THE INSTALLED ROOFING SYSTEM INCLUDING ALL ACCESSORIES, GROUND PLATES, 2"X4" BREATHER VENTS, ETC., SHALL NOT EXCEED 25 POUNDS PER SQUARE FOOT. INSULATION HEIGHT VARIES ACCORDING TO R-VALUE DESIRED.

104 SUBMITTALS

A. WRITTEN CONFIRMATION FROM DURO-LAST ROOFING, INC. THAT THE INSTALLER IS AN AUTHORIZED DEALER/CONTRACTOR.

B. SHOP DRAWING SHOWING THE LAYOUT OF THE PREFABRICATED ROOFING PANELS.

C. CONTRACTOR SHALL INFORM THE OWNER PROJECT MANAGER OF ALL TIMELINES, SCHEDULES, AND CONSTRUCTION PROCESSES PRIOR TO WORK COMMENCEMENT.

105 PRODUCT DELIVERY, STORAGE, & HANDLING PROCEDURES

A. FOLLOW DURO-LAST, INC.'S INSTRUCTIONS, CAUTIONS, WARNINGS AND PROCEDURES.

B. ROOFING SYSTEM SHALL NOT BE APPLIED WHEN WEATHER CONDITIONS ARE NOT WITHIN THE RANGE ACCEPTABLE UNDER DURO-LAST'S RECOMMENDATIONS.

PART 2 PRODUCT

201 ROOF MEMBRANE

A. MEMBRANE COMPONENTS TO BE PRODUCTS OF DURO-LAST ROOFING, INC. NO SUBSTITUTIONS WILL BE ACCEPTED.

B. A SPECIAL FORMULATED, PERMANENT, THERMOPLASTIC ALLOY, BONDED TO A HIGH TENACITY, LOW SHRINKAGE HEFT, INSERTED POLYESTER FABRIC WITH RESISTANCE TO ULTRAVIOLET RAYS, MICROORGANISMS AND IMPERVIOUS TO MOST CAUSTIC CHEMICALS, ANIMAL FATS, GREASES AND OILS TYPICALLY FOUND ON A RESTAURANT ROOF.

C. MEMBRANE SHALL BE FACTORY DIELECTRICALLY WELDED INTO PREFABRICATED SHEETS UP TO 2500 SQUARE FEET OR AS DETERMINED BY JOB CONDITION.

D. THE NEW ROOFING SHALL BE A PREFABRICATED MECHANICALLY FASTENED INSTALLATION OF SINGLE-PLY REINFORCED MEMBRANE, 40 MILS THICK.

E. FIRE RESISTANCE OF THE THERMOPLASTIC ROOFING SYSTEM SHALL MEET UL CLASS A. ALL PACKAGINGS OF MEMBRANE AND INSULATION SHALL BEAR UL CLASS A LABEL.

F. MEMBRANE SHALL BE WHITE.

G. ALL ROOFING COMPONENTS USED AT ROOF PENETRATIONS SHALL BE PROVIDED BY DURO-LAST ROOFING, INC.

202 INSULATION

A. INSTALL TWO LAYERS OF NEW POLYISOCYANURATE INSULATION. NEW INSULATION MUST BE A MINIMUM OF R-30. INSTALL INSULATION ACCORDING ROOF MEMBRANE MANUFACTURERS SPECIFICATIONS.

203 ROOF WALK PADS

A. 24" X 24" SAFETY STRIPE WALK PADS AS MANUFACTURED BY DURO-LAST ROOFING.

PART 3 EXECUTION

301 SUBSTRATE INSPECTION

A. INSPECT ALL SURFACES TO RECEIVE ROOFING FOR ANY CONDITION THAT WILL ADVERSELY AFFECT EXECUTION, PERFORMANCE, OR QUALITY OF WORK.

B. ALL ROOF SURFACES AND ALL SLOPED SURFACES TO DRAINS AND OUTLETS SHALL BE CHECKED AND APPROVED BY THE ROOFING CONTRACTOR PRIOR TO THE START OF THE ROOFING WORK.

C. INSTALL ROOFING MATERIAL ONLY UNDER SATISFACTORY CONDITIONS AS SPECIFIED BY THE MEMBRANE MANUFACTURER.

302 GENERAL REQUIREMENTS

- A. PRECAUTIONS
1. DO NOT LAY OUT OR EXPOSE ANY INSULATION ON THE DECK THAT CANNOT BE COVERED BY MEMBRANE ON THE SAME DAY.
 2. IN MAKING ALL FIELD HEAT WELDS, MAKE SURE ALL EDGES ARE CLEAN AND FREE OF TAR, MASTIC OR OTHER FOREIGN ITEMS.
 3. DO NOT DISPOSE MEMBRANE AND ACCESSORIES TO A CONSTANT TEMPERATURE IN EXCESS OF 10 DEGREES FAHRENHEIT.
 4. SEALANTS AND ADHESIVES SHOULD BE APPLIED ACCORDING TO DURO-LAST, INC.'S SPECIFICATIONS.
 5. START SECURING THE MEMBRANE AT THE HIGHEST POINT AND WORK TOWARDS THE DRAINS.

B. PROTECTION OF ROOFING SURFACES STORING, WHEELING, OR TRUCKING DIRECTLY ON ROOF INSULATION OR MEMBRANE SURFACE IS NOT RECOMMENDED. SMOOTH, CLEAN PLYWOOD OR PLANK WALKWAYS, RUNWAYS AND PLATFORMS SHALL BE PROVIDED AS NECESSARY.

303 INSULATION INSTALLATION

A. THE ROOF INSULATION SHALL BE INSTALLED WITH APPROVED FASTENERS AND DISTRIBUTION PLATES PLACED ACCORDING TO THE MANUFACTURERS MOST RECENT PUBLISHED SPECIFICATIONS FOR THE USE UNDER THE DURO-LAST ROOFING SYSTEM AND FOR ISOLANCE OF THE WARRANTY.

304 MEMBRANE INSTALLATION

A. INSTALL THE ROOFING SYSTEM TO DURO-LAST, INC.'S MOST RECENT PUBLISHED SPECIFICATIONS.

305 INSPECTION & WARRANTY

A. AFTER THE INSTALLATION IS COMPLETE, A DURO-LAST QUALITY ASSURANCE SPECIALIST SHALL INSPECT THE VISIBLE DETAILS OF THE ROOFING SYSTEM FOR ACCEPTABILITY FOR WARRANTY. ESUNCE ANY DEFICIENCIES SHALL BE CORRECTED BY THE CONTRACTOR AND MADE READY FOR REINSPECTION WITHIN FIVE (5) WORKING DAYS. UPON ACCEPTANCE, THE WARRANTY SHALL BE PROMPTLY ISSUED.

SECTION - 07840 - FIRESTOPPING

A. SUMMARY: FIRESTOPPING MATERIAL FOR PENETRATIONS IN FIRE-RATED CONSTRUCTION

B. SYSTEM DESCRIPTION

1. EACH FIRESTOPPING SYSTEM SHALL BE SELECTED TO MAINTAIN FIRE RATING OF THE ASSEMBLY IN WHICH IT USED.
2. FIRESTOPPING SYSTEMS SHALL BE RESILIENT AS NECESSARY TO ACCOMMODATE DIFFERENTIAL MOVEMENT BETWEEN ASSEMBLIES.

C. QUALITY ASSURANCE

1. PRIOR TO INSTALLATION OF FIRE STOPPING SYSTEMS OBTAIN APPROVAL FROM THE JURISDICTIONAL CODE AUTHORITIES FOR THE FIRE STOPPING SYSTEMS AND APPLICATIONS PROPOSED. NOTIFY THE OWNER / REPRESENTATIVE IF APPROVAL CANNOT BE OBTAINED.
2. FIRESTOPPING TESTED IN ACCORDANCE WITH ASTM E81, ASTM E84, OR UL 1711 TO MEET THE HOURLY FIRE RATINGS OF THE CONSTRUCTION BEING SEALED. PROVIDE FIRE RATED ASSEMBLIES, EXCEPT WHERE T-RATED ASSEMBLIES ARE REQUIRED BY THE CODE AUTHORITY.
3. FIRESTOPPING SYSTEMS SHALL BE UL LISTED ASSEMBLIES.

D. PRODUCTS

1. FIRESTOPPING SYSTEMS: SYSTEMS MEETING THE REQUIREMENTS SPECIFIED AND SUITABLE FOR THE CONDITIONS INDICATED.

E. INSTALLATION

1. PROVIDE FIRESTOPPING AT MECHANICAL, ELECTRICAL, AND PLUMBING PENETRATIONS THROUGH FIRE RATED FLOORS, WALLS, AND CEILINGS, AND OTHER LOCATIONS AS INDICATED ON THE DRAWINGS.
2. INSTALL FIRESTOPPING IN ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATIONS AND AS NECESSARY TO MEET THE SPECIFIED FIRE RATING REQUIREMENTS.
3. WHERE FIRESTOPPING IS USED TO SEAL AROUND PENETRATIONS THROUGH WATERPROOF MEMBRANES, INSTALL TO MAINTAIN INTEGRITY OF WATERPROOF BARRIER.
4. PATCHING OF HOLES IN EXISTING CONSTRUCTION
 41. FILL OPEN HOLES WHICH REMAIN AFTER REMOVAL OF EXISTING MECHANICAL, ELECTRICAL, AND PLUMBING COMPONENTS, PATCH AND REPAIR HOLES AS NECESSARY TO MATCH THE ADJACENT CONSTRUCTION AND TO MAINTAIN THE FIRE RATING OF THE ASSEMBLIES. FIRESTOPPING SYSTEMS MAY BE USED TO FILL HOLES THAT WILL BE CONCEALED IN THE FINISH CONSTRUCTION.
 42. WHERE FIRESTOPPING SYSTEMS ARE USED TO FILL FLOOR OPENINGS IN OCCUPIED AREAS, PROVIDE MINIMUM 1/8 GAGE SHEET METAL COVER AS NECESSARY TO SUPPORT FLOOR LOADS AND TO PREVENT DAMAGE TO THE FIRE STOPPING ASSEMBLIES. SECURE SHEET METAL AS NECESSARY TO PREVENT IRREGULARITIES FROM TELEGRAPHING THROUGH THE FLOOR FINISHES OVER THE SHEET METAL.

SECTION - 07850 - FIRE RATED JOINTS

A. SUMMARY:

1. FIRE RATED CONSTRUCTION JOINT ASSEMBLIES IN FIRE-RATED CONSTRUCTION, INCLUDING JOINTS AT THE FOLLOWING LOCATIONS:
 11. WHERE PARTITION HEADS MEET THE UNDERSIDE OF OVERHEAD FLOOR OR ROOF CONSTRUCTION.
 12. JOINTS IN FIRE RATED CONCRETE OR MASONRY WALLS.
2. REQUIREMENTS FOR FIRE RATED CONSTRUCTION JOINT ASSEMBLY COMPONENTS PROVIDED IN OTHER SECTIONS.

B. REFERENCES

1. AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)
 11. E81 - METHOD FOR FIRE TESTS OF BUILDING CONSTRUCTION AND MATERIALS.
2. UNDERWRITERS LABORATORIES (UL)

21. STANDARD 207M - TESTS FOR FIRE RESISTANCE OF BUILDING JOINT SYSTEMS.

C. SYSTEM DESCRIPTION

1. EACH FIRE RATED CONSTRUCTION JOINT ASSEMBLY SHALL BE SELECTED TO MAINTAIN FIRE RATINGS OF THE ASSEMBLY IN WHICH IT USED.
2. EACH FIRE RATED CONSTRUCTION JOINT ASSEMBLY SHALL BE RESILIENT AS NECESSARY TO ACCOMMODATE DIFFERENTIAL MOVEMENT BETWEEN ASSEMBLIES.

D. QUALITY ASSURANCE

1. FIRE RATED CONSTRUCTION JOINT ASSEMBLIES: SUCCESSFULLY TESTED IN ACCORDANCE WITH ASTM E81, INCLUDING HOSE STREAM TEST, TO MEET THE HOURLY RATINGS OF THE CONSTRUCTION BEING SEALED.
2. FIRE RATED CONSTRUCTION JOINT ASSEMBLIES AT PARTITION HEADS SHALL HAVE BEEN SUCCESSFULLY TESTED IN ACCORDANCE WITH THE DYNAMIC REQUIREMENTS OF UL 207M, INCLUDING HOSE STREAM TEST, TO MEET THE HOURLY FIRE RATINGS OF THE CONSTRUCTION BEING SEALED.

E. FIRE RATED CONSTRUCTION JOINT ASSEMBLIES

1. METAL STUD PARTITION HEAD CONSTRUCTION JOINT ASSEMBLY:

11. SYSTEM: BASED ON UL ASSEMBLIES LISTED ON THE DRAWINGS.
12. FIRE RATED RUNNER, FIRE TRAK® BY FIRE TRAK CORPORATION, KIMBALL, MI. (62-318-1200).
13. GYPSUM BOARD: AS SPECIFIED IN SECTION 04050.
14. FILL, VOID, OR CAVITY MATERIAL: AS LISTED IN THE FIRE RATED ASSEMBLY.

F. INSTALLATION

1. INSTALL CONSTRUCTION JOINT ASSEMBLIES IN ACCORDANCE WITH THE FIRE RATED ASSEMBLIES LISTED, AND AS NECESSARY TO MEET THE SPECIFIC FIRE RATINGS REQUIREMENTS.
2. COORDINATE INSTALLATION OF INTEGRAL COMPONENTS AS NECESSARY TO ENSURE THE FIRE RATINGS OF THE ASSEMBLIES.

SECTION - 07920 - JOINT SEALANTS

A. QUALITY ASSURANCE: USE ONLY SKILLED INSTALLERS SPECIALLY TRAINED IN THE TECHNIQUES OF SEALING, AND FAMILIAR WITH THE PUBLISHED RECOMMENDATIONS OF THE MANUFACTURERS OF THE SEALANTS BEING USED.

B. SEALANTS:

1. TYPE S - NEUTRAL CURE SILICONE SEALANTS
11. DOW CORNING, 790 SILICONE BUILDING SEALANT, OR 795 SILICONE STRUCTURAL GLAZING AND WEATHERPROOFING SEALANT.
12. PECORA, 840 ARCHITECTURAL SILICONE SEALANT.
2. TYPE PTMS: ASTM C420, TYPE M, GRADE NS, CLASS 25, PECORA "DYNATREED", TREMCO 11PL, OR APPROVED, CUSTOM COLORS TO MATCH ADJACENT GROUT COLOR.
3. TYPE A: ASTM C824; TREMCO "ACRYLIC LATEX CAULK", PECORA "AC-207, SONNEBORN "SONOLAC" OR APPROVED.
4. TYPE SM: MILDEW RESISTANT SILICONE SEALANT, USDA APPROVED, DOW CORNING 796 BY DOW CHEMICAL, GE SANITARY SEALANT OR APPROVED, CLEAR.
5. TYPE SG: SILL GASKET; DOW STYROFOAM SILL SEAL, FOAM GASKET

C. ACCESSORY MATERIALS

1. PRIMER: NON-STAINING TYPE, RECOMMENDED BY SEALANT MANUFACTURER TO SUIT APPLICATION.
2. JOINT CLEANER: NON-CORROSIVE AND NON-STAINING TYPE, RECOMMENDED BY SEALANT MANUFACTURER, COMPATIBLE WITH JOINT FORMING MATERIALS.
3. JOINT FILLER: CLOSED CELL POLYETHYLENE FOAM, ROUND PROFILE, THICKNESS 50% OF JOINT WIDTH.
4. BOND BREAKER: PRESSURE SENSITIVE TAPE RECOMMENDED BY SEALANT MANUFACTURER TO SUIT APPLICATION.

D. PREPARATION

1. CLEAN AND PREPARE JOINTS IN ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS. REMOVE LOOSE MATERIALS AND OTHER FOREIGN MATTER THAT MIGHT IMPAIR ADHESION OF SEALANT.
2. APPLY MASKING TIGHTLY AROUND JOINTS TO PROTECT ADJACENT SURFACES FROM EXCESS SEALANT.
3. PRIME AS REQUIRED FOR PROPER BOND TO SUBSTRATE MATERIALS.
4. PLACE BACKING MATERIALS TO ACHIEVE PROPER SEALANT WIDTH/DEPTH RATIOS. USE BOND BREAKER WHERE REQUIRED.

E. INSTALLATION

1. PERFORM WORK IN ACCORDANCE WITH ASTM G83, UNLESS SPECIFIED OTHERWISE OR RECOMMENDED OTHERWISE BY THE SEALANT MANUFACTURER.
2. SEALANT BEADS SHALL HAVE A SECTIONAL WIDTH TO DEPTH RATIO OF 2 TO 1.
3. INSTALL TYPE PTMS SEALANT FULL DEPTH IN TILE EXPANSION JOINTS WITH NO BACKER ROD.
4. TOOL JOINTS CONCAVE, UNLESS INDICATED OTHERWISE. FINISH FREE OF AIR POCKETS, FOREIGN EMBEDDED MATTER, RIDGES, AND SAGS.

F. PROTECT SEALANT IN JOINTS SUBJECT TO DIRT, MOISTURE, AND TRAFFIC DURING THE SEALANT CURING PROCESS. PROTECTION SHALL BE ABLE TO RESIST TRAFFIC WHILE REMAINING SECURELY IN POSITION.

G. SCHEDULES

1. TYPE S: PROVIDE AT ALL EXTERIOR JOINTS; STANDARD COLORS AS SELECTED BY OWNER / REPRESENTATIVE.
2. TYPE PTMS: PROVIDE AT ALL EXPANSION JOINTS IN STONE AND TILE; CUSTOM COLORS TO MATCH GROUT SAMPLES SUBMITTED BY THE TILE INSTALLER.
3. TYPE A: PROVIDE AT ALL INTERIOR JOINTS, UNLESS SPECIFIED OTHERWISE; STANDARD COLORS TO MATCH ADJACENT CONSTRUCTION.
4. TYPE SM: PROVIDE AT JOINTS AROUND COUNTER.
5. TYPE SG: PROVIDE AT ALL LOCATIONS WHERE A WOOD SILL PLATE OCCURS OVER A CONCRETE OR MASONRY SURFACE.

SECTION 0800 - METAL DOORS AND FRAMES

A. FIRE LABELS

PROVIDE UNDERWRITERS' LABELS ON DOORS AND FRAMES WHERE, AND OF CLASS INDICATED.

B. REFERENCE STANDARDS

1. STEEL DOOR INSTITUTE
 - SD-100 - RECOMMENDED SPECIFICATIONS FOR STANDARD STEEL DOORS AND FRAMES.
2. NATIONAL ASSOCIATION OF ARCHITECTURAL METAL MANUFACTURERS
 - NAAMM-04M SPECIFICATIONS FOR CUSTOM HOLLOW METAL DOORS AND FRAMES.
3. AMERICAN SOCIETY FOR TESTING AND MATERIALS
 - ASTM A366 - SPECIFICATION OF STEEL, CARBON, COLD-ROLLED SHEET QUALITY COMMERCIAL.

G. MATERIALS

1. CONFORM TO NAAMM, PAGES 3 THROUGH 6. CONFORM TO NAAMM FOR LABELED CONSTRUCTION.
2. ZINC-COAT ANY EXTERIOR DOORS, AND DOOR FRAMES, WHEN APPLICABLE STANDARD.
3. SOUND DEADENING: MANUFACTURERS STANDARD INORGANIC NON COMBUSTIBLE INSULATION.
4. ANCHORS, FASTENERS, AND ACCESSORIES: MANUFACTURERS

D. STEEL DOOR FRAME FABRICATION AND MANUFACTURER

KNOCK DOWN FRAMES: PROVIDE STANDARD TYPE, KNOCKED-DOWN FRAMES DESIGNED TO BE SECURELY INSTALLED IN THE ROUGH OPENING AFTER FINISH WALL MATERIAL IS APPLIED.

E. PREPARATION OF FINISH HARDWARE

1. WORK TO TEMPLATES FOR ALL HARDWARE CONFORM TO STANDARDS OF HARDWARE MANUFACTURER.

F. INSTALLATION

1. CONFORM TO NAAMM, PAGE 6, PART 3
2. KNOCK-DOWN FRAMES: FILL FRAME INTER WITH APPROVED FILLER, AND SMOOTH AND PRIME.

SECTION - 0805 - HOLLOW METAL DOORS AND FRAMES

A. SUMMARY: HOLLOW STEEL DOORS AND FRAMES

B. REFERENCES

1. NATIONAL FIRE PROTECTION ASSOCIATION (NFPA): NFPA 80 - FIRE DOORS AND WINDOWS.
2. STEEL DOOR INSTITUTE (SDI)
 21. SD-100 - STANDARD STEEL DOORS AND FRAMES.
 22. SD-105 - RECOMMENDED DIRECTION INSTRUCTIONS FOR STEEL FRAMES.
3. AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)
 31. A366 - SPECIFICATION FOR STEEL, CARBON, COLD ROLLED SHEET, COMMERCIAL QUALITY.
 32. A564 - SPECIFICATION FOR STEEL, CARBON (65 MAXIMUM PERCENT), HOT ROLLED SHEET AND STRIP, COMMERCIAL QUALITY.

C. QUALITY ASSURANCE

1. CONFORM TO REQUIREMENTS OF SD-100.
2. REGULATORY REQUIREMENTS
 21. INSTALLED FRAME AND DOOR ASSEMBLY SHALL CONFORM TO NFPA 80 FOR FIRE RATED CLASS INDICATED.
 22. WHERE DOORS ARE NOTED WITH AN HOURLY FIRE RESISTANCE RATING, PROVIDE DOOR AND FRAME ASSEMBLIES LABELED BY UNDERWRITERS LABORATORY OR ANY OTHER TESTING LABORATORY APPROVED BY THE LOCAL CODE AUTHORITIES TO MEET THE HOURLY FIRE RATINGS NOTED. ASSEMBLIES SHALL MEET JURISDICTIONAL REQUIREMENTS FOR POSITIVE PRESSURE.
 23. WHERE A HOLLOW METAL FRAME IS USED AS A GLAZED OPENING IN AN INTERIOR FIRE RATED WALL ASSEMBLY, THE FRAME SHALL BE LABELED TO MATCH THE FIRE RATING REQUIRED FOR A DOOR ASSEMBLY IN THE FIRE RATED WALL, EXCEPT IN A 1 HOUR FIRE RATED CORRIDOR WALL ASSEMBLY, THE GLAZED FRAME SHALL BE LABELED TO A 45 MINUTE RATINGS. IN A HOUR FIRE RATED CORRIDOR WALL ASSEMBLY, WHERE THE DOOR FRAME IS INTEGRAL WITH THE GLAZED FRAME, THE FRAME SHALL HAVE A 45 MIN RATINGS.
3. INCLUDE 1/2" LABEL ON FIRE RATED DOOR ASSEMBLIES WHICH ARE LOCATED AT 1 HOUR RATED EXIT CORRIDORS WHEN REQUIRED BY LOCAL JURISDICTION.
4. MEMBERS OF THE STEEL DOOR INSTITUTE AND OF THE NATIONAL ASSOCIATION OF ARCHITECTURAL METAL MANUFACTURERS, SUBJECT TO COMPLIANCE WITH THE SPECIFIED REQUIREMENTS.

D. MATERIALS

3. STEEL SHEET: COLD ROLLED ASTM A366, OR HOT ROLLED PICKLED AND OILED SHEET CONFORMING TO ASTM A564.

E. DOORS

1. SD-100, SEAMLESS DESIGN.
2. MINIMUM 1/8-GAGE FACE SHEETS FOR INTERIOR DOORS; MINIMUM 1/6 GAGE FACE SHEETS FOR EXTERIOR DOORS.
3. CORES
 31. INTERIOR DOORS: VERTICAL STEEL STIFFENERS WITH SOUND DEADENING FILL BETWEEN STIFFENERS, OR RESIN IMPREGNATED KRAFT PAPER HONEYCOMB CORE.
 32. EXTERIOR DOORS: POLYSTYRENE OR POLYURETHANE FOAM CORE.
4. PROVIDE CONTINUOUSLY WELDED SEAMLESS EDGES. NO PLASTIC FILLERS WILL BE ACCEPTED.

F. FULLY WELDED FRAMES

1. DESIGN: DOUBLE RABBIT, UNLESS INDICATED OTHERWISE; FULLY WELDED.
2. EXTERIOR FRAMES: MINIMUM 1/4 GAGE.
3. INTERIOR FRAMES: MINIMUM 1/6 GAGE FOR FRAMES OF DOOR OPENINGS UP TO AND INCLUDING 4 FEET IN WIDTH 1/4 GAGE FOR FRAMES GREATER THAN 4 FEET IN WIDTH.
4. PROVIDE EXTENDED RETURN LEGS AT EXTERIOR OPENINGS AS INDICATED TO SUPPORT SEALANT SYSTEMS.

G. FABRICATION

1. SHOP-FABRICATE UNITS TO ACCOMMODATE THE HARDWARE SPECIFIED IN SECTION 0810.
 2. FABRICATE FRAMES AND DOORS WITH HARDWARE REINFORCEMENT PLATES WELDED IN PLACE. REINFORCE FOR BUTTS, CLOSERS, AND OTHER SIMILAR MOVING HARDWARE ITEMS. REINFORCING SHALL BE MINIMUM 3/16-INCH STEEL PLATE. REINFORCE EACH BUTT WITH MINIMUM 1/2X1/2 X 1/2 INCH PLATE ON HINGE SIDES OF BOTH DOOR AND FRAME. REINFORCE FOR CLOSERS THE FULL WIDTH OF THE DOOR.
 3. REINFORCE FRAMES UNDER 48 INCHES WITH ROLL FORMED STEEL CHANNELS FITTED TIGHTLY INTO FRAME HEAD, FLUSH WITH TOP.
 4. CLOSE TOP AND BOTTOM EDGES OF DOORS WITH STEEL CHANNEL, MINIMUM 1/8-GAUGE EXTENDING FULL WIDTH OF DOOR, SPOT-WELDED TO BOTH FACES. CLOSE TOP EDGES OF EXTERIOR DOORS FLUSH WITH STEEL FILLER CAP, SEAL JOINTS WATER-TIGHT.
 5. FINISH AT EXTERIOR UNITS MODIFIED EPOXY ESTER BAKED-ON PRIMER TO RECEIVE URETHANE COATINGS SPECIFIED IN SECTION 0900, OR SERIES 64 EPOXYLINE F BY THERMAX, OR SERIES 880® BY CARBOLINE.
 6. PROVIDE METAL RAIN HOOD FOR EXTERIOR DOOR FRAMES.
 7. ATTACH FIRE RATED LABEL TO EACH FRAME AND DOOR UNIT.
- H. INSTALLATION OF WELDED FRAMES
1. INSTALL FRAMES IN ACCORDANCE WITH SD-105 AND IN ACCORDANCE WITH LABELING REQUIREMENTS.
 2. COORDINATE WITH WALL CONSTRUCTION FOR ANCHOR PLACEMENT.
 3. INSTALL ACCESSORIES.
 4. INSTALLATION TOLERANCES
 41. MAXIMUM DIAGONAL DISTORTION 1/16 INCH MEASURED WITH STRAIGHT EDGE, CORNER TO CORNER.
 42. INSTALL DOORS PLUMB AND LEVEL TO 1/16 INCH IN 7 FEET.

I. DOOR INSTALLATION

1. FIT AND PREPARE DOORS FOR INSTALLATION IN ACCORDANCE WITH THE DOOR MANUFACTURERS PRINTED INSTRUCTIONS.
2. INSTALL DOORS PLUMB AND SQUARE.
3. FABRICATE FOR 1/8 INCH CLEARANCE AT HEAD AND EACH JAMB, 1/8 INCH BETWEEN PARS OF DOORS, 3/16 INCH CLEARANCE FROM HARD SURFACE FINISH FLOOR, 3/4 INCH FROM HARD SURFACE BENEATH DOORS AT OPENINGS INDICATED TO RECEIVE CARPETING, AND 3/16 INCH CLEARANCE ABOVE TOP OF THRESHOLD.
4. INSTALL ROSES, KICK PLATES, CLOSERS, AND OTHER SURFACE MOUNTED HARDWARE ONLY AFTER DOOR FINISHING IS COMPLETE AND FINISHES ARE COMPLETELY CURED.
5. FIT HOLLOW METAL DOORS IN ACCORDANCE WITH SDI 100.
6. DOOR AND HARDWARE INSTALLATION IS SPECIFIED IN SECTION 0810.

SECTION 0820 - WOOD DOORS

A. DESCRIPTION OF SYSTEMS: REFER TO DOOR SCHEDULE FOR DOOR SPECIFICATION.

B. CODES AND STANDARDS

A. SECTION - 08305 - ACCESS DOORS

A. ACCESSIBLE MANUFACTURERS

1. ACCESS PANEL SOLUTIONS (B71) 542-0033

B. DOOR TYPES

1. NON RATED CONCEALED DRYWALL ACCESS DOOR.

11. RECESSED TYPE DESIGN

12. GLASS FIBER REINFORCED PANEL.

13. INTEGRAL ATTACHMENT FLANGE AND DRYWALL BEAD FOR FLUSH INSTALLATION.

14. FULLY CONCEALED PIVOT ROD HINGE.

15. LATCHES: SCREWDRIVER OPERATED CAM LATCH.

C. MINIMUM SIZES: PROVIDE ACCESS DOORS IN SIZES INDICATED. WHEN NOT INDICATED PROVIDE 12" X 12" SIZE FOR HAND ACCESS, AND 24" X 24" SIZE FOR MAN ENTRY.

D. INSTALLATION

1. PROVIDE ACCESS DOORS IN THE LOCATIONS INDICATED, AND FOR ACCESS TO BALANCING AND FIRE DAMPERS, TRAP PRIMERS, VALVES, FANS, TERMINAL UNITS, AND OTHER EQUIPMENT REQUIRING PERIODIC INSPECTION OR MAINTENANCE THROUGH FINISHED WALLS OR CEILINGS, WHETHER INDICATED OR NOT.
2. COORDINATE ACCESS REQUIREMENTS WITH OTHER TRADES AND LANDLORD.

SECTION - 0845 - ALUMINUM STOREFRONTS AND ENTRANCES

A. SUMMARY:

1. EXTERIOR ALUMINUM FRAMED WINDOW SYSTEMS.

B. REFERENCES

1. AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)
 11. B209 - ALUMINUM AND ALUMINUM ALLOY SHEET AND PLATE.
 12. B221 - ALUMINUM ALLOY EXTRUDED BARS, RODS, WIRE, SHAPES, AND TUBES.
 13. E289 - RATE OF AIR LEAKAGE THROUGH EXTERIOR WINDOWS, CURTAIN WALLS, AND DOORS.
 14. E330 - STRUCTURAL PERFORMANCE OF EXTERIOR WINDOWS, CURTAIN WALLS, AND DOORS BY UNIFORM STATIC AIR PRESSURE DIFFERENCE.
2. ARCHITECTURAL ALUMINUM MANUFACTURERS ASSOCIATION (AAMA).

C. SYSTEM DESCRIPTION

1. PERFORMANCE - EXTERIOR ALUMINUM WINDOW AND STOREFRONT SYSTEM
 11. SYSTEM SHALL ACCOMMODATE EXPANSION AND CONTRACTION CAUSED BY A TEMPERATURE RANGE OF 0 DEGREES F. TO 180 DEGREES F. WITHOUT DETRIMENTAL EFFECTS TO COMPONENTS, SEALING SYSTEMS, AND SURROUNDING CONSTRUCTION (AAMA 505-45).
 12. DESIGN SYSTEM WITH PROVISIONS TO DRAIN MOISTURE TO THE EXTERIOR OF THE SYSTEM.
 13. AIR INFILTRATION: SHALL NOT EXCEED .05 CFM PER SQUARE FOOT OF FIXED AREA WHEN TESTED IN ACCORDANCE WITH ASTM E283 AT 6.24 PSF.
 14. WATER INFILTRATION: NO WATER PENETRATION WHEN MEASURED IN ACCORDANCE WITH ASTM E331 AT (5) PSF AND WITH AAMA 504-44 AT (5) PSF.
2. WINDOW AND STOREFRONT STRUCTURAL DESIGN
 21. DESIGN AND SIZE MEMBERS TO WITHSTAND POSITIVE AND NEGATIVE WIND LOADS AS REQUIRED BY THE LOCAL JURISDICTIONAL AUTHORITY.
 22. LIMIT MILLION DEFLECTION TO VTB, OR FLEXURE LIMIT OF (3/4)" GLASS WITH FULL RECOVERY OF GLAZING MATERIALS, WHICHEVER IS LESS, (ASTM E-330).

D. WARRANTY: FURNISH FIVE YEAR WRITTEN WARRANTY EXECUTED TO THE OWNER FROM THE MANUFACTURER OF THE STOREFRONT SYSTEM, AGAINST DEFECTS IN MATERIALS AND WORKMANSHIP, IN ACCORDANCE WITH SECTION 0710.

E. MATERIALS

1. EXTRUDED ALUMINUM: ASTM B209, 6063 T5 ALLOY AND TEMPER.
2. SHEET ALUMINUM: ASTM B209, 5005-H32 ALLOY, OR APPROVED.

F. COMPONENTS

1. ACCESSIBLE MANUFACTURERS
 11. ANHELD BUILDING PRODUCTS DIVISION
 12. CECO
 13. CURRIES
 14. MESKER
 15. STEEL CRAFT, BY AMERICAN STANDARD

2. DOORS: BY MANUFACTURER

3. STOREFRONT AND WINDOW FRAMING

31. WHERE RECONFIGURATION OF EXISTING FRAMING IS SHOWN, MATCH DIMENSIONS, PROFILE, GLAZING THICKNESS AND FINISH OF EXISTING ALUMINUM WINDOW FRAMING.
32. PROVIDE THERMALLY BROKEN OR THERMALLY IMPROVED ASSEMBLIES AT ALL EXTERIOR SYSTEMS.
4. GLAZING BEADS: MANUFACTURERS STANDARD EPDM OR NEOPRENE GLAZING BEADS, FOR A COMPLETE WEATHERPROOF SEAL. FURNISH FOR INSTALLATION AS A PART OF THE WORK OF SECTION 0800.

5. FLEXIBLE FLASHING

51. WIR, GRACE VYCOR PLUS®.

52. MONEY BAKOR "BLUESKIN" 40 MIL THICKNESS.

D. MATERIALS

1. TILE TYPES AS SCHEDULED ON THE DRAWINGS.

2. SETTING MATERIALS

21. THINSET MORTAR: LATEX-PORTLAND CEMENT IN ACCORDANCE WITH ANSI A84.100 & ACRYLIC LATEX ADDITIVE AT ALL LOCATIONS. "KERABOND" WITH "UNIVERSAL KERALASTIC" BY MAPS CORP, DEERFIELD, FL (800/462-2784), OR "I-CRETE FILLER POWDER" WITH "425T LATEX THIN-SET ADDITIVE" BY LATCRETE INTERNATIONAL, BETHANY, CT (800/248-4788). PROPORTIONS AS RECOMMENDED BY THE MANUFACTURER, OR APPROVED.

22. RAPID-SET THIN BED MORTAR, LATEX MODIFIED, MINIMUM 400 PSI 28 DAY SHEAR STRENGTH TO PORCELAIN (IMPERVIOUS) TILES; "GRANIRAPID" WITH "KER 380" FLEXIBLE ADMIXTURE" BY MAPS CORP, OR "I-CRETE FILLER POWDER" WITH "425T LATEX THIN-SET MORTAR ADDITIVE" AND "I-CI RAPID SET LATEX" PROPORTIONS AS RECOMMENDED BY THE MANUFACTURER FOR THE SETTING TIME REQUIRED; SAVED; EXCEPT UNBANNED AT JOINTS SCHEDULED BY LATCRETE INTERNATIONAL, INC.

23. ORGANIC ADHESIVES ANSI A84.1 TYPE I PROVIDE PRIMER/SEALER AS RECOMMENDED BY THE ADHESIVE MANUFACTURER.

3. GROUT

31. "45 RAVEN" SPECTRALOCK EPOXY GROUT OR 2000CS (INDUSTRIAL GROUT) BY LATCRETE INTERNATIONAL.

32. FAST SETTING GROUT: "FLOOR JOINT AND GROUT FILLER" WITH "5101 LATEX MORTAR ADMIXTURE" OR "I-CI RAPID SET LATEX" BY LATCRETE INTERNATIONAL, INC. (PROPORTIONS AS RECOMMENDED BY THE MANUFACTURER FOR THE SETTING TIME REQUIRED); SAVED; EXCEPT UNBANNED AT JOINTS SCHEDULED AT 1/8" NCH JOINTS.

4. METAL SCREED AS MANUFACTURED BY SCHLUTER SYSTEMS, INC. (800/225-8402) CLEAR ANODIZED ALUMINUM TILE EDGES TRIM SIZES AS REQUIRED FOR INSTALLATION OF TOP OF SCREED FLUSH WITH TOP OF TILE, OR AS OTHERWISE DETAILED.

5. CRACK ISOLATION MEMBRANE: ONE OF THE FOLLOWING:

51. LATCRETE "BLUE 92" ANTI-FRACTURE MEMBRANE.

52. "TRP 38" BY MAPS CORP.

6. REINFORCED WATERPROOF MEMBRANE

61. LATCRETE INTERNATIONAL, INC. "LATCRETE 9235" GENERAL PURPOSE WATERPROOF MEMBRANE.

62. "NOBLESEAL TS" BY THE NOBLE COMPANY, OR "DAL-SEAL TS" BY DAL-TILE CORP; ONE SHEET WITH NON-MOVING POLYESTER FABRIC LAMINATED TO BOTH SIDES; NOBLEBOND 21 ADHESIVE BOND COAT.

7. SLOJANE TYPE TILE SEALER

71. "CERAMASEAL "MAGIC SEAL" BY BOSTIK/CERAMASEAL (800/523-6530).

72. MIRACLE SEALANTS "514007" BY MIRACLE SEALANTS AND ABRASIVES COMPANY (800/350-4101).

8. CEMENTITIOUS BACKER BOARD

81. 1/2 INCH NOMINAL THICKNESS AGGREGATED PORTLAND CEMENT PANEL, REINFORCED WITH GLASS FIBER MESH, "WONDERBOARD" BY CUSTOM BUILDING PRODUCTS (800/272-8786), "DUROCK INTERIOR OR EXTERIOR" BY USG, OR "GEORGIA PACIFIC "DENS-SHIELD" OR APPROVED.

82. TAPE FOR BACKER BOARD: OPEN WEAVE GLASS MESH JOINT TAPE, SELF-ADHESIVE, 24/2 INCHES WIDE.

83. FASTENERS: AS RECOMMENDED BY THE BACKER BOARD MANUFACTURER, THREAD FORMING SELF-DRILLING WATER HEAD SCREWS, POLYMER COATED OR ZINC PLATED, USG "DUROCK SCREWS" "ROCK-ON" OR APPROVED.

E. PREPARATION: CLEAN SUBSTRATE SURFACES FREE OF GREASE, DIRT, DUST, ORGANIC IMPURITIES, CURING AGENTS, AND OTHER MATERIALS THAT WOULD IMPAIR BOND; CLEAN FLOORS WITH "BLAST-TRACK" UNIT IF NECESSARY.

F. SLAB LEVELING (COORDINATE WITH LANDLORD REQUIREMENTS)

1. PRIOR TO INSTALLATION OF THINSET FLOOR TILE, WHERE LOCAL IRREGULARITIES IN THE SUBSTRATE SURFACE WOULD PREVENT LEVEL INSTALLATION OF THE TILE, THE SUBSTRATE SHALL BE BROUGHT TO PLANE SURFACE WITH VARIATIONS NOT TO EXCEED 1/8 INCH IN 4 FEET (CUMULATIVE) AND 1/4 INCH IN 10 FEET (NON-CUMULATIVE). SMOOTH ALL ABRUPT CHANGES IN PLANE.

2. USE THINSET MORTAR OR OTHER FILLER FOR SLAB LEVELING. OTHER FILLERS ARE SUBJECT TO ENDORSEMENT BY THE SETTING MORTAR MANUFACTURER. SUEMT MANUFACTURERS LETTER OF APPROVAL TO THE OWNER / REPRESENTATIVE, AND THE OWNERS REPRESENTATIVE.

3. SCREED OR FLOAT TO APPROPRIATE THICKNESS AND SPECIFIED SURFACE TOLERANCE. ALLOW 10 SET PRIOR TO PROCEEDING WITH INSTALLATION. DO NOT EXCEED THE MAXIMUM THICKNESSES FOR THIN BED MORTAR AS RECOMMENDED BY THE MANUFACTURER.

6. CRACK ISOLATION

1. INSTALL CRACK ISOLATION MEMBRANE ON A UNIT PRICE BASIS IN ACCORDANCE WITH THE MANUFACTURERS INSTRUCTIONS, UNLESS INDICATED OR SPECIFIED OTHERWISE.

2. CRACK ISOLATION MEMBRANE MAY BE REQUIRED AT THE FOLLOWING LOCATIONS

21. AT CONTROL AND CONSTRUCTION JOINTS IN CONCRETE FLOORS.

22. AT CHANGES IN SUBSTRATE MATERIALS.

23. SHRINKAGE CRACKS 1/8 INCH OR LARGER IN EXISTING SLABS.

3. EXTEND A MINIMUM OF 24 INCHES EACH SIDE OF CRACK OR JOINT.

4. SUBSTRATE EXAMINATION

41. SUBSTRATES ARE SUBJECT TO EXAMINATION BY THE OWNER AND THE OWNER / REPRESENTATIVE PRIOR TO INSTALLATION OF TILE OR SLAB LEVELING MATERIALS. FURNISH A MINIMUM OF 7 DAYS NOTICE.

42. THE EXAMINATION WILL DETERMINE THE NEED FOR CRACK ISOLATION MEMBRANE AT LOCATIONS SCHEDULED ABOVE.

1. INSTALL WATERPROOF MEMBRANE INTO CLAMPING RING OF FLOOR DRAINS.

2. PROTECT WATERPROOF MEMBRANE FROM DAMAGE UNTIL AFTER TILE INSTALLATION IS COMPLETE.

3. MEMBRANE LOCATIONS ARE SCHEDULED AT THE END OF THIS SECTION.

4. FLOOD TESTING OF MEMBRANE

01. WATER TEST WATERPROOF MEMBRANE INSTALLATIONS AT ABOVE GRADE FLOORS PRIOR TO INSTALLATION OF TILE.

02. NOTIFY THE OWNER / REPRESENTATIVE A MINIMUM OF 72 HOURS PRIOR TO TESTING.

03. VERIFY THAT ELEMENTS INSTALLED BY OTHER TRADES WHICH PENETRATE THE MEMBRANE ARE SEALED AND READY TO RECEIVE TESTING.

04. PLUS DRAINS AND PROVIDE WATER DAMS TO CONTAIN THE WATER.

05. FILL TEST AREA WITH WATER TO A DEPTH OF 1 INCH AT THE SHALLOWEST POINT, AND LEAVE FOR A MINIMUM OF 24 HOURS.

06. REPAIR LEAKS OBSERVED FROM TEST; RETEST AS NECESSARY TO ACHIEVE A LEAK-FREE INSTALLATION.

H. WATERPROOF MEMBRANE INSTALLATION

1. INSTALL WATERPROOF MEMBRANE IN STRICT ACCORDANCE WITH MANUFACTURERS INSTALLATION INSTRUCTIONS.

2. EXCEPT WHERE INDICATED OTHERWISE, EXTEND WATERPROOF MEMBRANE UP THE WALL TO 4 INCH MINIMUM HEIGHT. DO NOT EXPOSE THE WATERPROOF MEMBRANE TO VIEW.

I. SCREED INSTALLATION

1. INSTALL SCREEDS AT TILE FIELD EDGES AT THE LOCATIONS INDICATED.

2. ACCURATELY CUT TO LENGTH FOR FLUSH TIGHTLY BUTTED JOINTS. PROVIDE MITER CUT ANGLE JOINTS. REMOVE BURRS AT FIELD CUTS.

3. INSTALL IN LONGEST POSSIBLE LENGTHS, EXCEPT THAT NO SCREED SECTION SHALL BE LONGER THAN 12 FEET OR SHORTER THAN 4 FEET IN LENGTH FOR CONTINUOUS RUNS GREATER THAN 6 FEET.

4. INSTALL SCREEDS FREE FROM WAVES AND VARIATIONS IN HEIGHT, FLUSH WITH TOP OF ADJACENT TILE SURFACES.

5. SET SCREEDS DIRECTLY IN SETTING BED AS THE TILE INSTALLATION PROCEEDS. COMPLY WITH SCREED MANUFACTURER / INSTRUCTIONS TO ACHIEVE MORTAR TIGHTLY COMPACTED BETWEEN SCREED AND TILE EDGE.

6. GRIND SCREED JOINTS AS NECESSARY TO CORRECT MINOR MISALIGNMENT AND TO EASE SHARP OUTSIDE CORNERS.

D. CEMENTITIOUS BACKER BOARD INSTALLATION

1. INSTALL IN ACCORDANCE WITH THE MANUFACTURERS INSTALLATION INSTRUCTIONS.

2. INSTALL UNITS WITH EDGES FIRMLY SUPPORTED.

3. SCREW-ATTACH UNITS WITH 1 INCH LONG DRYWALL SCREWS SPACED 6 INCHES ON CENTER ALONG FRAMING.

4. INSTALL FIBERGLASS REINFORCING TAPE AT JOINTS BETWEEN PANELS. COMPLETELY EMBED IN A THIN SET MORTAR BED. TROWEL MORTAR SMOOTH WITH ADJACENT SURFACES.

5. CEMENT BACKER BOARD SHALL BE USED AT ALL VERTICAL MORTAR-SET STONE LOCATIONS.

K. INSTALLATION OF INTERIOR TILE

1. INTERIOR FLOOR APPLICATION: THINSET OVER CONCRETE SUBSTRATE OR CRACK ISOLATION MEMBRANE.

II. TCA SYSTEM: SIMILAR TO FEL.

12. INSTALLATION STANDARD: ANSI A805.

13. SETTING MATERIALS: THINSET MORTAR, 3/32-INCH MINIMUM THICKNESS.

2. WALL APPLICATION - GYPSUM BOARD SUBSTRATE

21. TCA SYSTEM: SIMILAR TO K244.

22. INSTALLATION STANDARD: ANSI A805 OR A804.

23. SETTING MATERIALS: THINSET MORTAR OR ORGANIC ADHESIVE.

24. JOINT PATTERN

241. LAY OUT TILE PATTERN PRIOR TO COMMENCING TILE INSTALLATION.

242. ACCURATELY LOCATE GROUT JOINTS ON LINES INDICATED; WHERE NOT INDICATED, ADJUST GROUT JOINTS WITHIN SPECIFIED TOLERANCES TO MINIMIZE USE OF CUT TILES AT FIELD TILES.

243. WHERE CUT TILES ARE NECESSARY, POSITION FLOOR TILE SUCH THAT CUT TILE AT EACH EDGE OF EACH RECTILINEAR FIELD IS NOT LESS THAN HALF OF A FULL SIZE UNIT.

3. WALL APPLICATION - THINSET OVER CEMENTITIOUS BACKING BOARD SUBSTRATE

31. TCA SYSTEM: SIMILAR TO K244.

32. INSTALLATION STANDARD: ANSI A805 OR A804.

33. SETTING MATERIALS: THINSET MORTAR.

34. JOINT PATTERN

341. LAY OUT TILE PATTERN PRIOR TO COMMENCING TILE INSTALLATION.

342. ACCURATELY LOCATE GROUT JOINTS ON LINES INDICATED; WHERE NOT INDICATED, ADJUST GROUT JOINTS WITHIN SPECIFIED TOLERANCES TO MINIMIZE USE OF CUT TILES AT FIELD EDGES.

343. WHERE CUT TILES ARE NECESSARY, POSITION FLOOR TILE SUCH THAT CUT TILE AT EACH EDGE OF EACH RECTILINEAR FIELD IS NOT LESS THAN HALF OF A FULL SIZE UNIT.

4. JOINT PATTERN

41. LAY OUT TILE PATTERN PRIOR TO COMMENCING TILE INSTALLATION.

42. ACCURATELY LOCATE GROUT JOINTS ON LINES INDICATED; WHERE NOT INDICATED, ADJUST GROUT JOINTS WITHIN SPECIFIED TOLERANCES TO MINIMIZE USE OF CUT TILES AT FIELD EDGES.

43. WHERE CUT TILES ARE NECESSARY, POSITION FLOOR TILE SUCH THAT CUT TILE AT EACH EDGE OF EACH RECTILINEAR FIELD IS NOT LESS THAN HALF OF A FULL SIZE UNIT.

44. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

5. CLEAN JOINTS OF MORTAR TO MINIMUM DEPTH OF 1/4 INCH TO ALLOW SUBSEQUENT GROUT INSTALLATION.

6. TOLERANCES

61. JOINT WIDTH VARIATION: PLUS OR MINUS .25% OF THE PROPOSED JOINT WIDTH.

62. TAPER: PLUS OR MINUS .25% FROM ONE END TO THE OTHER.

63. NO PORTION OF A TILE SURFACE SHALL VARY MORE THAN 1/6 INCH ABOVE OR BELOW AN ADJACENT TILE SURFACE.

64. INSTALL TILE FIELDS LEVEL TO WITHIN TOLERANCE SPECIFIED FOR FINISHED SUBSTRATE.

7. SPECIAL FLOOR TILE INSTALLATION REQUIREMENTS

71. WASH BACKS OF EACH TILE TO REMOVE ALL DUST AND SOL THAT WOULD COMPROMISE ADHESION.

72. DAMPEN SUBSTRATE AS NECESSARY TO PREVENT EXCESSIVE SUCTION. TROWEL MORTAR ONTO SURFACES TO RECEIVE TILE.

73. APPLY MORTAR BOND COAT WITH NOTCHED TROWEL AS REQUIRED FOR PROPER LEVEL.

74. SET TILE WITHIN THE SPAN RECOMMENDED BY MORTAR MANUFACTURER.

75. BACK BUTTER TILES PRIOR TO SETTING TO ACHIEVE MAXIMUM MORTAR COVERAGE OVER BACK OF TILE AND SUBSTRATE.

76. SET TILES IN ACCURATE ALIGNMENT. BEAT IN WITH A WOOD BLOCK, RUBBER HAMMER, OR THIST AS NECESSARY TO LEVEL TILES.

L. GROUTING

1. MIX GROUTS IN ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS.

2. GROUT ALL JOINTS, EXCEPT EXPANSION JOINTS, IN ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATIONS. FLOAT JOINTS TO A SLIGHTLY CONCAVE PROFILE.

3. REMOVE EXCESS GROUT FROM TILE SURFACES IN ACCORDANCE WITH THE GROUT AND TILE MANUFACTURERS RECOMMENDATIONS. DO NOT USE EXCESS AMOUNTS OF WATER.

4. PROTECT ADJACENT SURFACES FROM DAMAGE IF AID CLEANSERS ARE USED.

5. DO NOT GROUT JOINTS INDICATED TO RECEIVE SEALANTS, INCLUDING INSIDE RIGHT ANGLE CORNER JOINTS BETWEEN FLOORS AND WALLS OF COLUMN BASES. GROUT JOINTS PERPENDICULAR TO EXPANSION JOINTS SHALL BE FINISHED FLUSH WITH TILE EDGES.

6. CURED GROUT JOINTS SHALL BE MADE FREE OF EFFLORESCENCE, PRIOR TO SEALING.

7. CURE INSTALLATION IN ACCORDANCE WITH THE GROUT MANUFACTURERS RECOMMENDATIONS. PROTECT TILE AND GROUT DURING CURING OPERATIONS.

M. EXPANSION JOINT

1. PLACE EXPANSION JOINTS AS INDICATED ON THE DRAWINGS, BUT IN NO CASE MORE THAN 30-FOOT INTERVALS FOR INTERIOR INSTALLATIONS.

2. PLACE EXPANSION JOINTS AT CONTROL AND EXPANSION JOINTS IN CONCRETE SLABS, AND AT INTERSECTIONS WITH WALLS AND COLUMNS.

3. JOINT SIZES: SET TO MATCH WIDTH OF TYPICAL GROUTED JOINT.

4. LEAVE EXPANSION JOINTS FREE OF MORTAR.

5. SEALANT MATERIALS AND INSTALLATION ARE SPECIFIED IN SECTION 0720.

N. CLEANING: WASH AND THOROUGHLY RISE ALL TILE. LEAVE ALL TILE SURFACES CLEAN.

O. TILE SEALING

1. APPLY SEALER IN ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATIONS TO ACHIEVE MAXIMUM PENETRATION INTO GROUTS AND OTHER APPURTENANCES TO PRODUCE TIGHT JOINTS.

2. Wipe TILE SURFACES AFTER APPLICATION AS NECESSARY TO REMOVE ALL VISIBLE SEALER RESIDUE.

P. SPECIAL PROTECTION REQUIREMENTS FOR TILE SURFACES

1. AREAS SUBJECT ONLY TO FOOT TRAFFIC: LAY DOWN NON-STANDING CURING PAPER LAPPED AND SEALED AT JOINTS AND EDGES WITH NASHUA BRAND DUCT TAPE. DO NOT USE POLYETHYLENE OR PRODUCTS CONTAINING BITUMINOUS MATERIALS.

2. AREAS SUBJECT TO ROLLING TRUCKS, DOLLIES AND OTHER EQUIPMENT: IN ADDITION TO THE ABOVE, SUCH AREAS SHALL BE FURTHER PROTECTED BY CONTINUOUS PLYWOOD OR HARDBOARD RUNWAYS. COORDINATE DESIGNATION OF SUCH AREAS.

3. WHERE CUT TILES ARE NECESSARY, POSITION FLOOR TILE SUCH THAT CUT TILE AT EACH EDGE OF EACH RECTILINEAR FIELD IS NOT LESS THAN HALF OF A FULL SIZE UNIT.

4. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

5. CLEAN JOINTS OF MORTAR TO MINIMUM DEPTH OF 1/4 INCH TO ALLOW SUBSEQUENT GROUT INSTALLATION.

6. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

7. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

8. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

9. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

10. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

11. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

12. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

13. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

14. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

15. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

16. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

17. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

18. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

19. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

20. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

G. INSTALLATION

1. INSTALL SYSTEM IN ACCORDANCE WITH ASTM C636 AND THE REQUIREMENTS OF THE JURISDICTIONAL CODE AUTHORITIES.

2. INSTALL GRID TO PRODUCE FINISHED CEILING TRUE TO LINES AND LEVELS INDICATED; WITHIN THE SPECIFIED TOLERANCES.

3. INSTALL SUSPENSION SYSTEMS IN A MANNER TO SUPPORT ALL SUPERIMPOSED LOADS, WITH MAXIMUM PERMISSIBLE DEFLECTION OF 1/270 OF SPAN.

4. HANG SYSTEM INDEPENDENT OF WALLS, COLUMNS, DUCTS, PIPES AND CONDUIT. WHERE DUCTS OR OTHER EQUIPMENT PREVENT THE REGULAR SPACING OF HANGERS, PROVIDE SECONDARY CARRYING MEMBERS FOR INDIRECT SUPPORT OF THE SUSPENSION SYSTEM OR REINFORCE THE NEAREST ADJACENT HANGERS AND RELATED CARRYING CHANNELS AS REQUIRED TO SPAN THE REQUIRED DISTANCE.

5. CENTER SYSTEM ON ROOM AXES ACCORDING TO REFLECTED CEILING PLANS.

1. PROVIDE ALL ANCHORS REQUIRED FOR THE INSTALLATION OF THE CEILING SYSTEM. DO NOT ANCHOR SYSTEM IN ANY MANNER THAT MIGHT CAUSE DAMAGE TO THE STRUCTURAL SYSTEM.

2. INSTALL EDGE MOLDING AT INTERSECTION OF CEILING AND VERTICAL SURFACES, USING LONGEST PRACTICAL LENGTHS, MITER CORNERS. PROVIDE EDGE MOLDINGS AT JUNCTIONS WITH OTHER INTERIORS, FABRICATE EDGE MOLDINGS TO FIT THE SURFACES ENCOUNTERED.

3. FIT ACOUSTIC LAY-IN PANELS IN PLACE, FREE FROM DAMAGED EDGES OR OTHER DEFECTS DETRIMENTAL TO APPEARANCE AND FUNCTION. FIT BORDER UNITS NEATLY AGAINST ADJUTING SURFACES. SCREE AND FULL RECESSED REGULAR EDGE INTO PARTIAL BORDER UNITS SUPPORTED AT EDGE BY WALL MOLDINGS.

4. HOLD-DOWN CLIPS INSTALL HOLD-DOWN CLIPS AT PANELS WITHIN 20 FEET OF AN EXTERIOR DOOR.

5. TOLERANCES

51. VARIATION FORM FLAT AND LEVEL SURFACE: 1/8 INCH IN 10 FEET

52. VARIATION FROM PLUMB OF GRID MEMBERS CAUSED BY ECCENTRIC LOADS: TWO DEGREES MAXIMUM.

6. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

7. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

8. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

9. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

10. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

11. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

12. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

13. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

14. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

15. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

16. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

17. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

18. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

19. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

20. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

21. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

22. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

23. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

24. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

25. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

26. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

27. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

28. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

29. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

30. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

31. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

32. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

33. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

34. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

35. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

36. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

37. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

38. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

39. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

40. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

SECTION - 0465 - SELF - LEVELING UNDERLAYMENT (IF REQ'D)

A. ULTRAPLAN I

HIGH PERFORMANCE, QUICK-SETTING - LEVELING UNDERLAYMENT CONTACT MAPS NORTH AMERICAN HEADQUARTERS 144 EAST NEWPORT CENTER DRIVE DEERFIELD BEACH, FLORIDA 33442 PHONE (404) 246 0808 FAX (404) 246 0800 WWW.mapsc.com

SECTION - 0710 - WALL COVERINGS

A. MATERIALS

1. WALL COVERINGS AS SCHEDULED ON THE DRAWINGS.

2. ADHESIVES AS RECOMMENDED BY THE WALL COVERING MANUFACTURER.

3. ALL WALL COVERINGS SHALL HAVE A MAXIMUM FLAME SPREAD OF 75 OR LESS WHEN TESTED IN ACCORDANCE WITH ASTM E84. FIRE RETARDANT TREAT ALL NONCONFORMING WALL COVERINGS. TREATMENT SHALL NOT ALTER THE APPEARANCE OF THE FABRIC.

4. UNLESS OTHERWISE INDICATED, TILE JOINTS SHALL BE 1/8" WIDE.

5.



PAUL DHANENS • ARCHITECT

SECTION - 0920 - ACOUSTICAL INSULATION AND SEALANTS

A. MATERIALS

- 1. ACOUSTIC INSULATION: ASTM C665, TYPE I, UNFACED MINERAL FIBER BATT'S, BLANKETS, OR ROLLS; MINIMUM FIRE HAZARD CLASSIFICATION RATING OF 25/50 PER ASTM E84; MINIMUM 3/4-INCH THICK, UNLESS REQUIRED OTHERWISE TO MEET THE STC REQUIREMENTS INDICATED OR SPECIFIED; WIDTHS TO FRICION-FIT BETWEEN STUDS, WHERE INDICATED FOR INSTALLATION IN STUD WALLS.
- 2. ACOUSTICAL SEALANT: NON-HARDENING, NON-SKINNING, FOR USE IN CONJUNCTION WITH GYPSUM BOARD; SIMILAR TO USG "ACOUSTICAL SEALANT."
- 3. SPRAYED FOAM: DOWN CORNING FIRE STOP 2003 SILICON FOAM® OR APPROVED.
- 4. PREFORMED FOAM FILLER, FOAM ASSEMBLIES AVAILABLE FROM THE METAL DECK MANUFACTURER THAT ARE PREFORMED TO FIT THE FLUTES IN THE METAL DECK.
- 5. ACCESSORIES: FURNISH OTHER ACCESSORIES SUCH AS FASTENERS AND RETAINERS, NOT SPECIFICALLY DESCRIBED, BUT REQUIRED FOR A COMPLETE INSTALLATION.

B. INSTALLATION

- 1. INSTALL INSULATION IN ACCORDANCE WITH MANUFACTURERS' INSTRUCTIONS, AND AS INDICATED.
- 2. INSTALL INSULATION WITHOUT GAPS OR VOIDS.
- 3. TRIM INSULATION NEATLY TO FIT SPACES. USE INSULATION MATERIALS FREE OF DAMAGE.
- 4. ACOUSTICAL INSULATION AT CEILINGS:
 - 4.1. LAY ACOUSTICAL INSULATION OVER EACH ACOUSTICALLY INSULATED PARTITION THAT TERMINATES AT THE CEILING. INSULATION SHALL EXTEND A MINIMUM OF 3/4" EACH SIDE OF THE CENTERLINE OF THE ACOUSTICAL PARTITION.
 - 4.2. ACOUSTICAL INSULATION BATT'S SHALL BE TIGHTLY BUTTED.
 - 4.3. CUT AND FIT NEATLY AROUND MECHANICAL AND SPRINKLER DROPS.
 - 4.4. FILL SPACES BETWEEN WALL BATT'S (AT TOP PLATE LINE) AND CEILING BATT'S TO ENSURE COMPLETE SOUND CLOSURE.
- 4.5. OMIT INSULATION OVER TOPS OF RECESSED FLUORESCENT LIGHT FIXTURES, AND WITHIN 2 INCHES OF RECESSED INCANDESCENT FIXTURES.
- 5. SEALANT:
 - 5.1. INSTALL ACOUSTICAL SEALANT AROUND PERIMETER OF ALL ACOUSTICALLY INSULATED PARTITIONS ONE CONTINUOUS BEAD AT EACH SIDE OF FRAMING MEMBER INTERFACE WITH SUBSTRATE.
 - 5.2. SEAL ALL PENETRATIONS THROUGH ACOUSTICAL ASSEMBLIES, EXCEPT FOR PENETRATIONS IN FIRE RATED CONSTRUCTION TO RECEIVE FIRESTOPPING.
- 6. PROVIDE PREFORMED FOAM FILLERS OR SPRAYED FOAM TO SEAL THE FLUTE OPENINGS WHERE ACOUSTICAL PARTITIONS ARE INSTALLED TIGHT TO METAL DECK ASSEMBLIES.

SECTION 0900 - PAINTING

A. DESCRIPTION OF WORK:

- 1. PREPARATION OF NEW AND EXISTING SURFACES. PERFORMANCE AND COMPLETION OF PAINTING AND FINISHING NEW AND EXISTING INTERIOR SURFACES, INCLUDING MECHANICAL AND ELECTRICAL WORK IN FINISHED SPACES. FINISH FOR FACTORY-FINISH ITEMS.
- 2. EXCEPT AS OTHERWISE INDICATED, ALL NEW AND EXISTING SURFACES SHALL HAVE FINISH APPLIED TO THEM.
- 3. COLORS: SEE FINISH SCHEDULE FOR COLOR AND MANUFACTURER.
- 4. GC SHALL DO ALL TOUCHUP AT COMPLETION OF THE JOB WHERE OTHER TRADES HAVE MARRED THE PAINTED SURFACES. CLEAN PAINT DROPPING FROM HARDWARE, FLOOR, ETC.

B. MAINTENANCE MATERIALS

LEAVE ONE UNOPENED GALLON OF EACH TYPE AND COLOR FOR MAINTENANCE PURPOSES. LABEL FOR POSITIVE IDENTIFICATION. INCLUDE DESIGNATION INDICATED ON COLOR SCHEDULE, DATE OF MIXING, AND CROSS REFERENCE MANUFACTURER USED.

C. PRODUCT DELIVERY, STORAGE, AND HANDLING

- 1. DELIVERY OF MATERIAL: DELIVER IN SEALED CONTAINERS WITH MANUFACTURERS' ORIGINAL LABELS LEGIBLE AND INTACT.
- 2. STORAGE OF MATERIALS: STORE IN MANNER RECOMMENDED BY THE MANUFACTURER AND AS REQUIRED BY BUILDING CODE AND COMPLY WITH LOCAL HEALTH REGULATIONS.
- 3. HANDLING: TAKE ALL NECESSARY PRECAUTIONARY MEASURES TO PREVENT FIRE HAZARDS AND SPONTANEOUS COMBUSTION. PLACE COTTON WASH CLOTHS, AND OTHER HAZARDOUS MATERIALS IN CONTAINERS, AND REMOVE FROM SITE DAILY.

D. ENVIRONMENTAL CONDITIONS

COMPLY WITH MANUFACTURERS' RECOMMENDATIONS AS TO ENVIRONMENTAL CONDITIONS UNDER WHICH COATINGS AND COATING SYSTEMS CAN BE APPLIED.

E. PROTECTION

- 1. ADEQUATELY PROTECT OTHER SURFACES FROM DAMAGE. MAKE GOOD ANY DAMAGE CAUSED BY FAILURE TO PROVIDE SUITABLE PROTECTION.
- 2. REMOVAL OF HARDWARE AND MISCELLANEOUS ITEMS: REMOVE ELECTRICAL, OUTLET, AND SWITCH PLATES; MECHANICAL, DIFFUSERS, ESCUTCHEONS, REGISTERS, SURFACE HARDWARE, FITTINGS, FASTENINGS, AND THE LIKE PRIOR TO STARTING WORK.
- 3. DROP CLOTHS: PROVIDE DROP CLOTHS, SHIELDS, AND PROTECTIVE EQUIPMENT. EXTEND PROTECTION TO SURFACES WITHIN PREPARATION AREAS.

F. GUARANTEES

FURNISH TWO-YEAR WARRANTY FOR FULL VALUE OR WORK INCLUDED IN THIS SECTION.

D. MATERIALS

- 1. PAINT, VARNISH, STAIN AND RELATED PRODUCTS FOR PRIME, INTERMEDIATE AND FINISHED COATS, TOP LINE PRODUCTION PRODUCTS OF THE FOLLOWING APPROVED MANUFACTURERS:
 - PER MANUFACTURERS' LIST ON FINISH SCHEDULE
- 2. MATERIALS NOT SPECIFICALLY INDICATED, BUT REQUIRED, SUCH AS LINEED OIL, SHELLAC, THINNERS, AND THE LIKE TO BE OF QUALITY NOT LESS THAN REQUIRED BY APPLICABLE FEDERAL OR STATE SPECIFICATION STANDARDS.
- 3. ALL WORK:PREMIUM GRADE

H. INSPECTION

- 1. VERIFY SUBSTRATE SATISFACTORY FOR WORK OF THIS SECTION. DO NOT PROCEED UNTIL DEFECTS HAVE BEEN CORRECTED.
- 2. BY STARTING PAINTING, THE CONTRACTOR IMPLIES THAT HE HAS ACCEPTED THE SURFACES AS BEING FREE OF DEFECTS.

I. PREPARATION: NEW WORK

- 1. MISCELLANEOUS STEEL AND IRON, TO INCLUDE METAL DOORS AND FRAMES:
 - 1.1. SURFACES SHOP-PRIMED. REMOVE ALL SURFACE CONTAMINATION FROM ALL SURFACES. AT FIELD-WELDED OR ABRASED SPOTS, APPLY A PHOSPHORIC ACID ETCH SOLUTION AND LET SET FOR THE TIME RECOMMENDED BY ACID ETCH MANUFACTURER, RINSE WITH WATER WHEN THOROUGHLY DRY, IMMEDIATELY APPLY PRIME COAT.
 - 1.2. SURFACES NOT SHOP-PRIMED: REMOVE RUST AND SCALE BY WIRE BRUSHING OR OTHER METHODS. REMOVE DUST, DIRT, OIL, GREASE, CLEAN SURFACE BY SOLVENT WASH, APPLY PHOSPHORIC ACID SOLUTION AND LET SET FOR THE RECOMMENDED BY ACID ETCH MANUFACTURER, RINSE WITH WATER WHEN THOROUGHLY DRY, IMMEDIATELY APPLY PRIME COAT.
- 2. WOOD PRODUCTS TO BE PAINTED: REMOVE SURFACE CONTAMINATION, DUST AND GRIT. SPOT COAT KNOTS, FITCH STREAKS AND SAPPY SECTIONS WITH SEALER. FILL IN NAIL HOLES AND FINE CRACKS AFTER PRIMER HAS DRIED AND SAND SMOOTH. LEVEL WITH SURFACE READY FOR FINISH COAT.
- 3. WOOD PRODUCTS TO BE STAINED: REMOVE SURFACE CONTAMINATION, DUST AND GRIT. AFTER STAIN COAT, FILL NAIL HOLES WITH MATCHING COLOR FILLER.
- 4. GYPSUM WALLBOARD:
 - 4.1. REMOVE ANY MINOR SUBSEQUENT CONTAMINATION, DUST, AND DIRT.
 - 4.2. IF SURFACE DEFECTS APPEAR AFTER PRIME COATING, NOTIFY JOB SUPERINTENDENT AND ARCHITECT.
 - REQUIRE DEFECTS TO BE REPAIRED BY AND AT EXPENSE OF DRYWALL TRADE. AFTER DEFECTS ARE CORRECTED, PROCEED WITH FINISH PAINTING, AGAIN USING PRIMER OVER REPAIRED AREAS.

D. PAINTING, AGAIN USING PRIMER OVER REPAIRED AREAS.

- 1. MECHANICAL AND ELECTRICAL WORK: PREPARE METAL SURFACES AS SPECIFIED HEREIN ABOVE FOR MISCELLANEOUS STEEL AND IRON AS APPLICABLE TO TYPE OF MATERIAL SCHEDULED TO BE PAINTED. REMOVE DIRT, GREASE, AND OIL FROM CANVAS AND COTTON INSULATION COVERING.

J. PREPARATION: EXISTING WORK WHEN APPLICABLE

- 1. CLEAN TO EXTENT REQUIRED, AND OR REMOVE EXISTING COATINGS.
- 2. WOOD PRODUCTS TO BE PAINTED: THICK AND SHARP EDGES OF PAINT BUILDUPS, RUNS, AND SAGS SHALL BE SANDED SMOOTH (FEATHERED EDGES). REPAIR AND SAND SMOOTH ALL SURFACE DEFECTS, INCLUDING UNSET/RESET NAILS, CRACKS AND GOUGES.
- 3. GYPSUM WALLBOARD: FILL, SAND SMOOTH ALL SURFACE DEFECTS.

K. APPLICATION

- 1. APPLY PAINT OR FINISH BY METHODS GENERALLY ACCEPTED BY THE TRADE TO ACHIEVE APPROVED FINISHES.
- 2. COMPLY WITH RECOMMENDATIONS OF PRODUCT MANUFACTURER FOR DRYING TIME BETWEEN SUCCEEDING COATS.
- 3. VARY COLOR OF SUCCESSIVE UNDERCOATS.
- 4. SAND AND DUST BETWEEN EACH COAT TO REMOVE DEFECTS VISIBLE FROM A DISTANCE OF 5 FEET.
- 5. GC SHALL PAINT WALL SURFACES INDICATED ON PLANS USING A MINIMUM OF TWO COATS OF PAINT AND PRIME WHERE RECOMMENDED BY PAINT MANUFACTURER.
- 6. ALL PAINT WORK SHALL BE FIRST QUALITY WITH NO DEFECTS.
- 7. DRYWALL PAINT SHOULD BE APPLIED BY ROLLER. PAINT APPLIED TO WOOD SHALL BE BRUSHED ON. EXPOSED CEILING COMPONENTS TO BE SPRAYED.

L. FINISH SCHEDULE

- 1. INTERIOR FINISH SYSTEM 1: GYPSUM WALLBOARD CEILING
 - (1) COAT: LATEX PRIMER
 - (2) COATS: INTERIOR LATEX, FLAT FINISH
 - 2. INTERIOR FINISH SYSTEM 2: GYPSUM WALLBOARD WALLS
 - (1) COAT: LATEX PRIMER
 - (2) COATS: INTERIOR LATEX, SATIN FINISH
 - 3. INTERIOR FINISH SYSTEM 3: DOORS AND TRIM
 - (1) COAT: LATEX PRIMER
 - (2) COATS: INTERIOR LATEX, SEMI-GLOSS FINISH
 - 4. DAMAGED FINISHES INCLUDING PREFINISHED OWNER FURNISHED WHERE A TRANSPARENT CLASS B FINISH IS REQUIRED, USE:
 - ALBERT "DS CLEAR" FIRE RETARDANT COATING AND OVERCOATER "66-H" MATTE OR SEMI-GLOSS FINISH. (SEE SECTION 1250 FIRE RETARDANT COATINGS)
 - 5. WHERE A TRANSPARENT CLASS A FINISH IS REQUIRED, USE:
 - ALBERT "DS CLEAR" FIRE RETARDANT COATING AND OVERCOATER "66-H" MATTE OR SEMI-GLOSS FINISH. (SEE SECTION 1250 FIRE RETARDANT COATINGS)
- ITEMS:
PREPARE AND REFINISH AS SPECIFIED AND SCHEDULED FOR WORK. ALL THE ABOVE SURFACES MAY NOT BE ENCOUNTERED DURING THE COURSE OF THIS PROJECT.

SECTION - 10400 - SIGNAGE

A. SECTION INCLUDES

- 1. PLASTIC SIGNAGE
- 2. VINYL SIGNAGE

B. REFERENCES

- 1. AMERICAN WITH DISABILITIES ACT ACCESSIBILITY GUIDELINES (ADAAG) - LATEST EDITION.
- 2. AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI) A11.1, LATEST EDITION.

C. PLASTIC SIGNAGE

- 1. MATERIALS:
 - 1.1. PLASTIC SHEET: 1/8 INCH THICK ACRYLIC SHEET; BLUE, LOW GLOSS FINISH.
 - 1.2. ADHESIVE MOUNTING TAPE: 3M "SCOTCH BRAND #660" DOUBLE-STICK, DOUBLE-COATED TAPE, 1/4" WIDE.
 - 1.3. RAISED LETTERING: HELVETICA MEDIUM TYPEFACE, WHITE COLOR, 1 INCH HEIGHT, 1/32 INCH RELIEF, SELF-ADHESIVE.
 - 1.4. BRALLIES ANSI GRADE I, SELF-ADHESIVE, COLOR TO MATCH ACRYLIC SHEET.
 - 1.5. PICTOGRAMS ANSI COMPLIANT; SELF-ADHESIVE.
- 2. DIMENSIONS: 4-1/2 INCHES HIGH, WITH WIDTH DETERMINED BY SPECIFIED TEXT; MINIMUM 3/4 INCH BORDER UNLESS INDICATED OTHERWISE, 1/2 INCH RADIUS CORNERS.
- 3. SIGNS:
 - 3.1. FOR EACH TOILET ROOM DOOR, "MEN" OR "WOMEN" AS APPROPRIATE, BLUE WITH WHITE LETTERS, ACCOMPANIED WITH GRADE 2 BRaille SYMBOL; OVERALL SIGN TO BE 24 1/2 INCH HIGH BY LENGTH REQUIRED.
 - 3.2. FOR EACH TOILET ROOM DOOR, INTERNATIONAL SYMBOL OF ACCESSIBILITY; NOMINAL 3 INCHES BY 3 INCHES, STANDARD BLUE AND WHITE.

D. VINYL SIGNS

- 1. TYPE: PRESSURE SENSITIVE ADHESIVE BACK; MACHINE BLADE CUT; CUSTOM COLORS AS SCHEDULED.
- 2. TEXT: AS SCHEDULED BELOW.
- 3. STYLE/SIZES: HELVETICA MEDIUM, 1 INCH UNLESS OTHERWISE INDICATED.
- 4. SUBMIT SIGN FOR APPROVAL.

2. SCHEDULES

- 2.1. SUITE NUMBERS: 3" HIGH INDIVIDUAL LETTERS; TEXT AND COLOR AS DIRECTED BY OWNERS REPRESENTATIVE AND LANDLORD REQUIREMENTS.

- 01. AT ENTRY DOORS IN ECG JURISDICTIONS: "THIS DOOR TO REMAIN UNLOCKED DURING BUSINESS HOURS" SINGLE SIGN AT EACH ENTRY; SIZE AS REQUIRED; PROVIDE LETTERS IN COLOR WHICH CONTRAST DISTINCTLY FROM BACKGROUND (FRAME) COLOR.
- 02. AT ENTRY DOORS IN OTHER JURISDICTIONS, WORKING AS INDICATED, OR VERIFY WITH LOCAL CODE AUTHORITY FOR CORRECT WORKING OF SIGN IF WORKING NOT INDICATED; PROVIDE LETTERS IN COLOR WHICH CONTRAST DISTINCTLY FROM BACKGROUND (FRAME) COLOR.
- 03. EMERGENCY EXIT ONLY: ON REAR EXTERIOR DOOR (WHERE APPLICABLE), BLUE WITH WHITE LETTERS; MOUNT AT 4'-6" AFF.

E. FABRICATION

- 1. SIGNS SHALL BE FREE OF ROUGH EDGES, IRREGULAR SURFACES, NON-UNIFORM FINISHES, AND OTHER DEFECTS.
- 2. PROVIDE PICTOGRAMS WITH ACCURATE COLOR MATCH WITH RAISED LETTERING.
- 3. APPLY ADHESIVE PICTOGRAMS AND RAISED LETTERING CAREFULLY, IN ACCURATE ALIGNMENT.

F. INSTALLATION OF PLASTIC SIGNAGE

- 1. CLEAN SURFACES TO RECEIVE SIGNAGE.
- 2. INSTALL SIGNAGE AS REFERENCED IN THE GRAPHICS SCHEDULE AND OTHER ITEMS AS SPECIFIED BELOW.
- 3. GRAPHICS SHALL BE MOUNTED LEVEL, AND PLUMB.
- 4. APPLY SIGNAGE WITH TOP EDGE LOCATED 60 INCHES ABOVE THE FINISH FLOOR SURFACE UNLESS INDICATED OTHERWISE. USE SPECIFIED ADHESIVE MOUNTING TAPE; THE TAPE SHALL NOT BE VISIBLE IN THE INSTALLED POSITION.

G. INSTALLATION OF VINYL SIGNS

- 1. ADHERE BY REMOVING PROTECTIVE BACKING SHEET AND PRESSING FIRMLY TO SURFACE, FOLLOWING ACCURATE SPACING.
- 2. REMOVE ALL RESIDUE AROUND LETTERS, Wipe CLEAN.

H. CLEANUP

- 1. TAKE PRECAUTIONS TO ASSURE ADJACENT SURFACES REMAIN FREE FROM DUST, AND ADHESIVE.
- 2. IMMEDIATELY CLEAN SURFACES THAT BECOME SOILED DURING INSTALLATION OF THE LETTERS.
- 3. UPON INSTALLATION, CLEAN THE LETTERS AND PIN MOUNTS OF DUST WITH A DAMP CLOTH, TAKING CARE NOT TO DAMAGE UNDERLYING SURFACES.
- 4. LEAVE THE INSTALLATION CLEAN, AND COMPLETELY FREE OF FOREIGN MATERIAL THAT WOULD DETRACT FROM VISUAL APPEARANCE OF THE LETTERS.

SECTION - 10800 TOILET ACCESSORIES

A. DELIVERY, STORAGE AND HANDLING

- 1. DO NOT DELIVER ACCESSORIES TO SITE UNTIL ROOMS IN WHICH THEY ARE TO BE INSTALLED ARE READY TO RECEIVE THEM.
- 2. PACK ACCESSORIES INDIVIDUALLY IN A MANNER TO PROTECT ACCESSORY AND ITS FINISH.

B. GENERAL

- 1. PROVIDE ACCESSORIES AS MANUFACTURED BY BOBRICK WASHROOM EQUIPMENT COMPANY UNLESS OTHERWISE INDICATED, IN QUANTITIES INDICATED ON THE DRAWINGS.
- 2. ALL PRODUCTS SHALL BE SATIN STAINLESS STEEL, UNLESS OTHERWISE INDICATED.

C. PRODUCTS IN RESTROOMS AS SPECIFIED IN DRAWINGS

D. PREPARATION

- 1. DELIVER INSERTS AND ROUGH-IN FRAMES TO JOB SITE AT APPROPRIATE TIME FOR BUILDING-IN.
- 2. FURNISH TEMPLATES AND ROUGH-IN MEASUREMENTS AS REQUIRED.
- 3. BEFORE STARTING WORK, NOTIFY OWNERS REPRESENTATIVE IN WRITING OF CONFLICTS DETRIMENTAL TO INSTALLATION OR OPERATION OF UNITS.
- 4. PROTECT ADJACENT OR ADJOINING FINISHED SURFACES FROM DAMAGE DURING INSTALLATION OF WORK OF THIS SECTION.
- 5. VERIFY EXACT LOCATION OF ACCESSORIES.

E. INSTALLATION

- 1. INSTALL FIXTURES, ACCESSORIES AND ITEMS IN ACCORDANCE WITH MANUFACTURERS' INSTRUCTIONS AND ADAAG/ANSI STANDARDS.
- 2. INSTALL TRUE, PLUMB, AND LEVEL, SECURELY AND RISIDLY ANCHORED TO SUBSTRATE.
- 3. USE TAMPER-PROOF FASTENERS.

SECTION - 10991 - MISCELLANEOUS

A. CORNER GUARDS


- 1. CLEAR POLYCARBONATE ANGLE, 1/8" THICK, X 24 1/2" X 24 1/2" X 4'-0" LONG. TRIM-GUARDS, INC. TG-422, OR APPROVED; FURNISH WITH PREDRILLED COUNTERSINK MOUNTING HOLES AND CHROME PLATED OVAL HEAD MOUNTING SCREWS.

- 2. INSTALLATION: AS INDICATED ON THE DRAWINGS, SET BOTTOM OF CORNER GUARD FLUSH WITH TOP OF WALL BASE.

B. FIRE EXTINGUISHER DRY CHEMICAL TYPE - ABC MULTIPURPOSE TYPE

- 1. TYPE: STANDARD FIRE-TEST MODEL ABC-3, POTTER-ROEBER MODEL NO. 3003, LARSENS MANUFACTURING COMPANY MODEL: HPS, J.L. INDUSTRIES COSMIC SE, OR APPROVED.
- 2. 5 LB. CAPACITY, UL RATED 2A-10BC, APPROXIMATELY 4-1/2 INCH DIAMETER X 14 INCHES HIGH, BAKED ENAMEL STEEL SHELL.
- 3. AGENT: AMMONIUM PHOSPHATE BASE.
- 4. LOCATION: PROVIDE AT ALL FIRE EXTINGUISHER AND FIRE EXTINGUISHER CABINET LOCATIONS, UNLESS NOTED OTHERWISE.
- 5. FIRE EXTINGUISHER CABINETS (FEC): POTTER-ROEBER, INC. #1023-DV, LARSENS MANUFACTURING COMPANY #24045R-D, J.L. INDUSTRIES #081V-40, SEMI-RECESSED, WHITE BAKED ENAMEL INTERIOR AND DOOR.

ARCHITECT



5100 CALIFORNIA AVE., SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (805) 328-8836
FACSIMILE: (805) 328-8837

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor assigned to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS:
Written dimensions on these drawings shall take precedence over scaled dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT FOR



1946 WEST AVE. E
LANCASTER, CA

DATE ISSUED FOR

6-20-11 BUILDING DEPT. SUBMITTAL

NO. REVISIONS



SPECIFICATION

FILE NAME: 2366A6-0


SHEET

A-6.5




TENANT IMPROVEMENT FOR STEAK 'N SHAKE RESTAURANT AND DRIVE-THRU

1966 WEST AVE 'L', LANCASTER, CA 93534



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE, SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (805) 328-8838
FACSIMILE: (805) 328-8837

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor assigned to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS
Written dimensions on these drawings shall take precedence over scaled dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT FOR



1966 WEST AVE L
LANCASTER, CA

DATE	ISSUED FOR
6-20-11	BUILDING DEPT SUBMITTAL

NO. REVISIONS




TITLE SHEET

FILE NAME: 2366T1-0

SHEET

T-1.0

SITE INFORMATION



SITE PLAN

KEYNOTES

- EXISTING PATH OF TRAVEL TO PUBLIC RIGHT OF WAY
- EXISTING 9'-0" x 10'-0" HANDICAP PARKING STALL WITH 3'-0" x 3'-0" PAINTED STALL SIGN AND TO 50 IN POLE MOUNTED PARKING SIGN DISPLAYING THE INTERNATIONAL SYMBOL OF ACCESSIBILITY WITH AN ADDITIONAL SIGN OR LANGUAGE STATING MINIMUM FINE \$250.00 INCLUDE SIGN MOUNTED BELOW STATING "VAN ACCESSIBLE" WHERE APPROPRIATE PER CBC SECTION 112418-802 MINIMUM HEIGHT TO THE BOTTOM OF ALL POLE SIGNS
- EXISTING MIN 5'-0" WIDE HANDICAP ACCESS AISLE FOR VAN ACCESS WITH THE WORDS "NO PARKING" IN 12" HIGH CONTRASTING LETTERS - SLOPE NOT TO EXCEED 1/4 IN 12
- EXISTING MIN 4'-0" WIDE HANDICAP ACCESSIBLE CURB RAMP - SLOPE SHALL NOT EXCEED 1:20 WITH 4'-0" MINIMUM LANDING AT TOP AND 1'-0" BORDER OF 1/4" WARNING GROOVES AT TOP PER CBC STANDARDS. PROVIDE RAISED TRIANGULATED DOME TILES FOR THE FULL WIDTH OF BOTTOM LANDING PER CITY STANDARDS
- EXISTING TRASH ENCLOSURE
- EXISTING SHORT TERM 34" HIGH x 24" WIDE INVERTED U-STYLE LOOP BICYCLE PARKING RACKS
- EXISTING FIRE HYDRANT
- EXISTING PARKING STALLS
- MENU BOARD - SEE DETAIL 1/A-10

PROJECT ANALYSIS

APPLICABLE CODES:

2016 CBC / 2016 CMC / 2016 CPC / 2016 CEC / 2016 CFC

SITE ADDRESS:

1966 WEST AVE 'L'
LANCASTER, CA 93534
3109-019-003

APN #:

BUILDING DATA

EXISTING BUILDING/AREA OF IMPROVEMENT 2,684 S.F.

FIRE SPRINKLER

NO

OCCUPANCY

A-2

OCCUPANT LOAD

AREA	SQUARE FOOTAGE	# OF OCCUPANT
WALK-IN COOLER/STOR	184 SF	1 OCCUPANT
BOH	752 SF	8 OCCUPANTS
DINING	1,230 SF	73 SEATS
TOTAL OCCUPANT LOAD		82 OCC

EXITS REQUIRED

2

EXIT WIDTH REQUIRED (82 X 2)

16.4'

EXITS PROVIDED

3

EXIT WIDTH PROVIDED

14.4'

PARKING DATA

EXISTING CENTER NO CHANGE TO PARKING

BIKE PARKING PROVIDED BY ORIGINAL DEVELOPER

CALIFORNIA GREEN CODE NOTES

- CONTRACTOR SHALL SUBMIT A CONSTRUCTION WASTE MANAGEMENT PLAN FOR APPROVAL BY THE ENFORCEMENT AGENCY THAT:
 - IDENTIFIES THE MATERIALS TO BE DIVERTED FROM DISPOSAL BY EFFICIENT USAGE, RECYCLING, REUSE ON THE PROJECT OR SALVAGE FOR FUTURE USE OR SALE.
 - DETERMINES IF MATERIALS WILL BE SORTED ON-SITE OR MIXED.
 - IDENTIFIES DIVERSION FACILITIES WHERE MATERIAL COLLECTED WILL BE TAKEN.
 - SPECIFIES THAT THE AMOUNT OF MATERIALS DIVERTED SHALL BE CALCULATED BY WEIGHT OR VOLUME, BUT NOT BY BOTH.DOCUMENTATION SHALL BE PROVIDED TO THE ENFORCING AGENCY WHICH DEMONSTRATES COMPLIANCE WITH SECTION 5.408.2 ITEMS 1 THRU 4. THE WASTE MANAGEMENT PLAN SHALL BE UPDATED AS NECESSARY AND SHALL BE ACCESSIBLE DURING CONSTRUCTION FOR EXAMINATION BY THE ENFORCING AGENCY (PER CCBSC 2016, DIVISION 5.408.2)
- RECYCLE AND/OR SALVAGE FOR REUSE A MINIMUM OF 65 PERCENT OF THE NON-HAZARDOUS CONSTRUCTION AND DEMOLITION DEBRIS, OR MEET A LOCAL CONSTRUCTION AND DEMOLITION WASTE MANAGEMENT ORDINANCE, WHICHEVER IS MORE STRINGENT. CALCULATE THE AMOUNT OF MATERIALS DIVERTED BY WEIGHT OR VOLUME, BUT NOT BY BOTH. THE EXCEPTIONS ARE EXCAVATED SOIL AND LAND- CLEARING DEBRIS OR ALTERNATE WASTE REDUCTION METHODS DEVELOPED BY WORKING WITH LOCAL AGENCIES IF DIVERSION OR RECYCLE FACILITIES CAPABLE OF COMPLIANCE WITH THIS ITEM DO NOT EXIST (PER CCBSC 2016, DIVISION 5.408.3)
- PROVIDE READILY ACCESSIBLE AREAS THAT SERVE THE ENTIRE BUILDING AND ARE IDENTIFIED FOR THE DEPOSITING, STORAGE AND COLLECTION OF NON-HAZARDOUS MATERIALS FOR RECYCLING, INCLUDING (AT A MINIMUM) PAPER, CORRUGATED CARDBOARD, GLASS, PLASTICS AND METALS (PER CCBSC 2016, DIVISION 5.4101)
- THE HVAC SYSTEM SHALL BE TESTED PER THE MANUFACTURER'S INSTALLATION INSTRUCTIONS TO ENSURE EQUIPMENT IS FUNCTIONING PROPERLY. TESTS SHALL INCLUDE BUT ARE NOT LIMITED TO VISUAL INSPECTION OF FURNACE FIRE, AMP READING OF MOTOR TO ENSURE PROPER SETTING, TEMPERATURE SET POINT VERIFICATION TO ENSURE COOLING OPERATION, AIR BALANCE OF DUCT SYSTEM TO ENSURE PROPER AIR FLOW PER AC UNIT MANUFACTURER AND TO MATCH CONSTRUCTION DOCUMENTS.
- THE HVAC THERMOSTAT SHALL BE INSPECTED AND TESTED TO ENSURE PROPER OPERATION. TESTS SHALL INCLUDE BUT ARE NOT LIMITED TO PROGRAMMING, AND SET TEMPERATURES FOR COOLING AND HEATING.
- THE INDOOR AND OUTDOOR LIGHTING AND CONTROL SYSTEMS SHALL BE INSPECTED AND TESTED TO ENSURE PROPER INSTALLATION AND OPERATION. TESTS SHALL INCLUDE BUT ARE NOT LIMITED TO VISUAL INSPECTION OF ALL FIXTURES TO ENSURE CONFORMANCE TO SPECIFICATIONS LISTED IN THE APPROVED CONSTRUCTION DOCUMENTS AND MANUFACTURER'S RECOMMENDED INSTALLATION INSTRUCTIONS.
- THE WATER HEATING SYSTEM SHALL BE INSPECTED AND TESTED TO ENSURE PROPER OPERATION. TESTS SHALL INCLUDE BUT ARE NOT LIMITED TO VISUAL INSPECTION FOR LEAKS, SET POINT AND VERIFICATION OF TEMPERATURE.
- ALL BUILDING SYSTEMS TESTING AND ADJUSTING PROCEDURES SHALL BE PERFORMED IN ACCORDANCE WITH INDUSTRY BEST PRACTICES AND APPLICABLE STANDARDS ON EACH SYSTEM AS DETERMINED BY THE BUILDING OFFICIAL.
- UPON COMPLETION OF CONSTRUCTION CONTRACTOR SHALL PROVIDE THE BUILDING OWNER OR REPRESENTATIVE WITH: DETAILED OPERATING AND MAINTENANCE INSTRUCTIONS AND COPIES OF GUARANTEES/WARRANTIES FOR EACH SYSTEM. OPERATION AND MAINTENANCE INSTRUCTIONS SHALL BE CONSISTENT WITH OSHA REQUIREMENTS IN CFR, TITLE 29, SECTION 1910.262 AND OTHER RELATED REGULATIONS. INCLUDE A COPY OF ALL INSPECTION VERIFICATIONS AND REPORTS REQUIRED BY THE ENFORCING AGENCY.

SHEET INDEX

T-1.0	TITLE SHEET	F5-1.0	KITCHEN EQUIPMENT PLAN
A-1.0	FLOOR PLAN	F5-2.0	KITCHEN EQUIPMENT SCHEDULE
A-2.0	REFLECTED CEILING PLAN	F5-3.0	KITCHEN EQUIPMENT ELECTRICAL
A-3.0	FINISH PLAN	F5-4.0	KITCHEN EQUIPMENT PLAN
A-4.0	FURNITURE PLAN	F5-5.0	KITCHEN EQUIPMENT PLAN
A-5.0	DETAILS	F5-5.1	KITCHEN HOOD SHOP DRAWINGS
A-6.0	SPECIFICATIONS	F5-5.2	KITCHEN HOOD SHOP DRAWINGS
A-6.1	SPECIFICATIONS	F5-5.3	KITCHEN HOOD SHOP DRAWINGS
A-6.2	SPECIFICATIONS	F5-5.4	KITCHEN HOOD SHOP DRAWINGS
A-6.3	SPECIFICATIONS	F5-5.5	KITCHEN HOOD SHOP DRAWINGS
A-6.4	SPECIFICATIONS	F5-5.6	KITCHEN HOOD SHOP DRAWINGS
A-6.5	SPECIFICATIONS	F5-5.7	KITCHEN HOOD SHOP DRAWINGS
P-1.0	PLUMBING PLAN - DCM, DHW	F5-5.8	KITCHEN HOOD SHOP DRAWINGS
P-1.02	PLUMBING PLAN - SOIL WASTE & VENT	F5-5.9	KITCHEN HOOD SHOP DRAWINGS
P-1.03	PLUMBING PLAN - GAS AND CONDENSATE	F5-6.0	KITCHEN SPECIAL CONDITIONS
P-1.04	PLUMBING PLAN - ROOF	F5-6.1	KITCHEN WALK IN COOLER AND FREEZER
P-3.00	PLUMBING PLAN - FIXTURE SCHEDULE	F5-7.0	KITCHEN CRITICAL DIMENSION PLAN
P-3.01	PLUMBING PLAN - SCHEDULES	F5-8.0	EQUIPMENT ELEVATIONS
P-4.00	PLUMBING PLAN - DETAILS	F5-9.0	KITCHEN GENERAL NOTES
P-4.01	PLUMBING PLAN - DETAILS		
P-5.00	PLUMBING PLAN - PLUMBING NOTES		
P-5.01	PLUMBING PLAN - PLUMBING NOTES		
P-5.02	PLUMBING PLAN - PLUMBING NOTES		
P-5.03	PLUMBING PLAN - PLUMBING NOTES		
M-1.01	MECHANICAL PLAN		
M-1.02	MECHANICAL ROOF PLAN		
M-2.01	MECHANICAL SCHEDULE		
M-3.01	MECHANICAL NOTES		
M-3.02	MECHANICAL NOTES		
E-1.01	ELECTRICAL LIGHTING PLAN		
E-1.02	ELECTRICAL POWER AND SIGNAL PLAN		
E-3.01	ELECTRICAL ROOF		
E-4.01	ELECTRICAL LIGHTING CONTROL		
E-5.01	ELECTRICAL PANEL SCHEDULE		
E-5.02	ELECTRICAL DETAIL		
E-6.01	ELECTRICAL NOTES		
E-6.02	ELECTRICAL NOTES		
E-6.03	ELECTRICAL NOTES		
T-24	TITLE 24		

PLUMBING FIXTURE COUNT

DINING AREA (1/30)	1,230 SF	41 OCC
BOH/OFFICE (1/200)	752 SF	4 OCC
WALK - IN(1/200)	184 SF	1 OCC
TOTAL		46 OCC

LESS THAN 50 OCCUPANTS ONLY ONE FIXTURE REQUIRED FOR EACH SEX
CFC TABLE 422J NOTE #3

GENERAL NOTES

- VERIFY, AT SITE, ALL EXISTING CONDITIONS PRIOR TO CONSTRUCTION.
- EQUIPMENT AND ITEMS INDICATED AS NOT BEING INCLUDED IN THE CONTRACT(N.I.C.) SHALL BE VERIFIED WITH THE OWNER'S REPRESENTATIVE AS TO SIZE, SHAPE AND UTILITY REQUIREMENTS TO INSURE COMPLETE AND PROPER INSTALLATION AND OPERATION.
- ALL MANUFACTURED MATERIAL, EQUIPMENT, AND SYSTEMS SHALL BE INSTALLED AS DIRECTED BY THE MANUFACTURER UNLESS SPECIFIED TO THE CONTRARY AND ONLY THEN IS SUCH CONFLICT IS FIRST VERIFIED WITH THE ARCHITECT IN WRITING.
- WRITTEN DIMENSIONS SHALL HAVE PRECEDENCE OVER SCALED DIMENSIONS.
- IN THE EVENT OF CONFLICTING STATEMENTS OR REQUIREMENTS, NOTIFY THE ARCHITECT IN SUFFICIENT TIME TO PERMIT THE ISSUANCE OF WRITTEN CLARIFICATION.
- ALL WORK SHALL BE IN COMPLIANCE WITH ALL APPLICABLE CODES AND ORDINANCES.
- POST BUILDING ADDRESS PER FIRE DEPARTMENT REQUIREMENTS. VERIFY EXACT LOCATION WITH ARCHITECT.

DEFERRED SUBMITTALS

- A SITE DEVELOPMENT PERMIT IS REQUIRED FOR ANY EXTERIOR SIGNAGE INSTALLED


LUMINAIRE SCHEDULE																			
MARK	DESCRIPTION	MANUFACTURER	CATALOG NUMBER	LAMP SPECIFICATION (SEE GENERAL NOTE A)			VOLTS	VA LOAD	MOUNTING								REMARKS		
				LAMP QUAN	LAMP DESCRIPTION	LAMP TYPE			CEILING		WALL	GRADE		POLE	COVE	UNDERCABINET			
									RECESSED	SURFACE	RECESSED	SURFACE	FLUSH					STANCHION	
L1	14" WAREHOUSE SHADE (PENDANT MOUNT)	HI-LITE MFG	H-15114-CORD WITH 18/LED2/2700K/E/D/BCM/M	1	INCLUDED	LED	120	21				X							CORD SUSPENDED
L2	TRACK SPOTLIGHT (CEILING MOUNT)	COOPER LIGHTING/HALO	LZR1320-MB	1	LR20/25/27K/975/BK	LED	120	12		X									
L3	2 X 2 TROFFER	EATON/METALUX	22GR-LD4-32-F1-UNV-L830-CD1-G2-U	—	INCLUDED	LED	120/277	34	X										
L4	6" CAN LIGHTING	ACUITY LIGHTING/JUNO	IC2/J6RLEG4-27K-9-WH	—	INCLUDED	LED	120	16	X										
L5	2 X 4 TROFFER	EATON/METALUX	24GR-LD4-48-F1-UNV-L830-CD1-G2-U	—	INCLUDED	LED	120/277	45	X										
L6	2 X 4 TROFFER (EMERGENCY)	EATON/METALUX	24GR-LD4-48-F1-UNV-EL14W-L830- CD1-G2-U	—	INCLUDED	LED	120/277	45	X										
L7	DECORATIVE LAMPS	HATCO	DLH-500RL	1	COATED CLEAR DLH	HAL	120	375			X								
DC	EMERGENCY LIGHT UNIT (CEILING MOUNT)	BARRON LIGHTING	EXITRONIX LED-90	—	INCLUDED	LED	120/277	3		X									
DW	EMERGENCY LIGHT UNIT (WALL MOUNTED)	BARRON LIGHTING	EXITRONIX LED-90	—	INCLUDED	LED	120/277	3				X							
EW	EXIT SIGN (WALL MOUNTED)	BARRON LIGHTING	EXITRONIX GVEX-U-BP-WB-WH	—	INCLUDED	LED	120/277	4					X						
EC	EXIT SIGN/LIGHT COMBO (WALL MOUNTED)	BARRON LIGHTING	EXITRONIX GVLED-U-WH-EL90	—	INCLUDED	LED	120/277	7					X						

LUMINAIRE FIXTURE SCHEDULE GENERAL NOTES:
NOTE A: FL=FLUORESCENT, CFL=COMPACT FLUORESCENT, IND=INCANDESCENT, MH=METAL HALIDE, HPS=HIGH PRESSURE SODIUM, LED=LIGHT EMITTING DIODE, HAL=HALOGEN.
NOTE B: INSTALLATION OF LIGHT FIXTURES SHALL BE ACCORDING TO MANUFACTURER'S RECOMMENDATIONS AND APPLICABLE CODE REQUIREMENTS.
NOTE C: VERIFY THE EXACT MOUNTING HEIGHT AND FINISH OF ALL LIGHTING FIXTURES WITH ARCHITECT PRIOR TO PLACING ORDER OR COMMENCING WORK.

LIGHTING SWITCHBANK SCHEDULE			
SWITCH	LOAD CONTROLLED	DESCRIPTION	TYPE
a	-	ORDER LTS	MANUAL SWITCH
b	-	PICK LTS	LOW-VOLTAGE DIMMER SWITCH
c	-	TRACK LIGHTING	LOW-VOLTAGE DIMMER SWITCH
d	-	DINING LIGHTS	LOW-VOLTAGE DIMMER SWITCH
E	-	DINING LIGHTS	LOW-VOLTAGE DIMMER SWITCH
F	-	DINING LIGHTS	LOW-VOLTAGE DIMMER SWITCH
G	-	DINING LIGHTS	LOW-VOLTAGE DIMMER SWITCH

GENERAL ELECTRICAL NOTES:
A. SEE PANEL SCHEDULES FOR INFORMATION ON CIRCUITS THAT ARE TO BE ROUTED THROUGH CONTACTORS OR RELAYS FOR CONTROL.
B. CIRCUITS SERVING EMERGENCY LIGHTING EQUIPMENT SUCH AS EMERGENCY BATTERIES SHALL NOT SHARE A NEUTRAL (SHALL NOT BE PART OF A MULTIWIRED BRANCH CIRCUIT) WITH ANY OTHER CIRCUIT. PROVIDE A SEPARATE NEUTRAL FOR EVERY CIRCUIT THAT SERVES EMERGENCY LIGHTING EQUIPMENT.
C. ALTHOUGH NOT SPECIFICALLY SHOWN, THE ELECTRICAL CONTRACTOR SHALL PROVIDE ALL REQUIRED WIRING AND DATA CABLEING, INCLUDING ALL 0-10V CONTROL WIRING WHERE APPLICABLE, PER THE MANUFACTURER'S RECOMMENDATIONS FOR A COMPLETE, FUNCTIONAL DIMMING SYSTEM.

KEYED NOTES:
1. PROVIDE SWITCHBANK: REFER TO SWITCH SCHEDULE ON THIS SHEET. LABEL ALL SWITCHES WITH LOAD SERVED. COORDINATE SWITCH LABELING WITH ARCHITECT.
2. CONNECT TO EXHAUST FAN SERVING THIS ROOM. SEE SHEET E-201 FOR LOCATION OF EXHAUST FAN. SEE DETAIL 3/E-401 FOR CONTROL INFORMATION.
3. REFER TO SHEET E-201 FOR LIGHTING INFO FOR WALK-IN COOLER AND FREEZER.
4. CONNECT LIGHTING CIRCUIT VIA SWITCH(ES) LOCATED IN LIGHTING CONTROL SWITCHBANK. SEE SWITCH SCHEDULE FOR ADDITIONAL INFORMATION.



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE, SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (661) 326-8935
FACSIMILE: (661) 326-8037

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT 7 expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor designed to, in any third party without the expressed written consent of PAUL DHANENS ARCHITECT 7.

NOTICE TO CONTRACTORS:
Written dimensions on these drawings shall take precedence over noted dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT


TENANT IMPROVEMENT
FOR



1966 WEST AVE L
LANCASTER, CA

DATE ISSUED FOR
8-24-18 BUILDING DEPT SUBMITTAL
8-28-18

NO. REVISIONS




ELECTRICAL



FILE NAME: 2366A2-0

SHEET

E-101



LIGHTING CONTROL DIAGRAM - OCC SENSOR / RECEPTACLE



LIGHTING PLAN

1/4"



Kitchen Equipment List	
Mark	Equipment Description
EA01	WALK-IN COOLER/FREEZER
EA01A	HEAT TAPE
EA03	COOLER EVAP COIL
EA05	FREEZER EVAP COIL
EA14	GRIDDLE EXHAUST HOOD
EA14A	FIRE SUPPRESSION SYSTEM
EA14B	ELECTRICAL CONTROL PACKAGE
EA17	FRY LINE HOOD
EB01	AIR CURTAIN
EB07	SODA SYSTEM
EB15	FREEZER
EB17	OFFICE
EB24	POS
EB24A	POS
EB25	PRINTER
EB32	DISH MACHINE
EB47	ICE MACHINE
EB50	OIL TANK
EB51	ELECTRIC KETTLE
EB65	CONVECTION OVEN
EB66	FREEZER
EB67	HEAT LAMP
EB76	MILK DISPENSER
EB85	SODA DISPENSER
EB87	COFFEE BREWER
EB88	TEA BREWER
EB97	DRESSING TABLE
EB98	POS SYSTEM
EB101	STAB BOXES
EB103	VERTICAL TOASTER
EB104	GRIDDLE
EB105	GRIDDLE
EB106	DRESS TABLE
EB107	CHEESE MELTER
EB112	HEAT LAMP
EB112A	HEAT LAMP
EB113	DRAWER WARMER
EB114	COUNTER TOP WARMER
EB115	MICROWAVE
EB116	HOLDING UNIT
EB119	HOT FOOD DISPENSER
EB123	SMALL DUMP STATION
EB124	FRYER BATTER CONTROLS
EB125	POP UP TOASTER
EB126	FREEZER
EB132	KDS SYSTEM
ES10	PREP TABLE
ESS1	MAIN SHAKE STATION
ESS1A	SHAKE STATION ACCESSORY
ESS1B	SHAKE SATION ACCESSORY
E2000	AIR CURTAIN

KEYED NOTES:

1. PROVIDE FINAL CONNECTION TO SIGNAGE. COORDINATE LOCATION AND ALL REQUIREMENTS WITH SIGN CONTRACTOR PRIOR TO ROUGH-IN. PROVIDE AN APPROPRIATE LOCAL DISCONNECTING MEANS MOUNTED IN AN ACCESSIBLE, INCONSPICUOUS LOCATION THAT IS WITHIN SIGHT OF THE SIGN. EACH SIGN CIRCUIT SHALL HAVE A SEPARATE NEUTRAL AND SEPARATE EQUIPMENT GROUNDING CONDUCTOR.
2. PROVIDE FINAL CONNECTION TO WALK-IN COOLER/FREEZER EVAPORATOR. VERIFY ALL REQUIREMENTS WITH WALK-IN COOLER/FREEZER MANUFACTURER PRIOR TO ROUGH-IN. INTERLOCK WITH ASSOCIATED REMOTE CONDENSING UNIT, DEFROST CONTROLS, DOOR HEATERS, CONDENSATE LINE, HEAT TRACE, AND ALL OTHER APPURTENANCES PER THE MANUFACTURER'S REQUIREMENTS AND/OR RECOMMENDATIONS.
3. PROVIDE A 2'-0" x 8'-0" x 3/4" UL-LABELED FIRE-RETARDANT PLYWOOD BACKBOARD FOR TELECOMMUNICATIONS EQUIPMENT. PROVIDE GROUND BAR MOUNTED ON BACKBOARD WITH EQUIPMENT GROUNDING CONDUCTOR CONNECTED TO POWER SYSTEM'S GROUNDING ELECTRODE SYSTEM.
4. PROVIDE FINAL CONNECTION TO FREEZER HEAT TRACE TAPE. COORDINATE ALL REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN.
5. PROVIDE DEDICATED RECEPTACLE AT 88" AFF FOR OIL TANK. RECEPTACLE FOR OIL TANK SHALL NOT BE A GFI RECEPTACLE OR SHALL BE A GFI RECEPTACLE RATED FOR PUMP USAGE. PROVIDE JUNCTION BOX ON WALL 4" BELOW CEILING ABOVE FRYERS AND STUB 1" CONDUIT FROM BOX TO ABOVE CEILING FOR LOW VOLTAGE CABLING. COORDINATE INSTALLATION LOCATION AND REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN.
6. RUN FLEXIBLE CONDUIT CONCEALED WITH MILLWORK FOR CONNECTION TO DEVICES.
7. ALL PENETRATIONS THROUGH THE WALK-IN COOLER SHALL BE SEALED. ELECTRICAL CONTRACTOR SHALL AVOID SEAMS IN WALK-IN COOLER PANELS WHEN MAKING PENETRATIONS. ELECTRICAL CONTRACTOR SHALL MAKE ALL NECESSARY CONNECTIONS TO THE WALK-IN LIGHTS, DEFROST TIMERS, EVAPORATOR, ETC.
8. PROVIDE 20A/1P DISCONNECT SWITCH IN WEATHERPROOF, NEMA-3R ENCLOSURE FOR DRIVE-THRU MENU-BOARD. MOUNT DISCONNECT SWITCH TO BACK OF BOARD. COORDINATE EXACT LOCATION AND ALL REQUIREMENTS WITH ARCHITECTURAL PLANS.
9. PROVIDE (3) 1" UNDERGROUND CONDUITS, (1) FOR POWER, (1) FOR SPEAKER WIRES AND (1) FOR DETECTOR LOOP TO DRIVE-THRU MENU-BOARD AREA. EXTEND SPEAKER CONDUIT AND DETECTOR LOOP CONDUIT TO ABOVE CEILING. (NOTE: DETECTOR LOOP SHALL BE INSTALLED PRIOR TO THE PARKING LOT BEING INSTALLED. COORDINATE WITH OWNER AND GENERAL CONTRACTOR)
10. PROVIDE DEDICATED 15A/120V CIRCUIT FOR DRIVE THROUGH WINDOW. PROVIDE 30A/1P/NF NEMA-1 DISCONNECT SWITCH. COORDINATE EXACT LOCATION WITH PROJECT MANAGER AND ALL REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN.
11. PROVIDE 4" OCTAGONAL JUNCTION BOX WITH SCREW THREADS SET AT THE 2 AND 8 O'CLOCK POSITIONS FOR THE GREASE HOOD FIRE SUPPRESSION SYSTEM PULL STATION. PROVIDE A 1/2" CONDUIT FROM THE JUNCTION BOX TO 6" ABOVE THE ACCESSIBLE CEILING AND TERMINATE WITH A CONDUIT BUSHING. COORDINATE EXACT LOCATION WITH THE GREASE HOOD FIRE SUPPRESSION SYSTEM INSTALLER AND THE FIRE MARSHAL PRIOR TO ROUGH-IN.
12. INTERLOCK GAS SOLENOID VALVE WITH GREASE HOOD FIRE SUPPRESSION SYSTEM SUCH THAT GAS SOLENOID VALVE CLOSSES UPON GREASE HOOD FIRE SUPPRESSION SYSTEM DISCHARGE. COORDINATE ALL REQUIREMENTS WITH PLUMBING CONTRACTOR.
13. THE ELECTRICAL CONTRACTOR IS RESPONSIBLE TO PROVIDE ALL WIRING AND COMPONENTS INDICATED AS FIELD WIRING OF HOOD CONTROL SYSTEM. VERIFY AND COORDINATE ALL REQUIREMENTS WITH THE HOOD CONTROL PANEL MANUFACTURER AND MECHANICAL CONTRACTOR PRIOR TO ROUGH-IN.

GENERAL ELECTRICAL NOTES:

- A. WHERE THE MECHANICAL DESIGN UTILIZES A PLENUM RETURN AIR CEILING DESIGN, ALL EQUIPMENT AND MATERIALS INSTALLED WITHIN THE PLENUM RETURN CEILING MUST MEET THE FLAME SPREAD AND SMOKE DEVELOPED RATINGS OF 25/50 AND BE APPROVED FOR USE IN PLENUM RETURN CEILINGS. COORDINATE PLENUM CEILING LOCATIONS WITH THE MECHANICAL CONTRACTOR. LUMINAIRES THAT ARE MANUFACTURED WITH A METAL HOUSING MEET THIS REQUIREMENT AND ARE NOT REQUIRED TO BE PLENUM RATED UNLESS INDICATED OTHERWISE.
- B. COORDINATE ALL DEVICE LOCATIONS AND CIRCUIT ROUTING WITHIN ANY MILLWORK WITH MILLWORK VENDOR PRIOR TO ROUGH-IN.
- C. COORDINATE THE CONNECTIONS OF ALL EQUIPMENT PROVIDED BY OTHERS WITH THE CONTRACTOR PROVIDING THE EQUIPMENT PRIOR TO ROUGH-IN. THIS INCLUDES, BUT IS NOT LIMITED TO, MECHANICAL EQUIPMENT, KITCHEN EQUIPMENT, AUDIO/VISUAL EQUIPMENT, FIRE SUPPRESSION SYSTEM EQUIPMENT, FIRE ALARM EQUIPMENT, ETC. THE ELECTRICAL CONTRACTOR IS RESPONSIBLE TO PROVIDE THE APPROPRIATE DISCONNECTING MEANS FOR, AND TO MAKE THE FINAL CONNECTION TO, ANY HARDWIRED EQUIPMENT. THE ELECTRICAL CONTRACTOR IS ALSO RESPONSIBLE TO PROVIDE AN APPROPRIATE CORD AND PLUG FOR ANY CORD-AND-PLUG CONNECTED EQUIPMENT THAT IS NOT EQUIPPED WITH AN INTEGRAL CORD AND PLUG.
- D. SEE PANEL SCHEDULES FOR INFORMATION ON CIRCUITS THAT ARE TO BE ROUTED THROUGH CONTRACTORS OR RELAYS FOR CONTROL.
- E. ALL EQUIPMENT, DEVICES, AND LUMINAIRES SHALL BE SUITABLE FOR THE ENVIRONMENT IN WHICH THEY ARE INSTALLED. EQUIPMENT MOUNTED OUTDOORS SHALL BE NEMA 3R. DEVICES MOUNTED IN DAMP OR WET LOCATIONS SHALL BE WEATHERPROOF. RECEPTACLES RATED 15- OR 20-AMPS AND 120 VOLTS WHICH ARE LOCATED IN DAMP OR WET LOCATIONS SHALL BE GFCI PROTECTED AND EQUIPPED WITH A SUITABLE WEATHERPROOF COVERPLATE (WHILE-IN-USE IN WET LOCATIONS).
- F. ALL LUGS, TERMINALS, ETC. IN ELECTRICAL DISTRIBUTION EQUIPMENT SHALL BE LISTED FOR A MINIMUM OF 75 DEGREE C CONDUCTORS. TERMINATIONS LISTED FOR ONLY 60 DEGREE C CONDUCTORS ARE NOT PERMITTED.





POWER & SIGNAL PLAN

1/4"





PAUL DHANENS • ARCHITECT

ARCHITECT	
	
5100 CALIFORNIA AVE., SUITE 107 BAKERSFIELD, CALIFORNIA 93309 TELEPHONE: (805) 326-8935 FACSIMILE: (805) 326-8037	
CONSULTANT	
COPYRIGHT	
PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted in any third party without the expressed written consent of PAUL DHANENS ARCHITECT.	
NOTICE TO CONTRACTORS: Written dimensions on these drawings shall take precedence over noted dimensions. Contractors shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies for their resolution, if any.	
PROJECT	
TENANT IMPROVEMENT FOR	
	
1966 WEST AVE L LANCASTER, CA	
DATE	ISSUED FOR
8-24-18	BUILDING DEPT SUBMITTAL
6-26-19	
NO.	REVISIONS
▲	
▲	
▲	
▲	
ELECTRICAL	
FILE NAME:	2366A2-0
SHEET	
E-201	


- GENERAL ELECTRICAL NOTES:
- A. COORDINATE THE CONNECTIONS OF ALL EQUIPMENT PROVIDED BY OTHERS WITH THE CONTRACTOR PROVIDING THE EQUIPMENT PRIOR TO ROUGH-IN. THIS INCLUDES, BUT IS NOT LIMITED TO, MECHANICAL EQUIPMENT, KITCHEN EQUIPMENT, AUDIO/VISUAL EQUIPMENT, FIRE SUPPRESSION SYSTEM EQUIPMENT, FIRE ALARM EQUIPMENT, ETC. THE ELECTRICAL CONTRACTOR IS RESPONSIBLE TO PROVIDE THE APPROPRIATE DISCONNECTING MEANS FOR, AND TO MAKE THE FINAL CONNECTION TO, ANY HARDWIRED EQUIPMENT. THE ELECTRICAL CONTRACTOR IS ALSO RESPONSIBLE TO PROVIDE AN APPROPRIATE CORD AND PLUG FOR ANY CORD-AND-PLUG CONNECTED EQUIPMENT THAT IS NOT EQUIPPED WITH AN INTEGRAL CORD AND PLUG.
- B. ALL EQUIPMENT, DEVICES, AND LUMINAIRES SHALL BE SUITABLE FOR THE ENVIRONMENT IN WHICH THEY ARE INSTALLED. EQUIPMENT MOUNTED OUTDOORS SHALL BE NEMA 3R. DEVICES MOUNTED IN DAMP OR WET LOCATIONS SHALL BE WEATHERPROOF. RECEPTACLES RATED 15- OR 20-AMPS AND 120 VOLTS WHICH ARE LOCATED IN DAMP OR WET LOCATIONS SHALL BE GFCI PROTECTED AND EQUIPPED WITH A SUITABLE WEATHERPROOF COVERPLATE (WHILE-IN-USE IN WET LOCATIONS).
- C. ALL LUGS, TERMINALS, ETC. IN ELECTRICAL DISTRIBUTION EQUIPMENT SHALL BE LISTED FOR A MINIMUM OF 75 DEGREE C CONDUCTORS. TERMINATIONS LISTED FOR ONLY 60 DEGREE C CONDUCTORS ARE NOT PERMITTED.

- KEYED NOTES:
1. DISCONNECT SWITCH IS PROVIDED BY EQUIPMENT MANUFACTURER INTEGRAL WITH EQUIPMENT. THE ELECTRICAL CONTRACTOR SHALL PROVIDE CIRCUIT AND FINAL CONNECTION TO DISCONNECT SWITCH AS INDICATED.
2. WEATHERPROOF GFCI SERVICE RECEPTACLE IS PROVIDED BY EQUIPMENT MANUFACTURER INTEGRAL WITH EQUIPMENT. THE ELECTRICAL CONTRACTOR SHALL PROVIDE CIRCUIT AND FINAL CONNECTION TO SERVICE RECEPTACLE AS INDICATED.
3. DUCT SMOKE DETECTOR AND RELAY FOR HVAC UNIT SUPPLY FAN SHUTDOWN SHALL BE FURNISHED BY THE ELECTRICAL CONTRACTOR FOR INSTALLATION BY THE MECHANICAL CONTRACTOR. THE ELECTRICAL CONTRACTOR SHALL ALSO PROVIDE A REMOTE KEYED TEST STATION WITH VISUAL STATUS ANNUNCIATOR WHEN DUCT SMOKE DETECTOR IS INSTALLED IN A CONCEALED LOCATION GREATER THAN 10'-0" ABOVE FINISHED FLOOR OR WHEN DUCT SMOKE DETECTOR'S STATUS INDICATORS ARE NOT READILY VISIBLE. COORDINATE LOCATION OF REMOTE KEYED TEST STATION WITH AUTHORITY HAVING JURISDICTION AND OWNER PRIOR TO ROUGH-IN. ALL FINAL WIRING SHALL BE BY THE ELECTRICAL CONTRACTOR.
4. CONNECT EXHAUST FAN TO LIGHTING CIRCUIT SERVING THE RESTROOM. SEE SHEET E-101 FOR CONTINUATION.
5. STARTER IS FURNISHED BY HOOD SUPPLIER IN HOOD MASTER CONTROL PANEL. MAKE FINAL CONNECTION THROUGH HOOD MASTER CONTROL PANEL.



ELECTRICAL ROOF PLAN

1/4"




PAUL DHANENS • ARCHITECT

ARCHITECT	
<div><div>PAUL DHANENS ARCHITECT NO. C-23843 GENERAL STATE OF CALIFORNIA</div><div>5100 CALIFORNIA AVE, SUITE 107 BAKERSFIELD, CALIFORNIA 93309 TELEPHONE: (661) 326-8935 FACSIMILE: (661) 326-8937</div></div>	
CONSULTANT	
COPYRIGHT	
PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.	
NOTICE TO CONTRACTORS Written dimensions on these drawings shall take precedence over scaled dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.	
PROJECT	
TENANT IMPROVEMENT FOR	
<div><div>THAMOUS FOR</div><div>Steak 'n Shake</div><div>STEAKBURGERS</div></div>	
1966 WEST AVE L LANCASTER, CA	
DATE	ISSUED FOR
8-24-18	BUILDING DEPT SUBMITTAL
6-28-19	
NO.	REVISIONS
▲	
▲	
▲	
▲	
ELECTRICAL	
FILE NAME:	2366A2-0
SHEET	
E-301	

PANEL "M" SCHEDULE													
FED FROM:		FUSIBLE SWITCH				MOUNTING:				SURFACE MOUNTED			
VOLTAGE:		120/208V, 3 PHASE, 4 WIRE				ENCLOSURE:				NEMA 1			
BUS MATERIAL:		ALUMINUM OR COPPER				FAULT CURRENT:				35331 AMPS			
BUS LOAD:		104 AMPS				AIC RATING:				42 KAIC			
BUS RATING:		225 AMPS				OPTIONS*:				BONDED EQUIPMENT GROUND BAR			
MAIN:		MAIN LUG ONLY											
NOTES	CKT.	LOAD DESCRIPTION	LOAD (VA)			BREAKER	BREAKER	LOAD (VA)			LOAD DESCRIPTION	CKT.	NOTES
			A	B	C			A	B	C			
	1	ICE CONDENSING UNIT	1116			20/3	15/3	312			EF-1	2	
	3	-----		1116		----	----		312		-----	4	
	5	-----			1116	----	----			312	-----	6	
	7	ICE CONDENSING UNIT	1116			20/3	15/3	264			EF-2	8	
	9	-----		1116		----	----		264		-----	10	
	11	-----			1116	----	----			264	-----	12	
	13	ICE CONDENSING UNIT	1116			20/3	20/3	1088			MUA-1 CONDENSER 1	14	
	15	-----		1116		----	----		1088		-----	16	
	17	-----			1116	----	----			1088	-----	18	
	19	MUA-1	708			15/3	30/2	1875			AC-1	20	
	21	-----		708		----	----		1875		18A	22	
	23	-----			708	----	20/1			540	RECEPT	24	
	25	COOLER CONDEN	624			15/2	20/3	1088			MUA-1 CONDENSER 2	26	
	27	-----		624		----	----		1088		-----	28	
	29	FREEZER CONDEN			1882	25/2	----			1088	-----	30	
	31	-----	1882			----	30/2	1875			AC-2	32	
	33	AC-4		5220		60/3	----		1875		18A	34	
	35	43.5A			5220	----	30/2		1875		AC-3	36	
	37	-----		5220		----	----		1875		18A	38	
	39	SPACE ONLY									SPACE ONLY	40	
	41	SPACE ONLY									SPACE ONLY	42	
TOTALS:			11782	9900	11158			8377	6502	5167			
NOTES: * PROVIDE HANDLE TIES FOR ALL MULTIWIRED BRANCH CIRCUITS. SEE SPECIFICATIONS FOR OTHER OPTIONS REQUIRED.													
PHASE A VOLT-AMPS : <u>20159</u> VA.													
PHASE B VOLT-AMPS : <u>16402</u> VA.													
PHASE C VOLT-AMPS : <u>16325</u> VA.													
TOTAL DEMAND AMPS = <u>52886</u> VOLTS-AMPS ÷ (√3 • PHASE VOLTAGE <u>208</u> VOLTS) = <u>147</u> AMPS													

PANEL "T" SCHEDULE													
FED FROM:		POWER PANEL "MDP"					MOUNTING:		SEMI-FLUSH MOUNTED				
VOLTAGE:		120/208V, 3 PHASE, 4 WIRE					ENCLOSURE:		NEMA 1				
BUS MATERIAL:		ALUMINUM OR COPPER					FAULT CURRENT:		13900 AMPS				
BUS LOAD:		25 AMPS					AIC RATING:		22 KAIC				
BUS RATING:		100 AMPS					OPTIONS*:		BONDED EQUIPMENT GROUND BAR				
MAIN:		MAIN LUG ONLY											
NOTES	CKT.	LOAD DESCRIPTION	LOAD (VA)			BREAKER	BREAKER	LOAD (VA)			LOAD DESCRIPTION	CKT.	NOTES
			A	B	C			A	B	C			
	HPL 1	FIRE SUPPRESSION SYSTEM	500			20/1	20/1	900			DRESS TABLE	2	GFCI
	HPL 3	ELECTRICAL CONTROL PACK		500		20/1	20/1		1200		HOLDING UNIT	4	GFCI
	C-ST 5	VERTICAL TOASTER			1643	20/2	20/1			1200	HOLDING UNIT	6	GFCI
	C-ST 7	-----	1643			---	20/1	900			DRAWER WARMER	8	GFCI
	9	SPARE				20/1	15/1		648		HEAT LAMP	10	HPL
	11	SPARE				20/1	20/1		900		POS SYSTEM	12	GFCI
	13	SPARE				20/1					SPACE ONLY	14	
	15	SPARE				20/1					SPACE ONLY	16	
	17	SPARE				20/1					SPACE ONLY	18	
	19	SPARE				20/1					SPACE ONLY	20	
	21	SPARE				20/1					SPACE ONLY	22	
	23	SPARE				20/1					SPACE ONLY	24	
	25	SPARE				20/1					SPACE ONLY	26	
	27	SPARE				20/1					SPACE ONLY	28	
	29	SPARE				20/1					SPACE ONLY	30	
TOTALS:			2143	500	1643			1800	1848	2100			
NOTES:													
* PROVIDE HANDLE TIES FOR ALL MULTIWIRED BRANCH CIRCUITS. SEE SPECIFICATIONS FOR OTHER OPTIONS REQUIRED.													
GFCI CIRCUIT BREAKER SHALL BE GROUND-FAULT CIRCUIT INTERRUPTING (GFCI) TYPE													
HPL CIRCUIT BREAKER SHALL HAVE HANDLE PADLOCK ATTACHMENT TO LOCK BREAKER IN OPEN POSITION													
C-# CIRCUIT SHALL BE ROUTED THROUGH CONTACTOR, # = CONTACTOR NUMBER													
PHASE A VOLT-AMPS : <u>3943</u> VA.													
PHASE B VOLT-AMPS : <u>2348</u> VA.													
PHASE C VOLT-AMPS : <u>3743</u> VA.													
TOTAL DEMAND AMPS = <u>10034</u> VOLTS-AMPS ÷ (√3 • PHASE VOLTAGE <u>208</u> VOLTS) = <u>28</u> AMPS													

PANEL "K" SCHEDULE														
FED FROM:			PANEL UTILITY TRANSFORMER				MOUNTING:			SURFACE MOUNTED				
VOLTAGE:			120/208V, 3 PHASE, 4 WIRE				ENCLOSURE:			NEMA 1				
BUS MATERIAL:			ALUMINUM OR COPPER				FAULT CURRENT:			15093 AMPS				
BUS LOAD:			104 AMPS				AIC RATING:			22 KAIC				
BUS RATING:			225 AMPS				OPTIONS*:			BONDED AND ISOLATED GROUND BARS				
MAIN:			MAIN LUG ONLY											
NOTES	CKT.	LOAD DESCRIPTION	LOAD (VA)			BREAKER	BREAKER	LOAD (VA)			LOAD DESCRIPTION	CKT.	NOTES	
			A	B	C			A	B	C				
	GFCI	1	KDS SYSTEM	900			20/1	20/1	500			HOOD CONTROL	2	
	GFCI	3	POS SYSTEM		900		20/1	20/1		500		HOOD CONTROL	4	
	HPL	5	FREEZER EVAP COIL			1352	20/2	20/1			500	LCP	6	
		7	-----	1352			----	20/1	500			SHUNT TRIP CONTACTOR	8	
	GFCI	9	OFFICE RECEP		1800		20/1					SHUNT TRIP COIL	10	ST
	GFCI	11	OFFICE RECEP			1800	20/1	20/1				SPARE	12	
	GFCI	13	TELEPHONE BOARD	360			20/1	20/1	180			GRIDDLE	14	GFCI/ C-S
		15	SPARE				15/1	20/1		180		GRIDDLE	16	GFCI/ C-S
	HPL	17	WALK-IN COOLER/FREEZER			600	15/1	20/1			900	STAB BOXES	18	GFCI/ C-S
		19	RECEPT.	180			20/1	20/1	500			HWM-1	20	
	GFCI	21	SODA SYSTEM		1000		20/1	20/1		500		P-1	22	C-INT
		23	OIL TANK			1000	20/1	20/1				SPARE	24	
		25	RECEPT.	540			20/1	20/1	720			UC REFRIGERATOR	26	GFCI
	GFCI	27	PRINTER		360		20/1	15/1				SPARE	28	
	GFCI	29	POS			900	20/1	20/1				SPARE	30	
	GFCI	31	PRINTER	360			20/1	20/1	1800			HEAT TRACE	32	GFPE
	GFCI	33	KDS SYSTEM		900		20/1	20/1		360		PRINTER	34	GFCI
	GFCI	35	SMALL DUMP STATION			1080	20/1	20/1		900		POS	36	GFCI
GFCI/ C-ST	37	FRYER BATTER CONTROLS	612				20/1	20/1	900			POS SYSTEM	38	GFCI
GFCI	39	KDS SYSTEM		900			20/1	20/1		180		SHAKE STATION ACCESSORY	40	GFCI
GFCI	41	SHAKE STATION ACCESSORY			600		20/1	20/1		420		SODA DISPENSER	42	GFCI
GFCI	43	SHAKE STATION ACCESSORY	600				20/1	30/1	2400			MAIN SHAKE STATION	44	GFCI
GFCI	45	FREEZER		1140			20/1	20/1		600		SHAKE STATION ACCESSORY	46	GFCI
GFCI	47	FREEZER			1140		20/1	20/1			600	SHAKE STATION ACCESSORY	48	GFCI
GFCI	49	PREP TABLE	1800				20/1	20/1				SPARE	50	
GFCI	51	MILK DISPENSER		180			20/1	20/1				SPARE	52	
	53	SPARE					20/1	20/1				SPARE	54	
HPL	55	COOLER EVAP COIL	1332				15/1					SPACE ONLY	56	
	57	SPARE					20/1					SPACE ONLY	58	
	59	SPARE					20/1					SPACE ONLY	60	
			TOTALS:	8036	7180	8472			7500	2320	3320			
NOTES:														
* PROVIDE HANDLE TIES FOR ALL MULTIWIRE BRANCH CIRCUITS. SEE SPECIFICATIONS FOR OTHER OPTIONS REQUIRED.														
GFCI CIRCUIT BREAKER SHALL BE GROUND-FAULT CIRCUIT INTERRUPTING (GFCI) TYPE														
OFFPE CIRCUIT BREAKER SHALL BE GROUND-FAULT PROTECTION OF EQUIPMENT (GFFE) TYPE														
ST CIRCUIT BREAKER SHALL BE EQUIPPED WITH SHUNT TRIP COIL														
HPL CIRCUIT BREAKER SHALL HAVE HANDLE PADLOCK ATTACHMENT TO LOCK BREAKER IN OPEN POSITION														
C-# CIRCUIT SHALL BE ROUTED THROUGH CONTACTOR, # = CONTACTOR NUMBER														
PHASE A VOLT-AMPS : 15536 VA														
PHASE B VOLT-AMPS : 9500 VA														
PHASE C VOLT-AMPS : 11792 VA														
TOTAL DEMAND AMPS = 36828 VOLTS-AMPS ÷ (√3 * PHASE VOLTAGE 208 VOLTS) = 102 AMPS														



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE, SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (661) 326-8936
FACSIMILE: (661) 326-8037

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted in any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS:
Written dimensions on these drawings shall take precedence over unnoted dimensions. Contractors shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT
FOR



1966 WEST AVE L
LANCASTER, CA

DATE	ISSUED FOR
8-24-18	BUILDING DEPT SUBMITTAL
8-28-19	


NO.	REVISIONS
▲	
▲	
▲	
▲	

ELECTRICAL

FILE NAME: 2366A2-0


SHEET

E-502



ONE—LINE DIAGRAM

NOT TO SCALE



GENERAL NOTES APPLICABLE TO THIS DETAIL:

- THIS DETAIL IS DIAGRAMMATIC IN NATURE AND IS NOT INTENDED TO INDICATE PROPOSED CIRCUIT ROUTING. PHASE CONDUCTORS AND RACEWAYS ARE NOT SHOWN FOR CLARITY. ALL RACEWAYS SHALL BE SECURELY BONDED TO THE ENCLOSURES THE RACEWAYS CONNECT.
- A GREEN EQUIPMENT GROUND CONDUCTOR IS REQUIRED FOR EVERY APPLIANCE BRANCH CIRCUIT, EVERY GENERAL-PURPOSE BRANCH CIRCUIT, EVERY INDIVIDUAL BRANCH CIRCUIT, AND EVERY MULTI-WIRE BRANCH CIRCUIT. UNDER NO CIRCUMSTANCES WILL A METALLIC RACEWAY SYSTEM BE ACCEPTED AS THE SOLE MEANS OF EQUIPMENT GROUNDING.
- GROUND (NEUTRAL) CONDUCTORS ARE ONLY REQUIRED FOR 120V LOADS OR POLYPHASE LOADS THAT REQUIRE 120V POWER.
- WHEN INSTALLED PER THE CURRENT NATIONAL ELECTRICAL CODE REQUIREMENTS, AT LEAST TWO GROUND CONDUCTOR PATHS ARE REQUIRED; ONE FOR THE RECEPTACLE GROUND AND ONE FOR THE RECEPTACLE.

NOTES APPLICABLE TO THIS DETAIL:

- ONLY EQUIPMENT GROUNDING CONDUCTORS SHALL TERMINATE ON THIS EQUIPMENT GROUND BAR. UNDER NO CIRCUMSTANCES SHALL ANY ISOLATED GROUNDING OR GROUND (NEUTRAL) CONDUCTORS TERMINATE ON THIS BAR.
- ONLY GROUND (NEUTRAL) CONDUCTORS SHALL TERMINATE ON THIS NEUTRAL BAR. UNDER NO CIRCUMSTANCES SHALL ANY ISOLATED GROUNDING OR EQUIPMENT GROUNDING CONDUCTORS TERMINATE ON THIS BAR.
- ONLY ISOLATED GROUNDING CONDUCTORS SHALL TERMINATE ON THIS ISOLATED GROUND BAR. UNDER NO CIRCUMSTANCES SHALL ANY EQUIPMENT GROUNDING OR GROUND (NEUTRAL) CONDUCTORS TERMINATE ON THIS BAR.
- UNLESS INDICATED OTHERWISE, CIRCUITS SERVED BY THIS PANEL SHALL BE ROUTED IN DEDICATED RACEWAYS AND SHALL NOT BE COMBINED IN THE SAME RACEWAY WITH NON-ISOLATED GROUND CIRCUITS.
- ISOLATED GROUNDING CONDUCTOR IS PERMITTED TO PASS THROUGH PANELBOARDS BUT MUST TERMINATE AT THE SERVICE EQUIPMENT GROUNDING TERMINAL OR AT THE GROUNDING TERMINAL OF THE SEPARATELY DERIVED SYSTEM, IF APPLICABLE, UNLESS INDICATED OTHERWISE.

CONDUCTOR LEGEND

- GC— GROUND (NEUTRAL) CONDUCTOR
- EGC— EQUIPMENT GROUNDING CONDUCTOR
- IG— ISOLATED GROUNDING CONDUCTOR
- GEC— GROUNDING ELECTRODE CONDUCTOR

ISOLATED GROUND SYSTEM DETAIL

NOT TO SCALE

- C. Provide nameplate for each controller indicating room(s) controlled.
D. Install room controller wall-mounted switches 46 inches above finished floor to the centerline of the box unless indicated otherwise.
- 3.08 CLOSETOUT
A. Demonstrate proper operation of lighting control devices to the Owner and correct deficiencies or make adjustments as directed.
B. Train Owner's personnel on operation, adjustment, programming, and maintenance of lighting control devices.
C. Provide a written report of all program settings and photosensor settings to the Owner.

END OF SECTION

SECTION 262416 - PANELBOARDS

PART 1 GENERAL - NOT USED

PART 2 PRODUCTS

- 2.01 LIGHTING AND APPLIANCE PANELBOARDS
A. Description: Square D Type NQ for 240 Volt Class and Square D Type NF for 600 Volt Class unless Production Notes indicate otherwise.
B. Voltage, Phase, and Current Ratings: As indicated or otherwise required.
C. Short-Circuit Current Rating (SCCR): No less than the available fault current. The Contractor shall determine the available fault current where not indicated on the Drawings.
D. Bussing: As indicated or otherwise required.
E. Bonded Equipment Ground Bar: Provide for each panelboard.
F. Isolated Ground Bar: Provide for each panelboard that serves isolated ground loads.
G. Enclosures: Manufacturer's standard enclosure suitable for the environment in which the panelboard is installed; 5/8 inch deep, 20 inches wide unless indicated otherwise; surface or flush mounted as indicated.
H. Cabinet Front: Surface or flush type as indicated with hinged door, flush lock, metal directory frame and finish as manufacturer's standard enamel.
I. Circuit Breakers:
1. Built-in thermal-magnetic molded case circuit breakers with common trip handle for all poles.
a. Provide type SWD for lighting circuits.
b. Provide Type HACR for heating, air-conditioning, and refrigeration equipment circuits.
c. Provide Class A ground-fault circuit interrupter (GFCI) where indicated or otherwise required.
d. Provide ground-fault protection of equipment (GFPE) where serving feed trunks or otherwise required.
e. Provide combination type arc-fault circuit interrupter (AFCI) where indicated or otherwise required.
f. Provide dual-rated combination type arc-fault circuit interrupter (AFCI) and Class A ground-fault circuit interrupter (GFCI) where indicated or otherwise required.
2. Accessories:
a. Provide handle ties for circuit breakers serving multiple branch circuits.
b. Provide Square D #BL01 handle dampers for circuit breakers denoted as "ILO" and for all fire protection and fire alarm equipment and all circuits serving emergency lighting.
c. Provide Square D #DXY-DV-WI power interface unless indicated otherwise.
d. Provide dual-rated combination type arc-fault circuit interrupter (AFCI) and Class A ground-fault circuit interrupter (GFCI) where indicated or otherwise required.
3. Amp Interrupting Current (AIC) Rating: No less than the available fault current; fully rated series combination.
4. The Contractor shall determine the available fault current where not indicated on the Drawings.
5. Do not use multi-pole circuit breakers that mount in a 1-pole circuit breaker space (i.e. half-size circuit breakers).

PART 3 EXECUTION

- 3.01 INSTALLATION
A. Install panelboards 6 feet to top of panelboard but no less than 4 inches above floor.
B. Provide 4 inch thick concrete housekeeping pad for surface-mounted panelboards installed within 4 inches of the floor.
C. Provide fire fillets for unused spaces in panelboards.
D. Provide typed circuit directory and nameplate for each panelboard. Revise directory to reflect circulating changes required to balance phase loads.
E. Provide five 1 inch square conduit for each panelboard to install panelboard to an accessible location above ceiling. Identify each as SPARE.
F. Measure steady state load currents of each panelboard feeder and rearrange circuits as required to balance the phase loads to within 10 percent maximum imbalance. Maintain proper phasing for multiwire branch circuits.
G. Provide nameplate indicating panelboard equipment designation for each panelboard.

3.02 ADDITIONAL INSTALLATION REQUIREMENTS FOR REMOTE CONTROLLED CIRCUIT BREAKER PANELBOARDS

- A. Hold meeting with the Owner.
B. Coordinate and make adjustments requested by the Owner.
C. Determine all timeslot settings such as ON and OFF times for each day of the week, holiday settings, latitude and longitude of the project site for astronomical features, etc.
D. Determine all control settings such as on and off triggers, blink settings, sweep settings, etc.
E. Provide all control wiring and communications cabling, whether or not shown on the Drawings, per manufacturer's recommendations and as required for a complete and operational system.
F. Program the entire system as established in meeting with the Owner.
G. Demonstrate proper operation of remote controlled circuit breaker panelboard control system to the Owner and correct deficiencies or make adjustments as directed.
H. Train Owner's personnel on operation, adjustment, programming, and maintenance of remote controlled circuit breaker panelboard control system.
I. Provide a written report of all remote controlled circuit breaker panelboard control system program settings to the Owner.

END OF SECTION

SECTION 262701 - ELECTRICAL SERVICE ENTRANCE

PART 1 GENERAL

- 1.01 PRE-INSTALLATION MEETING: Converse with utility company one month prior to commencing work to review and coordinate all requirements and details.

PART 2 PRODUCTS

- 2.01 INSTRUMENT TRANSFORMER CABINET: Steel metal cabinet with hinged door, provisions for locking and sealing, and conforming to all utility company requirements; size as required by utility company.
2.02 METER SOCKET: Furnished by utility company or the Electrical Contractor as specified by the utility company.
2.03 UTILITY TRANSFORMER PAD: Prefabricated precast concrete or cast-in-place transformer pad sized as required by the utility company. Construct in strict conformance with the utility company standards.
2.04 OTHER COMPONENTS: Provide all conduits, boxes, accessories, and components as required by utility company for a complete, functional, and safe installation.

END OF SECTION

SECTION 262711 - EQUIPMENT WIRING

PART 1 GENERAL

- 1.01 COORDINATION WITH OTHER TRADES
A. Meet with all other trades before commencing any work and obtain and review shop drawings, product data, manufacturer's wiring diagrams, and manufacturer's instructions for equipment furnished under other Sections.
1. Determine all equipment connection locations, equipment requirements, and verify that proper power supply is available prior to subcontractor's ordering equipment.
2. Sequence rough-in of electrical connections to coordinate with installation of equipment.
3. Sequence electrical connections to coordinate with start-up of equipment.
B. Verify and coordinate all requirements and installation details of all materials and equipment prior to rough-in.
C. Verify proper voltage, phase, and current rating of power supply and immediately report any discrepancies to the Owner.
D. Responsibility for verification of proper power supply voltage and any damage resulting from incorrect connections shall rest with this Contractor.
E. Any conflicts arising from lack of coordination shall be this Contractor's responsibility.

PART 2 PRODUCTS

- 2.01 CORDS
A. Description: Multi-conductor flexible cord Type SO for dry and damp locations or Type SOW in wet locations.
B. Conductor Quantity: As required for the load served; include identified equipment grounding conductor.
C. Conductor Insulation Rating: As required for the voltage of the load served.
D. Conductor Ampacity: No less than the rating of the overcurrent protection device protecting the circuit.
2.02 CORD CAPS: Match cord cap to receptacle configuration at outlet provided for equipment.
2.03 OTHER MATERIALS: Provide all disconnect switches, wiring devices, conduit, wire and cable, and boxes required.

PART 3 EXECUTION

- 3.01 ELECTRICAL CONNECTIONS
A. Make electrical connections in accordance with equipment manufacturer's instructions.
B. Make conduit connections to equipment using flexible conduit. Use equipment flexible conduit with weather-tight connections in damp or wet locations.
C. Connect rated producing equipment using wire and cable with insulation suitable for temperature encountered.
D. Provide receptacle outlet to accommodate connection with attachment plug.
E. Provide cord and cap where field-mounted attachment plug is required.
F. Install outlet strain-relief dampers and fittings for cord connections at outlet boxes and equipment connection boxes.
G. Install disconnect switches, controllers, control stations, and control devices to complete equipment wiring requirements.
H. Install terminal block lumps to complete equipment wiring requirements.
I. Install interconnecting conduit and wiring between devices and equipment to complete equipment wiring requirements.
J. Cut and seal conduit openings in freezer and cooler walls, floors, and ceilings where applicable.

END OF SECTION

SECTION 262728 - WIRING DEVICES

PART 1 GENERAL

- 1.01 PREPARATION: Contact the Architect to determine colors of all wiring devices, cover plates, and carpet and tile flanges, locations where stainless steel cover plates are required, and locations where carpet and tile flanges are required.

PART 2 PRODUCTS

- 2.01 RECEPTACLES
A. Receptacles:
1. Color as selected by Architect.
2. Provide tamper-resistant receptacles where denoted "TR" on the Drawings and otherwise required.
3. Provide ground-fault circuit interrupter receptacles where denoted "GFCI" on the Drawings and otherwise required.
4. Provide receptacles with controlled receptacle marking where denoted "CR" on the Drawings and where controlled by automatic shutoff controls.
5. Provide identified weather-resistant receptacles for receptacles installed outdoors.
6. NEMA 5-15R unless indicated otherwise.
B. Standard NEMA 5-20R Duplex: Hubbell #3632 unless indicated otherwise.
C. Standard NEMA 5-20R Duplex: Hubbell #3632 unless indicated otherwise.
D. Interior GFCI Duplex: Hubbell #2720 unless indicated otherwise.
E. Exterior GFCI Duplex: Hubbell #2720 unless indicated otherwise.
F. Isolated Ground Duplex: Hubbell #RCR352 unless indicated otherwise.
G. Surge Protection: Hubbell #RBL5235 unless indicated otherwise.
H. Clock Hanger Receptacles: Hubbell #RBL5235 unless indicated otherwise.
I. Other NEMA Configurations: As required by the load served.
2.02 FACELESS GFCI: Hubbell #RFP220 power as selected by Architect.
2.03 MULTI-OUTLET ASSEMBLY: Wemrod Plungemold 2000 Series with receptacles at 6 inches on center. Provide all fittings required for a complete and functional installation. Coordinate device and channel finish color with the Architect.

2.04 WALL SWITCHES

- A. All Switches:
1. Color as selected by Architect.
2. Horsepower rated when used as motor disconnecting means.
B. Single Pole Toggle: Hubbell #1221 unless indicated otherwise.
C. Three-Way Toggle: Hubbell #1223 unless indicated otherwise.
D. Four-Way Toggle: Hubbell #1224 unless indicated otherwise.
E. Single Pole Toggle with Pilot Light: Hubbell #RBL1221FLC unless indicated otherwise.
F. Single Pole Keyed: Hubbell #RBL1221 unless indicated otherwise.
G. Three-Way Keyed: Hubbell #RBL1223 unless indicated otherwise.
H. Four-Way Keyed: Hubbell #RBL1224 unless indicated otherwise.
2.05 WALLBOX DIMMERS: Color as selected by Architect.

- B. Inconducant Dimmers:
1. Up to 600 Watts: Lutron Maestro #MAF-600 unless indicated otherwise.
2. Between 600 and 1200 Watts: Lutron Maestro #MAF-1200 unless indicated otherwise.
3. 277 Volt, Up to 6 Amps: Lutron Maestro #MAF-277 unless indicated otherwise.
4. 277 Volt, Between 6 and 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
5. Fluorescent 0-10 Volt Dimmers:
a. Up to 120 Watts: Lutron Maestro #MAF-6AM unless indicated otherwise.
b. Between 6 and 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
6. 277 Volt, Up to 6 Amps: Lutron Maestro #MAF-277 unless indicated otherwise.
7. 277 Volt, Between 6 and 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
8. Fluorescent 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. Between 600 and 1200 Watts: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
c. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with Lutron #PMPH-WBX-DV-WI power interface unless indicated otherwise.
b. LED Dimmers:
1. All LED Dimmers: Dimmer utilized shall be tested and listed by the LED manufacturer as a compatible dimmer.
2. 0-10 Volt Dimmers:
a. Up to 16 Amps: Lutron Maestro #MAF-6AM with

3.05 INSTALLATION OF CROSS-CONNECTION EQUIPMENT

- A. Only if required pursuant to meeting with the Owner:
1. Install connector blocks at hoods as directed by the Owner.
 2. Install patch panels in equipment racks as directed by the Owner.
 3. Install labels complying with TIA/EIA-598 using coded identifiers:
 - a. Patch Panels: Label each jack with a unique numerical identifier as to its type and function.
 - b. Patch Cords: Label with jack identifier corresponding to initial installation.

END OF SECTION

SECTION 283100 – FIRE DETECTION AND ALARM

PART 1 GENERAL

1.01 ADMINISTRATIVE

- A. The word "should" used in NFPA 72 shall be considered a mandatory requirement.

1.02 PREPARATION

- A. Examine the plans of all trades to determine scope of fire alarm and detection work including, but not limited to:
1. Architectural plans to determine occupancy classification, occupant loads, and locations where voice alarm will be required.
 2. Fire sprinkler plans, including fire sprinkler plans that are designed by others, to determine locations of all flow switches, tamper switches, post indicator valves, corrosion monitoring probes, dry-type system compressors, and fire pumps.
 3. Mechanical plans to determine locations of all individual HVAC units rated equal to or greater than 2,000 cubic feet per minute (CFM), locations of HVAC units serving the same room or area where the total aggregate capacity of the units is equal to or greater than 2,000 cubic feet per minute (CFM), locations of HVAC units sharing a common return or plenum where the total aggregate capacity of the units is equal to or greater than 2,000 cubic feet per minute (CFM), smoke dampers, smoke exhaust equipment, and Type 1 grease hood fire suppression systems.

- B. Coordinate all notification appliance colors with the Architect.

1.03 SYSTEM DESIGN

- A. Provide a fully engineered Code-compliant design of the fire detection and alarm system from a Fire Alarm Designer.
- B. The Fire Alarm Designer shall be a NICET Level III or IV (3 or 4) certified fire alarm technician, registered fire protection engineer, employee of the fire alarm control unit manufacturer, or Contractor with experience designing fire detection and alarm systems in the jurisdictional area.
- C. The Fire Alarm Designer shall develop all fire detection and alarm plans, riser diagrams, calculations, and equipment submittal packages required by NFPA 72–2013 section 7.6. The Fire Alarm Designer shall review and submit the same as a deferred permit.
- D. The General Contractor shall include all costs associated with the development of the fully engineered fire detection and alarm plans and permit fees in the BID.
- E. Any fire detection and alarm information indicated on the Drawings is strictly for the purpose of establishing a minimum criteria to aid the Fire Alarm Designer in the design of the fully engineered fire alarm drawings. The Fire Alarm Designer is responsible to provide a design that is fully compliant with all applicable Codes and Jurisdictional requirements.

PART 2 PRODUCTS

2.01 GENERAL

- A. All new fire alarm initiation devices, including new initiation devices added to existing systems, shall be of the same manufacturer as the control unit and fully compatible with the system.

2.02 NEW FIRE ALARM AND DETECTION SYSTEMS

- A. Fire Detection and Alarm System:
1. Control Unit: Notifier #NFV2–100 unless indicated otherwise.
 2. Communicator: Digital Alarm Communicator Transmitter (DACT) connected to central station.
 3. Secondary Power: Storage battery and battery charger capable of operating entire system for period of time specified by NFPA 72 plus 25 percent spare capacity.40. Auxiliary Battery Cabinet: As required for the batteries installed within.
 5. Relay Module: As required for a complete operational system.
 6. Remote Annunciator: Notifier #R–ANN–80–W unless indicated otherwise; provide when control unit is located at a location other than the First Responder's primary point of entry.
- B. Voice Alarm System:
1. Control Unit: Notifier #NFC–50–100 unless indicated otherwise.
 2. Secondary Power: Storage battery and battery charger capable of operating entire system for period of time specified by NFPA 72 plus 25 percent spare capacity.
 3. Auxiliary Battery Cabinet: As required for the batteries installed within.
 4. Audio Amplifier Modules: As required for speakers served.

2.03 INITIATING DEVICES

- A. Smoke Detectors:
1. Detector: Notifier #NP–100 unless indicated otherwise.
 2. Base: Notifier #B21DLP unless indicated otherwise; provide Notifier #B224RB relay base when smoke detector is used for door releasing service.
- B. Duct Smoke Detectors:
1. General:
 - a. Provide for each HVAC unit rated equal to or greater than 2,000 cubic feet per minute.
 - b. Provide for all HVAC units serving the same room or area where the total aggregate capacity of the units is equal to or greater than 2,000 cubic feet per minute.
 - c. Provide for all HVAC units that share a common return air plenum where the total aggregate capacity of the units is equal to or greater than 2,000 cubic feet per minute.
 - d. Provide as required for control of each smoke damper.
 2. Detector: Notifier #NP–100R base unless indicated otherwise.
 3. Housing: Notifier #NHR unless indicated otherwise.
 4. Sampling Tube: As required for the duct.
 5. Remote Test Stations: Notifier #RTSDIRKEY unless indicated otherwise; provide when duct smoke detector is installed in a concealed location greater than 10 feet above finished floor or when duct smoke detector's status indicators are not readily visible.
 6. Remote Alarm LED Annunciators: Notifier #RA100A unless indicated otherwise; provide for each duct smoke detector that is not connected to a fire alarm control unit.
- C. Heat Detectors:
1. Detector: Notifier #NH–100R unless indicated otherwise.
 2. Base: Notifier #B21DLP unless indicated otherwise; provide Notifier #B224RB relay base when heat detector is used for elevator shunt trip.
- D. Manual Pull Stations: Notifier #NOT–BG12LX unless indicated otherwise; semi-flush mounted in all finished areas and surface mounted with #S8–10 backbox in unfinished areas.

2.04 NOTIFICATION APPLIANCES

- A. General:
1. All notification appliances shall be from the same manufacturer.
 2. All notification appliances shall be semi-flush mounted in all finished areas; notification appliances are permitted to be surface mounted in unfinished areas.
 3. All notification appliance housings shall be white unless indicated otherwise or unless the Authority Having Jurisdiction requires red housings.
 4. Provide strobe synchronization modules when more than one strobe is located within a viewing area.
- B. Horns: System Sensor #HW unless indicated otherwise.
- C. Strobes: System Sensor #SW for wall-mount and #SCW for ceiling-mount unless indicated otherwise.
- D. Combination Horn/Strobes: System Sensor #P2W for wall-mount and #PC2W for ceiling-mount unless indicated otherwise.
- E. Speakers: System Sensor #SPW for wall-mount and #SPCW for ceiling-mount unless indicated otherwise.
- F. Combination Speaker/Strobes: System Sensor #SPSW for wall-mount and #SPSCW for ceiling-mount unless indicated otherwise.
- G. Exterior Combination Speaker/Strobes: System Sensor #P2RK unless indicated otherwise.

2.05 AUXILIARY DEVICES

- A. Addressable Monitor Modules: As required for a complete operational system.
- B. Addressable Control Modules: As required for a complete operational system.
- C. Addressable Relay Modules: As required for a complete operational system.
- D. Door Holders: Notifier D424120 series with 24 volt coil and 40 pounds of holding force unless indicated otherwise; coordinate selection of door holders with architectural hardware requirements and verify required clearances, sizes and locations to operate properly with the doors and hardware specified.
- E. Notification Appliance Circuit Power Supplies: As required for a complete operational system.
- F. End-of-Line Resistors: As recommended by the manufacturer.
- G. Bypasses: Provide for any wall-mounted notification appliances located in garages or where otherwise exposed to physical damage.
- A. Kidde #120105CO unless indicated otherwise; for use within individual dwelling units only.

2.06 COMBINATION SMOKE/CARBON MONOXIDE ALARMS

- A. Kidde #120105CO unless indicated otherwise; for use within individual dwelling units only.

2.07 CONDUIT: See section 280534; painted red.

2.08 RIGGS: See section 280537; painted red.

2.09 WIRE AND CABLE

- A. All Wire and Cable:
1. Riser Cabling: Unshielded Type FPLR when installed in conduit and Type FPLP when not installed in conduit unless indicated otherwise or otherwise required; red jacket.
 2. Horizontal Cabling: Unshielded Type FPL when installed in conduit and Type FPLP when not installed in conduit unless indicated otherwise or otherwise required; red jacket.
- B. Initiating Device Circuits (IDC):
1. Number of Conductors: As recommended by the manufacturer.
 2. Conductor Size: As recommended by the manufacturer but not smaller than 18 AWG.
- C. Signaling Line Circuits (SLC):
1. Number of Conductors: As recommended by the manufacturer.
 2. Conductor Size: As recommended by the manufacturer but not smaller than 18 AWG.
- D. Notification Appliance Circuits (NAC):
1. Number of Conductors: As recommended by the manufacturer.
 2. Conductor Size: As recommended by the manufacturer but not smaller than 14 AWG.

PART 3 EXECUTION

3.01 COORDINATION WITH OTHER TRADES

- A. Coordinate all fire alarm work with all other trades including, but not limited to:
1. Connection of all fire sprinkler monitoring components including all flow switches, tamper switches, post indicator valves, corrosion monitoring probes, dry-type system compressors, and fire pumps with the Fire Sprinkler Contractor.
 2. Connection of all individual HVAC units rated equal to or greater than 2,000 cubic feet per minute (CFM), locations of HVAC units serving the same room or area where the total aggregate capacity of the units is equal to or greater than 2,000 cubic feet per minute (CFM), locations of HVAC units sharing a common return or plenum where the total aggregate capacity of the units is equal to or greater than 2,000 cubic feet per minute (CFM), smoke dampers, smoke exhaust equipment, and Type 1 grease hood fire suppression systems with the Mechanical Contractor.
 3. Connection of all elevator controllers and elevator recall systems with the Vertical Transportation Contractor.

4. Locations where boxes and/or conduit are to be roughed-in for initiating devices and/or notification appliances and locations where 120 volt power is required with the Electrical Contractor.
5. Change orders arising from a lack of coordination with the other trades will not be considered.

3.02 INSTALLATION

- A. Install all components in accordance with all applicable codes including, NFPA 70, NFPA 72, and the applicable Fire and Building Codes.
- B. Install all products in strict accordance with manufacturer's instructions. Obtain Owner's approval of locations of all components prior to rough-in.
- C. Install components at the following mounting heights:
1. Control Units: Top of 72 inches above finished floor.
 2. Remote Annunciators: Top of 60 inches above finished floor.
 3. Manual Pull Stations: Centerline of 46 inches above finished floor.
 4. Audible Notification Appliances: Top of 80 inches above finished floor or 6 inches below finished ceiling, whichever is lower.
 5. Visible Notification Appliances: Top of 85 inches above finished floor or 6 inches below finished ceiling, whichever is lower.
 6. Combination Audible/Visual Notification Appliances: Top of 85 inches above finished floor or 6 inches below finished ceiling, whichever is lower.
- E. Make conduit and wiring connections to all initiating devices, notification appliances, control units, fire sprinkler system components, HVAC system components, smoke control system components, vertical transportation components, grease hood fire suppression system components, monitor modules, control modules, relay modules, etc. for a complete fully functional system. Install outlet boxes for door holders to withstand 80 pounds of pulling force.
- G. Install control relays within 3 feet of the controlled equipment.
- H. Install duct smoke detector remote test stations and/or remote alarm LED annunciators; coordinate locations with the Owner and the Authority Having Jurisdiction prior to rough-in.
- I. Install end-of-line resistor in box with last device or separate box adjacent to last device in circuit.
- J. Conceal all wiring, conduit, boxes, and supports where located within finished areas.
- K. Install all concealed, inaccessible wiring, including wiring installed in walls, and all exposed wiring in conduit in accordance with NFPA 70.
1. Wiring may be installed without conduit where accessible and not subject to damage only when specifically permitted by the Authority Having Jurisdiction.
- L. Plenum rated cable may be used only where concealed above accessible tile ceilings or accessible shafts.
- M. Separate cables from any open conductors of Class 1 circuits and do not place in any conduit, junction box, or raceway containing Class 1 cables. Provide the following circuit classes:
1. Initiating Device Circuits (IDC): Class B.
 2. Signaling Line Circuits (SLC) Within Building: Class B.
 3. Signaling Line Circuits (SLC) Between Buildings: Class A.
 4. Notification Appliance Circuits (NAC): Class B.
 5. Door Holders: Class D.
- O. Provide a minimum of 25 percent spare capacity on all circuits.
- P. Connect control unit to a separate dedicated branch circuit with a separate, dedicated circuit breaker with lock-on accessory and label circuit as FIRE ALARM.
- Q. Connect any 120 volt exterior fire sprinkler alarm bells to the same circuit serving the control unit.
- R. Install instruction cards and labels; provide legible, permanent labels for each control device, using identification used in operation and maintenance data.

3.03 FIRE SAFETY SYSTEMS INTERFACES

- A. Provide the following fire safety system interfaces upon activation. Coordinate all components requiring interface, including exact locations, with the associated Contractor. Change orders arising from a lack of coordination with the other trades will not be considered.
1. General:
 - a. Manual Pull Stations: Transmit alarm signal to control unit.
 - b. Smoke Detectors: Transmit alarm signal to control unit.
 - c. Heat Detectors: Transmit alarm signal to control unit.
 2. Fire Sprinkler Systems:
 - a. Flow Switches: Transmit alarm signal to control unit.
 - b. Tamper Switches: Transmit supervisory signal to control unit.
 - c. Post Indicator Valves: Transmit supervisory signal to control unit.
 - d. Corrosion Monitoring Probes: Transmit supervisory signal to control unit.
 - e. Pressure Monitoring Systems: Transmit supervisory signal to control unit.
 - f. Fire Pumps: Transmit supervisory signal to control unit per NFPA 20 and NFPA 72.
 3. HVAC System Duct Smoke Detectors:
 - a. Shut down supply fan on each individual unit rated equal to or greater than 2,000 cubic feet per minute.
 - b. Shut down all supply fans on all units that share a common return or plenum where the total aggregate capacity of the units is equal to or greater than 2,000 cubic feet per minute.
 - c. Shut down all supply fans on all units that serve a common room or area where the total aggregate capacity of the units is equal to or greater than 2,000 cubic feet per minute.
 - d. Close smoke dampers.
 - e. Transmit alarm or supervisory signal to control unit; coordinate required signal type with the Authority Having Jurisdiction.
 4. Grease Hood Fire Suppression System:
 - a. Disconnect power to all appliances located under hood.
 - b. Close gas valve(s) serving appliances located under hood.
 - c. Shut down all supply air fan(s).
 - d. Start hood exhaust fan(s) if not already running.
 - e. Transmit alarm signal to control unit.
 5. Smoke Exhaust:
 - a. Shut down all supply air fan(s).
 - b. Start smoke exhaust fan(s).
 - c. Transmit alarm signal to control unit.
 6. Smoke Barrier Door Holders:
 - a. Release upon activation of smoke detectors on either side of door.
 - b. Release upon activation of manual pull station on the same floor.
 - c. Release upon activation of fire sprinkler flow switch.
 7. Electromagnetic Locks on Egress Doors: Release upon any alarm signal.
 8. Vertical Transportation:
 - a. Elevator Shutdown Control Circuits: Transmit supervisory signal to control unit.
 - b. Smoke Detectors in Elevator Lobbies, Machine Rooms, and Hoistways:
 1. Activate elevator recall.
 2. Transmit alarm signal to control unit.
 - c. Heat Detectors in Elevator Machine Rooms and Hoistways:
 1. Shunt trip elevator controller prior to machine room and hoistway fire sprinkler activation.
 2. Transmit alarm signal to control unit.
 9. Fire Alarm Wiring:
 - a. Open Circuit: Transmit trouble signal to control unit.
 - b. Single Ground: Transmit trouble signal to control unit.
 - c. Short Circuit: Transmit trouble signal to control unit.

3.04 SEQUENCE OF OPERATION

- A. Alarm:
1. Visual and audible alarm at control unit.
 2. Visual and audible alarm at remote annunciator.
 3. Transmit alarm signal to central station.
 4. Activate visual notification appliances.
 5. Activate audible notification appliances.
 6. Transmit signal to building mechanical systems to initiate supply air fan shut down.
 7. Transmit signal to building mechanical systems to close smoke damper(s).
 8. Transmit signal to building mechanical system to grease hood exhaust fan(s).
 9. Transmit signal to building mechanical system to start smoke exhaust fan(s).
 10. Transmit signal to elevator controllers to initiate elevator recall.
- B. Supervisory:
1. Visual and audible alarm at control unit.
 2. Visual and audible alarm at remote annunciator.
 3. Transmit supervisory signal to central station.
- C. Trouble:
1. Visual and audible alarm at control unit.
 2. Visual and audible alarm at remote annunciator.
 3. Transmit trouble signal to central station.
 4. Manual acknowledge silence audible trouble alarm at control unit and remote annunciator but visual alarm remains displayed until trouble condition is cleared.

3.05 INSPECTION, TESTING, AND ADJUSTMENT


- A. Complete NFPA 72 "RECORD OF COMPLETION" form.
- B. Notify the Authority Having Jurisdiction and comply with their requirements for scheduling inspections and tests and for observation by their personnel.
- C. Perform inspection and testing in accordance with NFPA 72 and requirements of the Authority Having Jurisdiction.
- D. Document each inspection and test, correct any defective work, and retest until entire system complies with the requirements of NFPA 72, the Authority Having Jurisdiction, and the Contract Documents.

3.06 PERSONNEL INSTRUCTION

- A. Provide hands-on instruction for the Owner's designated representative.
- B. Provide the services of instructors, teaching aids, and copies of operation and maintenance data during instruction.

3.07 CLOSEOUT

- A. Substantial Completion: Substantial Completion cannot be achieved until inspection and testing is successful, all aspects of operation have been demonstrated to Owner, final acceptance of the fire alarm system has been given by the Authority Having Jurisdiction, the occupancy permit has been issued, and the personnel instruction is complete.
- B. Demonstration: Demonstrate proper operation of all functions to Owner. Demonstration may be combined with inspection and testing required by the Authority Having Jurisdiction.
- C. Closeout Documentation and Materials:
1. Provide the following closeout documentation and materials to the Owner:
 - a. Manufacturer's cut sheets, owner's manual, manufacturer's published instructions, and troubleshooting guides covering all system equipment.
 - b. Detailed but easy to read explanation of procedures to be used by non-technical personnel in the event of system trouble, when routine testing is being conducted, and for fire drills.
 - c. Record drawings complying with NFPA 72–2013 section 7.5.5.
 - d. NFPA 72–2013 "RECORD OF COMPLETION" form.
 - e. NFPA 72–2013 "SYSTEM RECORD OF INSPECTION AND TESTING" form.
 - f. Preventive maintenance schedule.
 - g. Testing and inspection procedures and schedule.
 2. All closeout documentation shall be neatly organized in a three-ring binder with labeled dividers separating sections.
- D. MAINTENANCE CONTRACT
- A. Provide, as an alternate to the base bid for later acceptance by the Owner, a proposal for a two-year maintenance contract that includes:
1. Services to perform routine inspection, testing, and preventive maintenance required by NFPA 72, including maintenance of fire safety interface and supervisory devices connected to fire alarm system, and repairs required.
 2. Record keeping required by NFPA 72 and the Authority Having Jurisdiction.



PAUL DHANENS • ARCHITECT

ARCHITECT



5700 CALIFORNIA AVE., SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (805) 326-8335
FACSIMILE: (805) 326-8037

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT® expressly reserves its copyright and other property rights in these documents and shall not be reproduced, changed or copied in any written, electronic or mechanical form, including photocopying, recording, or by any information storage and retrieval system, without the prior written consent of PAUL DHANENS ARCHITECT®.

NOTICE TO CONTRACTORS
Within 10 business days of the date of this agreement, the Contractor shall submit a written statement of the Contractor's proposed schedule of completion, including all dimensions and shall notify the architect of any discrepancies or any responsibilities for field variations discovered.

PROJECT

TENANT IMPROVEMENT FOR




1966 WEST AVE L
LANCASTER, CA

DATE ISSUED FOR

8-24-18 BUILDING DEPT SUBMITTAL

8-28-18

NO. REVISIONS



ELECTRICAL



FILE NAME: 2366A2-0

SHEET

E-603


- GENERAL NOTES:
- EXISTING CONDITIONS ARE BASED ON RECORD DRAWINGS PROVIDED BY THE OWNER. CONTRACTOR SHALL ADJUST TO ACTUAL FIELD CONDITIONS AT NO ADDITIONAL EXPENSE TO THE PROJECT.
 - CONTRACTOR SHALL BE RESPONSIBLE FOR FIELD VERIFICATION OF ALL EXISTING CONDITIONS PRIOR TO SUBMITTING HIS BID. NO ADDITIONAL COMPENSATION WILL BE PROVIDED FOR ANY EXTRAS DUE TO THE CONTRACTOR'S FAILURE TO VISIT THE PROJECT SITE PRIOR TO SUBMITTING THE BID. ANY DISCREPANCIES SHALL BE IMMEDIATELY REPORTED TO THE ENGINEER FOR RESOLUTION.
 - ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH ALL APPLICABLE GOVERNMENT AND LOCAL CODES.
 - MECHANICAL CONTRACTOR SHALL FIELD COORDINATE WITH ELECTRICAL CONTRACTOR FOR ALL POWER REQUIREMENTS.
 - ALL CONTRACTORS SHALL REVIEW A COMPLETE SET OF CONSTRUCTION DOCUMENTS AND COOPERATE WITH THE OTHER TRADES SO THAT THE INSTALLATION OF ALL EQUIPMENT MAY BE PROPERLY COORDINATED.
 - ALL EQUIPMENT FURNISHED SHALL FIT THE SPACE AVAILABLE WITH CONNECTIONS IN THE REQUIRED LOCATIONS AND WITH ADEQUATE SPACE FOR OPERATING AND SERVICING. THE DRAWINGS ARE GENERALLY DIAGRAMMATIC AND INDICATE THE INTENT OF THE INSTALLATION WHILE THE SPECIFICATIONS AND EQUIPMENT LIST DENOTE THE TYPE AND QUALITY OF MATERIAL AND WORKMANSHIP TO BE USED. THE DRAWINGS SHALL NOT BE SCALED FOR EXACT MEASUREMENTS. WHERE A CONFLICT EXISTS BETWEEN THE DRAWINGS AND THE SPECIFICATIONS, THE HIGHER AND/OR MORE COSTLY STANDARD WILL APPLY. THE CONTRACTOR SHALL PROMPTLY NOTIFY THE ENGINEER WHOSE DECISION SHALL BE FINAL. NO ALLOWANCE WILL BE MADE SUBSEQUENTLY IN THIS REGARD ON BEHALF OF THE CONTRACTOR AFTER AWARD OF THE CONTRACT.
 - COORDINATE DUCT ROUTING AND HEIGHTS WITH GENERAL CONTRACTOR. VERIFY ALL CLEARANCES BEFORE STARTING WORK.
 - THE CONTRACTOR SHALL INSTALL ALL PIPING, DUCTWORK AND EQUIPMENT AS REQUIRED TO CONFORM TO THE STRUCTURE, AVOID OBSTRUCTIONS, PRESERVE CEILING HEIGHTS AND HEADROOM AND MAKE ALL EQUIPMENT REQUIRING MAINTENANCE OR REPAIR ACCESSIBLE.
 - ALL DUCT CONNECTIONS TO HVAC EQUIPMENT MUST BE MADE WITH FLEXIBLE CONNECTORS.
 - DO NOT ATTACH ANYTHING TO DECK ABOVE. ATTACH TO STRUCTURE (i.e. BEAMS, JOISTS) ONLY. DUCT HANGERS SHALL BE INSTALLED IN ACCORDANCE WITH LOCAL CODE. ALL CONNECTIONS TO JOISTS SHALL BE MADE AT THE TOP CORN.
 - ALL DUCT DIMENSIONS INDICATED ARE CLEAR INSIDE DIMENSIONS. ALL SUPPLY AND UNTEMPERED OUTDOOR AIR DUCTWORK SHALL BE LINED WITH 1-1/2" ACOUSTICAL DUCT LINER OR WRAPPED WITH 2" THICK FIRE RETARDANT FIBERGLASS WITH A REINFORCED ALUMINUM FOIL JACKET AND SHALL BE APPROVED FOR USE BY SAAONA AND NAMA. RETURN AIR TRANSFER DUCTS AND RETURN DUCTWORK WITHIN 10 FEET OF THE UNIT FAN SHALL BE LINED WITH 1" ACOUSTICAL DUCT LINER.
 - EXPOSED SPIRAL DUCT TO BE GALVANIZED FINISH, FREE FROM SCRATCHES, DENTS OR BLEMISHES AND PAINTED TO MATCH THE SURROUNDING AREA. DUCT SHALL BE INTERNALLY LINED AND SEALED WITH DUCT SEALER COMPLETELY CONCEALED WITHIN THE DUCT JOINT. NO EXPOSED SEALER OR TAPE WILL BE ACCEPTED.
 - ALL EXPOSED DUCTWORK SHALL BE INSTALLED THRU JOIST SPACE.
 - PROVIDE REMOTE VOLUME DAMPER CONTROL MANUFACTURED BY YOUNG REGULATOR OR UNITED ENERTECH FOR DAMPERS LOCATED ABOVE INACCESSIBLE CEILINGS. LOCATE CONTROLLER ABOVE ACCESSIBLE CEILING LOCATION.
 - TENANT'S CONTRACTOR SHALL BE RESPONSIBLE FOR THE FIELD VERIFICATION OF ALL UTILITY RUNS AND/OR OTHER IMPROVEMENTS LOCATED ON THE PREMISES PRIOR TO BIDDING. TENANT'S CONTRACTOR SHALL ALSO BE RESPONSIBLE FOR ALL COSTS RELATING TO THE RELOCATION OF, DAMAGE TO, REPAIR OF ANY EXISTING UTILITY RUNS AND/OR IMPROVEMENTS WHICH ARE DAMAGED AS A RESULT OF TENANT'S WORK IN OR AROUND THE PREMISES.
 - ROOF MOUNTED EQUIPMENT SHALL BE LABELED WITH THE TENANT NAME AND SPACE NUMBER WITH 3" HIGH WEATHER PROOF LETTERS.
 - ALL GREASE EXHAUST DUCTWORK SHALL BE PROVIDED WITH 3" FOIL FACED THERMAL-CERAMIC INSULATION FOR GREASE DUCTS. INSULATION SHALL MEET NFPA 96 AND ASTM E 2336 REQUIREMENTS.
 - GREASE DUCT LEAKAGE TESTING MUST BE PERFORMED PRIOR TO CONCEALMENT OF THE DUCTWORK.
 - MECHANICAL CONTRACTOR SHALL PROVIDE TENANT WITH A WRITTEN ONE (1) YEAR MANUFACTURER'S WARRANTY ON ALL HVAC EQUIPMENT PROVIDED AND / OR INSTALLED. THE WARRANTY SHALL INCLUDE ALL LABOR, MATERIALS AND THREE (3) ROUTINE SERVICES INCLUDING FILTER CHANGES DURING A ONE (1) YEAR PERIOD.
 - AT THE COMPLETION OF CONSTRUCTION AN NEBB, AABC OR TABB CERTIFIED AIR BALANCE REPORT SHALL BE SUBMITTED TO THE ENGINEER AND LANDLORD. THE BALANCING MUST BE COMPLETED BY AN INDEPENDENT, THIRD PARTY CONTRACTOR WITH NO TIES TO THE INSTALLING CONTRACTORS.

- HVAC NOTES:
- CONTRACTOR SHALL UNDERCUT DOOR 3/4".
 - OPEN END RETURN AIR DUCT.
 - PROVIDE NEW FULLY DIGITAL 7 DAY PROGRAMMABLE TYPE THERMOSTAT WITH REMOTE SENSING CAPABILITIES, AUTO CHANGE OVER AND AUTO SET BACK AND HUMIDITY CONTROL. IF HUMIDITY CONTROL IS NOT AVAILABLE, PROVIDE SEPARATE HUMIDISTAT. MOUNT THERMOSTAT AT 48" ABOVE FINISHED FLOOR. COORDINATE LOCATION WITH WALL GRAPHICS LAYOUT. PROVIDE REMOTE TEMPERATURE SENSORS AS INDICATED ON PLAN.
 - DUCT SMOKE DETECTOR ON RETURN SIDE DUCT AND SHUTDOWN RELAY SHALL BE FURNISHED BY THE ELECTRICAL CONTRACTOR FOR INSTALLATION BY THE MECHANICAL CONTRACTOR. ALL WIRING SHALL BE BY THE ELECTRICAL CONTRACTOR.
 - INSTALL SUPPLY DUCTWORK TIGHT TO BOTTOM OF BEAM.
 - INSTALL SUPPLY DUCT BRANCHES WITHIN TRUSS SPACE, TYPICAL.
 - UP TO EF-1 ON ROOF. SEE ROOF PLAN FOR CONTINUATION.
 - UP TO EF-2 ON ROOF. SEE ROOF PLAN FOR CONTINUATION.
 - UP TO EF-3 ON ROOF. SEE ROOF PLAN FOR CONTINUATION.
 - PROVIDE VOLUME DAMPER AT EACH DROP TO HOOD AND BALANCE TO CFM INDICATED ON THE CAPTIVEARE HOOD DRAWINGS. DUCT SIZE SHALL MATCH HOOD CONNECTION SIZE. SEE SHEET H-101 FOR MORE INFORMATION.
 - CUSTOM FABRICATED TYPE 1 KITCHEN EXHAUST DUCT PROVIDED BY OWNER. INSTALLED BY MC UP TO EXHAUST FAN ON ROOF. COORDINATE WITH CAPTIVEARE DRAWINGS.
 - UP TO RTU-1 ON ROOF.
 - UP TO RTU-2 ON ROOF.
 - UP TO MUA-1 ON ROOF.
 - REMOTE HUMIDITY SENSOR MOUNTED AT 60" AFF FOR RTU-1.
 - REMOTE TEMPERATURE SENSOR MOUNTED AT 60" AFF FOR RTU-1.
 - REMOTE HUMIDITY SENSOR MOUNTED WITHIN RETURN DUCT FOR RTU-2. WIRE BACK TO THERMOSTAT AT MANAGER'S DESK.
 - REMOTE TEMPERATURE SENSOR MOUNTED WITHIN RETURN DUCT FOR RTU-2. WIRE BACK TO THERMOSTAT AT MANAGER'S DESK.
 - PROVIDE REMOTE VOLUME DAMPER CONTROL MANUFACTURED BY YOUNG REGULATOR OR UNITED ENERTECH FOR ALL DAMPERS LOCATED ABOVE INACCESSIBLE CEILINGS.
 - PROVIDE 26/14 PLENUM ABOVE RETURN GRILLES.



MECHANICAL PLAN

SYMBOLS	
SYMBOL	DESCRIPTION
	THERMOSTAT
	REMOTE SENSOR
	SUPPLY DIFFUSER
	RETURN OR EXHAUST GRILLE
	SUPPLY OR FRESH AIR DUCT (SA OR FA)
	RETURN OR EXHAUST AIR DUCT (RA OR EA)
	RECTANGULAR DUCT FIRST FIGURE IS SIDE SHOWN
	ROUND DUCT
	VOLUME DAMPER (ELEV AND PLAN)
	TURNING VANES
	SUPPLY REGISTER OR GRILLE (R OR G)
	RETURN REGISTER OR GRILLE (R OR G)
	FRESH AIR INTAKE (FA)
	SQUARE CEILING DIFFUSER (SUPPLY)



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE, SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (661) 326-8935
FAC SIMILE: (661) 326-8037

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS:
Within dimensions on these drawings shall take precedence over noted dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies for field verification.

PROJECT

TENANT IMPROVEMENT
FOR



1966 WEST AVE L
LANCASTER, CA

DATE ISSUED FOR
8-24-18 BUILDING DEPT SUBMITTAL
8-28-18

NO. REVISIONS

MECHANICAL

FILE NAME: 2366A2-0



SHEET

M-101

1/4"


- HVAC NOTES:
1. PROVIDE NEW ROOFTOP UNIT AS SCHEDULED ON SHEET M-201.
 2. PROVIDE NEW EXHAUST FAN AS NOTED ON PLANS AND SCHEDULED ON SHEET M-201. THE CONTRACTOR SHALL FIELD VERIFY THAT THE LOCATION SHOWN IS A MINIMUM OF 15'-0" FROM ANY OUTDOOR AIR INTAKE.
 3. PROVIDE MAKEUP AIR UNIT PER CAPTIVEAIRE DRAWINGS.
 4. TRANSITION RETURN AIR DROP DOWN TO 28/16 BEFORE PENETRATING ROOF DECK. ROUTE SUPPLY AND RETURN DROPS TO AVOID STRUCTURE.

- GENERAL NOTES:
- A. EXISTING CONDITIONS ARE BASED ON RECORD DRAWINGS PROVIDED BY THE OWNER. CONTRACTOR SHALL ADJUST TO ACTUAL FIELD CONDITIONS AT NO ADDITIONAL EXPENSE TO THE PROJECT.
 - B. CONTRACTOR SHALL BE RESPONSIBLE FOR FIELD VERIFICATION OF ALL EXISTING CONDITIONS PRIOR TO SUBMITTING HIS BID. NO ADDITIONAL COMPENSATION WILL BE PROVIDED FOR ANY EXTRAS DUE TO THE CONTRACTOR'S FAILURE TO VISIT THE PROJECT SITE PRIOR TO SUBMITTING THE BID. ANY DISCREPANCIES SHALL BE IMMEDIATELY REPORTED TO THE ENGINEER FOR RESOLUTION.
 - C. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH ALL APPLICABLE GOVERNMENT AND LOCAL CODES.
 - D. MECHANICAL CONTRACTOR SHALL FIELD COORDINATE WITH ELECTRICAL CONTRACTOR FOR ALL POWER REQUIREMENTS.
 - E. ALL CONTRACTORS SHALL REVIEW A COMPLETE SET OF CONSTRUCTION DOCUMENTS AND COOPERATE WITH THE OTHER TRADES SO THAT THE INSTALLATION OF ALL EQUIPMENT MAY BE PROPERLY COORDINATED.
 - F. ALL EQUIPMENT FURNISHED SHALL FIT THE SPACE AVAILABLE WITH CONNECTIONS IN THE REQUIRED LOCATIONS AND WITH ADEQUATE SPACE FOR OPERATING AND SERVICING. THE DRAWINGS ARE GENERALLY DIAGRAMMATIC AND INDICATE THE INTENT OF THE INSTALLATION WHILE THE SPECIFICATIONS AND EQUIPMENT LIST DENOTE THE TYPE AND QUALITY OF MATERIAL AND WORKMANSHIP TO BE USED. THE DRAWINGS SHALL NOT BE SCALED FOR EXACT MEASUREMENTS. WHERE A CONFLICT EXISTS BETWEEN THE DRAWINGS AND THE SPECIFICATIONS, THE HIGHER AND/OR MORE COSTLY STANDARD WILL APPLY. THE CONTRACTOR SHALL PROMPTLY NOTIFY THE ENGINEER WHOSE DECISION SHALL BE FINAL. NO ALLOWANCE WILL BE MADE SUBSEQUENTLY IN THIS REGARD ON BEHALF OF THE CONTRACTOR AFTER AWARD OF THE CONTRACT.
 - G. COORDINATE DUCT ROUTING AND HEIGHTS WITH GENERAL CONTRACTOR. VERIFY ALL CLEARANCES BEFORE STARTING WORK.
 - H. THE CONTRACTOR SHALL INSTALL ALL PIPING, DUCTWORK AND EQUIPMENT AS REQUIRED TO CONFORM TO THE STRUCTURE, AVOID OBSTRUCTIONS, PRESERVE CEILING HEIGHTS AND HEADROOM AND MAKE ALL EQUIPMENT REQUIRING MAINTENANCE OR REPAIR ACCESSIBLE.
 - I. ALL DUCT CONNECTIONS TO HVAC EQUIPMENT MUST BE MADE WITH FLEXIBLE CONNECTORS.
 - J. DO NOT ATTACH ANYTHING TO DECK ABOVE. ATTACH TO STRUCTURE (i.e. BEAMS, JOISTS) ONLY. DUCT HANGERS SHALL BE INSTALLED IN ACCORDANCE WITH LOCAL CODES. CONNECTIONS TO JOISTS SHALL BE MADE AT THE TOP CORNER.
 - K. ALL DUCT DIMENSIONS INDICATED ARE CLEAR INSIDE DIMENSIONS. ALL SUPPLY AND UNTEMPERED OUTDOOR AIR DUCTWORK SHALL BE LINED WITH 1-1/2" ACOUSTICAL DUCT LINER OR WRAPPED WITH 2" THICK FIRE RETARDANT FIBERGLASS WITH A REINFORCED ALUMINUM FOIL JACKET AND SHALL BE APPROVED FOR USE BY SMACNA AND NAIMA. RETURN AIR TRANSFER DUCTS AND RETURN DUCTWORK WITHIN 10 FEET OF THE UNIT FAN SHALL BE LINED WITH 1" ACOUSTICAL DUCT LINER.
 - L. EXPOSED SPIRAL DUCT TO BE GALVANIZED FINISH, FREE FROM SCRATCHES, DENTS OR BLEMISHES AND PAINTED TO MATCH THE SURROUNDING AREA. DUCT SHALL BE INTERNALLY LINED AND SEALED WITH DUCT SEALER COMPLETELY CONCEALED WITHIN THE DUCT JOINT. NO EXPOSED SEALER OR TAPE WILL BE ACCEPTED.
 - M. ALL EXPOSED DUCTWORK SHALL BE INSTALLED THRU JOIST SPACE.
 - N. PROVIDE REMOTE VOLUME DAMPER CONTROL MANUFACTURED BY YOUNG REGULATOR OR UNITED ENERTECH FOR DAMPERS LOCATED ABOVE INACCESSIBLE CEILINGS. LOCATE CONTROLLER ABOVE ACCESSIBLE CEILING LOCATION.
 - O. TENANT'S CONTRACTOR SHALL BE RESPONSIBLE FOR THE FIELD VERIFICATION OF ALL UTILITY RUNS AND/OR OTHER IMPROVEMENTS LOCATED ON THE PREMISES PRIOR TO BIDDING. TENANT'S CONTRACTOR SHALL ALSO BE RESPONSIBLE FOR ALL COSTS RELATING TO THE RELOCATION OF, DAMAGE TO, REPAIR OF ANY EXISTING UTILITY RUNS AND/OR IMPROVEMENTS WHICH ARE DAMAGED AS A RESULT OF TENANT'S WORK IN OR AROUND THE PREMISES.
 - P. ROOF MOUNTED EQUIPMENT SHALL BE LABELED WITH THE TENANT NAME AND SPACE NUMBER WITH 3" HIGH WEATHER PROOF LETTERS.
 - Q. ALL GREASE EXHAUST DUCTWORK SHALL BE PROVIDED WITH 3" FOIL FACED THERMAL-CERAMIC INSULATION FOR GREASE DUCTS. INSULATION SHALL MEET NFPA 96 AND ASTM E 2336 REQUIREMENTS.
 - R. GREASE DUCT LEAKAGE TESTING MUST BE PERFORMED PRIOR TO CONCEALMENT OF THE DUCTWORK.
 - S. MECHANICAL CONTRACTOR SHALL PROVIDE TENANT WITH A WRITTEN ONE (1) YEAR MANUFACTURER'S WARRANTY ON ALL HVAC EQUIPMENT PROVIDED AND / OR INSTALLED. THE WARRANTY SHALL INCLUDE ALL LABOR, MATERIALS AND THREE (3) ROUTINE SERVICES INCLUDING FILTER CHANGES DURING A ONE (1) YEAR PERIOD.
 - T. AT THE COMPLETION OF CONSTRUCTION AN NEBB, AABC OR TABB CERTIFIED AIR BALANCE REPORT SHALL BE SUBMITTED TO THE ENGINEER AND LANDLORD. THE BALANCING MUST BE COMPLETED BY AN INDEPENDENT, THIRD PARTY CONTRACTOR WITH NO TIES TO THE INSTALLING CONTRACTORS.



MECHANICAL ROOF PLAN

1/4"



PAUL DHANENS • ARCHITECT


ARCHITECT	
<div><div>PAUL DHANENS NO. C-23843 GENERAL STATE OF CALIFORNIA</div><div>5100 CALIFORNIA AVE, SUITE 107 BAKERSFIELD, CALIFORNIA 93309 TELEPHONE: (805) 326-8935 FACSIMILE: (805) 326-8037</div></div>	
CONSULTANT	
COPYRIGHT	
<p>PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.</p> <p>NOTICE TO CONTRACTORS: Written dimensions on these drawings shall take precedence over noted dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.</p>	
PROJECT	
TENANT IMPROVEMENT FOR	
<div><div>THAMOUS FOR</div><div>Steak 'n Shake</div><div>STEAKBURGERS</div></div>	
1966 WEST AVE L LANCASTER, CA	
DATE	ISSUED FOR
8-24-18	BUILDING DEPT SUBMITTAL
6-28-19	
NO.	REVISIONS
▲	
▲	
▲	
▲	
MECHANICAL	
FILE NAME:	2366A2-0
SHEET	
M-102	

SECTION 230000 – HVAC GENERAL CONDITIONS	
PART 1 GENERAL	
1.01 APPLICABILITY	A. This section supplements all sections of the Specifications for Division 23 and shall apply to all phases of work hereinafter specified, shown on the Drawings, or required to provide a complete installation of approved HVAC systems.
1.02 DEFINITIONS	A. "Work" is hereby defined as, "The construction and services required by the Contract Documents whether completed or partially completed and includes all labor, materials, equipment, and services provided or to be provided by the Contractor to fulfill the Contractor's obligations. The work may constitute the whole or a part of the project." B. "Furnish" is hereby defined as, "To supply and deliver, unload, and inspect for damage." C. "Install" is hereby defined as, "To unpack, assemble, erect, apply, place, finish, cure, protect, clean, connect, and place into operation into the work." D. "Provide" is hereby defined as, "To furnish and install." E. "Connect" is hereby defined as, "To bring service to the equipment and make final attachment including necessary ductwork, piping, wiring, etc." F. "Concealed" is hereby defined as, "Hidden from sight in closets, turned spaces, shafts, hung ceilings, embedded in construction, in crawl spaces, or buried." G. "Exposed" is hereby defined as, "Not installed underground nor concealed as defined by the Specifications." H. "Drawings" is hereby defined as, "All plans, details, equipment schedules, diagrams, schedules, etc. issued for the construction of the work." 1.03 CODES AND STANDARDS A. Perform work in accordance with the applicable Building Code, Electrical Code, Fire Code, Mechanical Code, Plumbing Code, Energy Code, and all other applicable codes, amendments, and ordinances. Also perform all work in accordance with the Americans with Disabilities Act (ADA) and the Authority Having Jurisdiction (AHJ) including Fire Marshall(s). B. Perform work in accordance with Landlord requirements, including any Tenant Criteria Manuals and Lease Exhibits, where applicable. C. Perform work in accordance with the applicable utility companies serving the project. Make all arrangements with the utility companies for proper coordination of the work. D. Recognized Standards: Design, manufacture, testing and method of installation of all apparatus and materials furnished under the requirements of these Specifications shall conform to the latest publications or standards rules of Underwriters Laboratories, Inc. (U.L.), American Society for Testing and Materials (ASTM), American National Standards Institute (ANSI), and National Electrical Code (NEC), National Fire Protection Association (NFPA), American Institute of Refrigerating and Air-Conditioning Engineers (ASHRAE), and the Sheet Metal and Air Conditioning Contractors' National Association (SMACNA). E. The Contract Documents shall take precedence over the Contract Documents exceed code, Landlord, utility, or recognized standards requirements. 1.04 PERMITS AND FEES A. Permits, licenses, fees, inspections and arrangements required for the work under this Contract shall be obtained by the Contractor at his expense, unless otherwise indicated. 1.05 CONTRACT DRAWINGS A. The Contractor is responsible to obtain, fully understand, and coordinate the work with the complete set of Contract Documents. Any required corrections, including all associated costs, arising from issues caused by the Contractor's failure to understand and/or coordinate the work with the complete set of Contract Documents are the Contractor's sole responsibility. B. Work under these sections is diagrammatic unless indicated otherwise and is intended to convey the scope of work and indicate the general arrangement of ductwork, piping, equipment, and materials. The Contractor shall be responsible for the work and verify spaces for the installation of these materials and equipment. Wherever a question exists as to the exact intended location of ductwork, piping, or equipment, obtain instructions from the Architect before proceeding with the work. C. Notify the Architect for resolution if a discrepancy is discovered within the Contract Documents. Should the Architect reject a discrepancy resolution of which they were not notified, the Contractor is fully responsible to correct the installation, including all associated costs, until approval of the installation is given by the Architect. 1.06 EXISTING CONDITIONS A. Verify existing conditions prior to beginning work. B. Any existing conditions indicated in the Contract Documents are based on information drawings provided by others and possibly limited field verification. The Contractor shall adjust for actual field conditions at no additional expense to the Owner. C. The Contractor shall visit the project site, review existing conditions against the Contract Documents, and familiarize himself with the work prior to bidding and start of the work. By signing the Contract, the Contractor acknowledges the site visit has been completed and the existing conditions are accepted. D. The Contractor shall notify the Architect of any discrepancies in writing so the appropriate modifications to the design can be made without delay to the project. The Contractor assumes full responsibility of adjusting for discrepancies of which the Architect is not informed. 1.07 SUBMITTALS A. Shop Drawings: 1. Furnish the Architect shop drawing portfolios containing names of manufacturer and cut sheets of equipment to be used on the project. Use manufacturer's specification sheets identified by number indicated on drawings or schedules. Indicate catalog number on the cut sheets. As applicable, provide construction data, weight and dimensional data, voltage ratings, performance data, loading curves, fan curves and sound data as part of the shop drawing submittal. 2. Submittals are reviewed only for general compliance with the Contract Documents. Dimensions, quantities and/or details are checked during submittal review. Review of the submittals does not relieve the Contractor of the responsibility for providing all materials, equipment and accessories necessary for a complete and operational system meeting the requirements of the project and the intent of the Contract Documents. The responsibility for coordination of substituted materials and equipment lies solely with the subcontracting Contractor. 3. Electrical Characteristics: Verify that proper power supply is available prior to ordering equipment. Verify that voltage, phase and current rating of power supply and inform Engineer of any deviations prior to order, connection of equipment or start-up. Responsibility for verification of proper power supply voltage and current rating and of damage resulting from incorrect connections shall rest with this Contractor. B. Project Record Documents: Provide as specified. C. Operation and Maintenance Data: Include manufacturer's descriptive literature, operating instructions, installation instructions, maintenance and repair data, and parts listing. D. Test Reports: Provide as specified. 1.08 QUALITY ASSURANCE A. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum five years experience. B. Installer Qualifications: Company specializing in performing the work of this section, with minimum five years experience. C. Products: 1. Listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated. D. All equipment and components shall be free of all rust/corrosion or any visible damage. All items not complying with this requirement shall be replaced without any change in the Contract amount. E. Equipment performance and accessories shall be as scheduled on the Drawings and specified herein. Inclusion in both locations is not a prerequisite to inclusion in the Contract. Equipment and accessories specified in either location shall be included in the Contract. Provide all necessary accessories and connections as required for a complete, functional system, including all required components reasonably inferred to as necessary although such components may or may not be specifically indicated in the Contract Documents. F. Code or utility company requirements shall supersede any conflicting requirements of this section. 1.09 DELIVERY, STORAGE, AND HANDLING A. Rooftop Equipment: Protect units from physical damage by storing off site until roof mounting curbs are in place, ready for immediate installation of units. B. Protect insulation from weather and construction traffic, dirt, water, chemical, and mechanical damage, by storing in original wrapping. C. Protect dampers and accessories from damage to operating linkages, blades and finishes. D. Provide temporary end caps and closures on piping and fittings. Mount in place until installation. E. Protect motors stored on site from weather and moisture by maintaining factory covers and suitable weather-proof covering. For extended outdoor storage, remove motors from equipment and store separately. 1.10 WARRANTY AND GUARANTEE A. Submit manufacturer's warranty and ensure forms have been filled out in Owner's name and registered with manufacturer. B. Provide one year manufacturer warranty for pumps. C. Provide three year manufacturer warranty for solid state ignition modules. D. Provide five year manufacturers warranty for compressors, heat exchangers, condensing units, and electronic air cleaners. PART 2 PRODUCTS 2.01 SUBSTITUTIONS A. The manufacturers listed are listed to set minimum standards for quality, design, and functionality. The products of other manufacturers may be substituted, at the Contractor's option, during shop drawing review unless indicated otherwise. The products of other manufacturers shall meet or exceed all requirements of the Contract Documents. The Contractor accepts all responsibility for costs and coordination issues arising out of the substitution of materials or equipment, and the coordination of such substitutions with all other contractors and subcontractors. B. The Contractor may use any of the following ductwork, piping or insulation materials at his option, provided the selected material meets with the approval of

	all State, local authorities and any utility company requirements. Verification of compliance of the selected material is the sole responsibility of the installing Contractor.
PART 3 EXECUTION	
3.01	COORDINATION OF WORK A. Examine the Contract Documents as a whole for the work of other trades. Coordinate all work accordingly. B. Promptly report to the Architect any delay or difficulties encountered in the installation of the work, which might prevent prompt and proper installation, or make it unsuitable to connect with or receive the work of others. Failure to so report shall constitute an acceptance of the work of other trades as being fit and proper for the execution of this work. C. Plan, lay out, and coordinate the work with all trades well enough in advance so that it proceeds with a minimum of interference to work that has not been completed and work that is in progress. Inform all trades of openings required for the work and provide all special frames, sleeves, and anchor bolts required. The HVAC system layout may be altered to suit the conditions with engineer approval, prior to the installation of any work and without additional cost to the Owner. Conflicts arising from lack of coordination shall be this Contractor's responsibility. D. Perform all work in conformity with the Contract Documents and afford other trades reasonable opportunity for the execution of their work. Properly connect and coordinate this work with the work of other trades at such time and in such a manner as not to delay or interfere with their work. E. All roofing penetrations shall be flashed and weather sealed by the roofing manufacturer's authorized roofing contractor at this Contractor's expense. This Contractor shall contract with the factory authorized roofing contractor for the specific roofing system applicable to this Project. The use of an unauthorized roofing contractor may result in removal and replacement of the penetration systems at this Contractor's expense. F. All temperature control wiring, thermostat wiring, damper interlock wiring, control panel interlock wiring and miscellaneous low voltage wiring associated with the equipment furnished or installed under this contract shall be furnished and installed by the mechanical contractor or his sub-contractor. All wiring installed under the contract shall be in full compliance with the National Electrical Code, all State and local codes and requirements of the Electrical Specifications for this project.
3.02	EXAMINATION A. Verify field measurements are as indicated on the Drawings. B. Verify all equipment locations prior to rough-in. Maintain adequate equipment service clearance per manufacturer and code. C. Verify routing of all ductwork and piping in field prior to fabrication or installation. Verify adequate clearance with structures, light fixtures, and ceiling heights. D. Verify that proper fuel and power supply is available for connection.
3.03	INTERFACE WITH OTHER PRODUCTS A. Install all ductwork, pipe, equipment, and accessories to preserve fire resistance rating of partitions and other elements, using materials and methods specified.
3.04	FIELD QUALITY CONTROL A. Provide tests as necessary to establish the adequacy, quality, safety, completed status, and suitable operation of each system. Tests shall be conducted under the supervision of the Architect.
3.05	CLEANING AND REPAIR A. Clean fire suppression parts to remove harmful materials. B. Clean exposed surfaces of all ductwork pipe, equipment, and accessories of all dirt, debris, splatter, and other deleterious materials. Follow the manufacturer's recommendations for cleaning as applicable. C. Repair or replace damaged ductwork, pipe, equipment, and accessories, as directed by and to the satisfaction of the Architect, where marking or disfigurement has occurred. All pipe, equipment, and accessories shall be new.
3.06	PROJECT CLOSEOUT A. Project Record Documents: At project closeout, provide one printed copy and one electronic copy of project record drawings to the Owner. Information contained on project record drawings shall include, as a minimum: 1. Actual locations of all equipment, ductwork, air inlets/outlets, accessories, etc. 2. Actual routing of ductwork with sizes and elevations. 3. Actual locations of control devices including valves and volume dampers. B. Operation and Maintenance Data: At project closeout, submit to the Architect two copies of descriptive literature, maintenance and operation data for all hvac equipment, control systems, accessories, and materials used. Include maintenance procedures, intervals, and parts list of each item installed under this contract. Include all manufacturer's guarantees and warranties. C. Maintenance Materials: At project closeout, furnish to the Owner the following: 1. One set of replacement parts and materials for all hvac equipment. 2. The maintenance contract for the hvac system, if applicable. D. Test Reports: At project closeout, submit to the Architect two copies of the following: 1. Testing, Adjusting and Balancing Report
END OF SECTION	
SECTION 230548 – VIBRATION AND SEISMIC CONTROLS FOR HVAC PIPING AND EQUIPMENT	
PART 1 GENERAL	
1.01	SECTION INCLUDES A. Vibration isolators for piping and equipment. B. Seismic restraints. C. Equipment: 1. Fans, axial and centrifugal 2. Packaged roof top equipment
1.02	SUBMITTALS A. Product Data: Provide schedule of vibration isolator type with location and load on each.
PART 2 PRODUCTS	
2.01	MANUFACTURERS A. Isolation Technology, Inc.; Kinetics Noise Control, Inc.; Mason Industries.
2.02	VIBRATION ISOLATORS A. Restrained Open Spring Isolators: 1. Springs: Minimum horizontal stiffness equal to 75 percent vertical stiffness, with working deflection between 0.3 and 0.6 of maximum deflection. 2. Color coding: Springs shall be color coded to indicate load carrying capacity. 3. Spring Mounts: Provide with leveling devices, minimum 0.25 inch thick neoprene sound pads, and zinc chromate plated hardware. 4. Sound Pads: Provide with minimum deflection of 0.05 inch; meet requirements for neoprene pad isolators. 5. Restraint: Provide heavy mounting frame and limit stops. 6. For Exterior and Humid Areas: Hot dipped galvanized housings and neoprene coated springs. B. Spring Hanger: 1. Springs: Minimum horizontal stiffness equal to 75 percent vertical stiffness, with working deflection between 0.3 and 0.6 of maximum deflection. 2. Color code springs for load carrying capacity. 3. Housings: Incorporate neoprene isolation pad meeting requirements for neoprene pad isolators or rubber hanger with threaded insert. 4. Misalignment: Capable of 20 degree hanger rod misalignment. 5. For Exterior and Humid Areas: Hot dipped galvanized housings and neoprene coated springs. C. Neoprene Pad Isolators: 1. Rubber or neoprene waffle pads. a. Hardness: 30 durometer b. Thickness: Minimum 1/2 inch. c. Maximum Loading: 50 psi. d. Rib Height: Maximum 0.7 times width. 2. Configuration: Single layer. D. Rubber Mount or Hanger: Molded rubber designed for 0.4 inch deflection with threaded insert. E. Glass Fiber Pads: Neoprene jacketed pre-compressed molded glass fiber.
2.03	SEISMIC RESTRAINTS A. Type: Non-directional and double acting unit consisting of interlocking steel members restrained by neoprene elements. B. Elements: Replaceable neoprene, minimum of 0.75 inch thick with minimum 1/8 inch air gap. C. Capacity: 4 times load assigned to mount groupings at 0.4 inch deflection. D. Attachment Points and Fasteners: Capable of withstanding 3 times rated load capacity of seismic snubber.
PART 3 EXECUTION	
3.01	INSTALLATION A. Install in accordance with manufacturer's instructions. B. On closed spring isolators, adjust so side stabilizers are clear under normal operating conditions. C. Prior to making piping connections to equipment with operating weights substantially different from installed weights, block up equipment with temporary shims to final height. When full load is applied, adjust isolators to load to allow shim removal. D. Support piping connections to equipment mounted on isolators using isolators or resilient hangers to nearest flexible pipe connector. E. Provide flexible connections on all piping and ductwork connections to equipment. Refer to other sections of this Specification for the acceptable types of flexible connectors to be used. F. Selection of type, thickness and deflection of vibration isolation shall be by the vibration control manufacturer based on the specific equipment type and size, as scheduled on the Drawings and indicated below.
3.02	SCHEDULES A. Equipment Isolation Schedule: (Minimum deflection as sized by the isolation equipment manufacturer). 1. Fans, axial and centrifugal. a. Small fans up to 22" diameter wheel: 1) Rubber Mount or Hanger


2. Packaged roof top equipment. a. Above grade roof structures: 1) Base: Roof Curb. 2) Isolation: Full perimeter Neoprene Pad between curb and units. Provide restrained spring vibration isolation curbs when indicated on the Drawings.	
END OF SECTION SECTION 230593 – TESTING, ADJUSTING, AND BALANCING FOR HVAC PART 1 GENERAL 1.01 SECTION INCLUDES A. Testing, adjustment, and balancing of air systems. 1. Air handling units; Packaged heating and/or cooling equipment; Fans. (Exhaust and supply); Coils; Terminal equipment; Air inlets and outlets. (Diffusers, grilles, louvers, etc.) 2. Measurement of final operating condition of HVAC systems. Independent agency requirements. 1.02 SUBMITTALS A. Qualifications: Submit name of adjusting and balancing agency and TAB supervisor for approval within 30 days after award of Contract. Provide TAB Agency qualifications. B. Final Report: Indicate deficiencies in systems that would prevent proper testing, adjusting, and balancing of systems and equipment to achieve specified performance. 1. Submit to the Construction Manager within two weeks after completion of testing, adjusting, and balancing. 2. Provide reports in bound manuals, complete with index page and indexing tabs, with cover identification at front and side. Include set of reduced drawings with air outlets and equipment identified to correspond with data sheets, and indicating thermostat and equipment locations. 3. Include actual instrument list, with manufacturer name, serial number, and date of calibration. 4. Form of Test Reports: Where the TAB standard being followed recommends a report format use that; otherwise, follow ASHRAE Std 111. 5. Include the following on the title page of each report: a. Name, address and telephone number of Testing, Adjusting, and Balancing Agency. b. Project Name; location; Engineer; Contractor; Report date. 1.03 WARRANTY A. The Balancing Contractor shall be prepared to return to the site at no additional cost to re-adjust air quantities as required to provide uniform temperatures, eliminate drafts and objectionable noises during the first year of occupancy, including one full heating and one full cooling season, after the acceptance of the final balancing report. PART 2 PRODUCTS – NOT USED PART 3 EXECUTION 3.01 GENERAL REQUIREMENTS A. Perform total system balance in accordance with one of the following: 1. ASHRAE Std 111, Practices for Measurement, Testing, Adjusting and Balancing of Building Heating, Ventilation, Air-Conditioning, and Refrigeration Systems. 2. NEBB Procedural Standards for Testing Adjusting Balancing of Environmental Systems. 3. SMACNA HVAC Systems Testing, Adjusting, and Balancing. B. Begin work after completion of systems to be tested, adjusted, or balanced and complete work prior to Substantial Completion of the project. C. Where HVAC systems and/or components interface with life safety systems, including fire and smoke detection, alarm, and control, coordinate scheduling and testing and inspection procedures with the authorities having jurisdiction. D. TAB Agency Qualifications: 1. Company specializing in the testing, adjusting, and balancing of systems specified in this Section with a minimum of five years experience. 2. Certified by one of the following: a. ASBC, Associated Air Balance Council; upon completion submit ASBC National Performance Guaranty. b. NEBB, National Environmental Balancing Bureau. c. TABS, The Testing, Adjusting, and Balancing Bureau of National Energy Management Institute. 3. The TAB Agency must be a completely independent, third party balancing contractor with no financial, common owners or other ties to the installing contractors. E. TAB Supervisor and Technician Qualifications: Certified by same organization as TAB agency. 3.02 ADJUSTMENT TOLERANCES A. Air Handling Systems; Air Outlets and Inlets; Hydronic Systems: Adjust to within plus or minus 0.15 percent of design. 3.03 RECORDING AND ADJUSTING A. Permanently mark settings of valves, dampers, and other adjustment devices allowing settings to be restored. Set and lock memory stops. B. Mark on the Drawings the locations where traverse and other critical measurements were taken and cross reference the location in the final report. 3.04 AIR SYSTEM PROCEDURE A. Adjust air handling and distribution systems to provide required or design supply, return, and exhaust air quantities. B. Make air quantity measurements in ducts by Pitot tube traverse of entire cross sectional area of duct. C. Measure air quantities at air inlets and outlets. D. Adjust distribution system to balance uniform space temperatures free from objectionable drafts and noise. E. Use volume control devices to regulate air quantities only to extend that adjustments do not create objectionable air motion or sound levels. Effect volume control by duct internal devices such as dampers and splitters. Do not use diffuser, grille or register integral dampers for balancing adjustments unless the plans do not indicate duct mounted devices. F. Vary total system air quantities by adjustment of fan speeds. Provide drive changes required at no additional expense to the Owner. Vary branch air quantities by damper regulation. G. Measure static air pressure conditions on air supply units, including filter and coil pressure drops, and total pressure across the fan. Make allowances for 50 percent loading of filters. H. Adjust outside air automatic dampers, outside air, return air, and exhaust dampers for design conditions in all operating modes as indicated in the sequence of control. I. Measure temperature conditions across outside air, return air, and exhaust dampers to check leakage. J. Where modulating dampers are provided, take measurements and balance at extreme conditions and at all intermediate operating conditions specified in the sequence of control. Balance variable volume systems at maximum air flow rate, full cooling, and at minimum air flow rate, full heating. 3.05 SCOPE A. Equipment Requiring Testing, Adjusting, and Balancing (if present on the project): 1. HVAC Pumps; Boilers; All Air Handling Equipment; All Packaged Heating and/or Cooling Equipment; All Coils; All Heat Exchangers; Terminal Heat Transfer Units; Air Terminal Units; Air Inlets and Outlets 3.06 MINIMUM DATA TO BE REPORTED A. (As applicable to the project): 1. Summary Comments: a. Design versus final performance b. Notable characteristics of system c. Summary of outdoor and exhaust flows to indicate amount of building pressurization d. Nomenclature used throughout report and test conditions. B. Electric Motors and drives: 1. Manufacturer; Model/Frame; HP/BHP; Phase, voltage, amperage; nameplate, actual, no load; RPM; Service factor; Sheave Make/Size/Bore. 2. V-Belt Drives: Identification/location; Required driven RPM; Driven sheave, diameter and RPM; Bell, size and quantity. C. Cooling and Heating Coils: 1. Identification/number; Manufacturer 2. Air flow, design and actual 3. Air pressure drop, design and actual 4. Entering and leaving air DB and WB temperature, design and actual 5. Water flow, design and actual (if applicable) 6. Water pressure drop, design and actual (if applicable) 7. Entering and leaving water temperature, design and actual (if applicable) D. Air Moving Equipment: 1. Manufacturer; Model number; Serial number; Arrangement/Class/Discharge 2. Air flow, specified and actual 3. Inlet; Discharge; Total static pressure (total external), specified and actual E. Air Distribution: 1. Air terminal number 2. Room number/location 3. Test weights, block up assemblies. 4. Terminal size 5. Area factor 6. Design velocity 7. Design air flow 8. Test (final) velocity 9. Test (final) air flow 10. Percent of design air flow END OF SECTION SECTION 230713 – DUCT INSULATION PART 1 GENERAL 1.01 SECTION INCLUDES	

A. Duct insulation. B. Duct liner. C. Insulation jackets. D. Supply, return or exhaust ducts in ceiling spaces. E. Supply, return or exhaust ducts in interior unconditioned areas. F. Supply, return or exhaust ducts in exposed locations. 1.02 FIELD CONDITIONS A. Maintain ambient temperatures and conditions required by manufacturers of adhesives, mastics, and insulation cements. B. Maintain temperature during and after installation for minimum period of 24 hours.	
PART 2 PRODUCTS 2.01 REQUIREMENTS FOR ALL PRODUCTS OF THIS SECTION A. Surface Burning Characteristics: Flame spread/Smoke developed index of 25/50, maximum, when tested with ASTM E 84, 255, or UL 723. B. Manufacturer: Knaflex Fiber Glass; Johns Manville Corporation; Owens Corning Corp.; CertainTeed Corporation. 2.02 GLASS FIBER, FLEXIBLE A. Insulation: ASTM C 553; flexible, noncombustible blanket. 1. "K" value: 0.31 at 75 degrees F, when tested in accordance with ASTM C 518. 2. Maximum Service Temperature: 450 degrees F. 3. Maximum Water Vapor Sorption: 5.0 percent by weight. B. Vapor Barrier Jacket: 1. Kraft paper with glass fiber yarn and bonded to aluminumized film. 2. Moisture Vapor Permeability: 0.028 ng/Pa s m (0.02 perm inch), when tested in accordance with ASTM E 96/E 90M. 3. Secure with pressure sensitive tape. C. Vapor Barrier Tape: 1. Kraft paper reinforced with glass fiber yarn and bonded to aluminumized film, with pressure sensitive rubber based adhesive. D. Outdoor Vapor Barrier Mastic: 1. Vinyl emulsion type acrylic or mastic, compatible with insulation, black color. 2. Tie Wire: Annealed steel, 16 gage. 2.03 DUCT LINER A. Insulation: Incombustible glass fiber complying with ASTM C 1071; flexible blanket, rigid board, and preformed round liner board; impregnated surface and edges coated with acrylic polymer shown to be fungus and bacteria resistant by testing to ASTM G 21. B. Apparent Thermal Conductivity: Maximum of 0.31 at 75 degrees F. C. Rated Velocily on Coated Air Side for Air Erosion: 5,000 fpm, minimum. D. Minimum Nominal Thickness: a. 1/2 inch Thickness: 0.30. b. 1 inch Thickness: 0.45. c. 1 1/2 inches Thickness: 0.60. d. 2 inch Thickness: 0.70. B. Adhesive: Waterproof, fire-retardant type. C. Liner Fastener: Galvanized steel, self-adhesive pad or impact applied with integral, or press-on head. PART 3 EXECUTION 3.01 INSTALLATION A. Install in accordance with manufacturer's instructions and NAIMA National Insulation Standards. B. Insulated ducts conveying air below ambient temperature: 1. Provide insulation with vapor barrier jackets. 2. Finish with tape and vapor barrier jacket. 3. Control emulsion through walls, sleeves, hangers, and other duct penetrations. C. Insulated ducts conveying air above ambient temperature: 1. Provide with or without standard vapor barrier jacket. 2. Insulate fittings and flanges where service access is required, bevel and seal ends of insulation. D. External Duct Insulation Application: 1. Seal ducts with adhesive or vapor barrier with wires and seal jacket joints with vapor barrier adhesive or tape to match jacket. 2. Secure insulation without vapor barrier with staples, tape, or wires. 3. Seal ducts with top on underside of duct. Use adhesive or mechanical fasteners where necessary to prevent sagging. Lift duct off trapeze hangers and install. 4. Seal vapor barrier penetrations by mechanical fasteners with vapor barrier adhesive. 5. Staple and point insulation around access doors and damper operators to allow operation without disturbing wrapping. E. Duct and Plenum Liner Application: 1. Adhere insulation with adhesive for 90 percent coverage. 2. Secure insulation with mechanical liner fasteners. Refer to SMACNA HVAC Duct Construction Standards – Metal and Flexible for spacing. 3. Seal ducts with top on underside of duct. Use adhesive or mechanical fasteners where necessary to prevent sagging. Lift duct off trapeze hangers and install. 4. Seal liner surface penetrations with adhesive. 5. Increase duct size to allow for insulation thickness. 3.02 SCHEDULES A. The Contractor may use any of the following insulating materials, at his option, provided the selected material meets with the approval of all State, local authorities and utility company requirements. Verification of compliance of the selected insulating material and thickness with all State and local codes and utility company requirements is the sole responsibility of the installing Contractor. B. Supply air ducts in ceiling spaces: 1. Flexible Glass Fiber Duct Insulation: 2 inches thick. 2. Flexible Glass Fiber Duct Liner Insulation: 1-1/2 inches thick. C. Supply, return or exhaust air ducts in crawl spaces, attics or other unconditioned areas: 1. Flexible Glass Fiber Duct Insulation: 3 inches thick. 2. Flexible Glass Fiber Duct Liner Insulation: 1-1/2 inches thick. D. Supply air ducts in interior unconditioned areas: 1. Flexible Glass Fiber Duct Insulation: 3 inches thick. 2. Flexible Glass Fiber Duct Liner Insulation: 1-1/2 inches thick. E. Return or exhaust air ducts exposed in finished areas: None. END OF SECTION SECTION 230713.13 – GREASE DUCT FIREPROOFING PART 1 GENERAL 1.01 SECTION INCLUDES A. Fire resistant duct wrap for kitchen hood exhaust ventilation ducts (grease ducts). B. Fireproofing at duct penetrations through fire rated walls and floors. 1.02 SUBMITTALS A. Product Data: Manufacturer's data sheets on each product to be used. B. Certification: Evidence that the proposed fireproofing and fireproofing are acceptable to the authorities having jurisdiction. PART 2 PRODUCTS 2.01 MANUFACTURERS A. Acceptable Manufacturer: 3M Fire Protection Products, Inc.; Unifrax FireWrap; B. Morgan Thermal Ceramics. 2.02 MATERIALS A. Grease Duct Fireproofing: Material applied directly to metal ducts and achieving two-hour fire rated separation when tested in accordance with UL 2221 or ASTM E2336 by independent testing agency. 1. Surface Burning Characteristics: Flame spread index of 0 and smoke developed index of 0, when tested in accordance with ASTM E 84, both blanket and foil. 2. Combustibility: Non-combustible, when tested in accordance with ASTM E 136. 3. Flexibility: Capable of being formed around corners and shapes by hand. 4. Surface: Foil or other damage resistant surface; fiber not exposed after installation. 5. Accommodation For Duct Access Doors and Panels: Capable of being installed to achieve fire rating without impeding access. 6. Acceptable Product: 3M Fire Barrier Duct Wrap; fire resistant inorganic blanket encapsulated with scrim-reinforced foil facing. B. Fasteners: Non-combustible; use one or both of the following to attach fireproofing to ducts: 1. Banding: Steel or stainless steel, 1/2 inch wide, minimum, and 0.015 inch thick, minimum; with steel banding clips. 2. Insulation Pins: Copper-coated steel impalement pins, minimum 12 gage, for welded attachment, with galvanized steel self-locking washers, 1-1/2 inch square or diameter; or equivalent sized cup-head pins. 3. Access Door Hardware: Hardened steel rods, sleeves, washers, and wing nuts as specified in Manufacturer's instructions. D. Tape: Aluminum foil tape for sealing exposed fiber edges and repairing tears in fireproofing. E. Fireproofing: Material tested in conjunction with fireproofing, in accordance with ASTM E 814, to achieve fire rated penetration seal at duct penetrations through fire rated walls and floors. PART 3 EXECUTION 3.01 EXAMINATION A. Do not begin installation until substrates have been properly prepared. B. If substrate preparation is the responsibility of another installer, notify Engineer of unsatisfactory preparation before proceeding. 3.02 PREPARATION A. Clean surfaces thoroughly prior to installation. B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions. 3.03 INSTALLATION A. Install in strict accordance with manufacturer's instructions and as indicated on	



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE., SUITE 507
BAVERSDALE, CALIFORNIA 93009
TELEPHONE: (661) 326-8535
FACSIMILE: (661) 326-8537


CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves his copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic, electronic form or by any means, without the express written consent of Paul Dhanens Architect. The copyright in these drawings and any variations discovered.

PROJECT

TENANT IMPROVEMENT FOR



1966 WEST AVE L
LANCASTER, CA


DATE	ISSUED FOR
9-24-18	BUILDING DEPT SUBMITTAL
6-28-19	

NO.	REVISIONS
▲	
▲	
▲	
▲	

MECHANICAL

FILE NAME:	2366A2-0
SHEET	

M-301



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE., SUITE 107
BAVERFIELD, CALIFORNIA 93309
TELEPHONE: (916) 326-8532
FACSIMILE: (916) 326-8537

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor designs, without the express written consent of only first party without the expressed authority of any other parties or third variations disclosed.

PROJECT

TENANT IMPROVEMENT FOR



NO. REVISIONS

MECHANICAL

FILE NAME: 2366A2-0

SHEET

M-302

- the Drawings.
- B. Perform all required regulatory duct leakage and weld tests in the presence of the code official, including but not limited to light tests and smoke tests, to demonstrate the integrity of the duct construction prior to the installation of any insulation that prevents visual inspection of the ductwork on all sides.
- C. Install fireproofing on entire surface of ducts indicated, except where Contract Documents explicitly indicate 3-sided or 2-sided installation.
- D. At penetrations of ducts through fire rated assemblies (walls, floors, roofs), extend fireproofing through the opening and seal annular space between fireproofing and edges of opening with fireproofing.
- E. Fasten fireproofing to ducts using either banding or insulation pins welded directly to surface of duct; do not use adhesives.
- F. Install fireproofing supports and hangers unless hanger rods are at least 3/8 inch in diameter, spaced not more than 80 inches on center along length of duct, and horizontal supports are at least 2 by 2 by 1/4 inch steel angle or equivalent.
- G. Access Panels: Do not block access; install fireproofing so that panel can be removed and reinstalled without damaging fireproofing.
- H. Seal all cut edges and ends and repair tears in facing using aluminum foil tape.

END OF SECTION

SECTION 233100 – HVAC DUCTS AND CASINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Metal ductwork.
- B. Nonmetal ductwork.
- C. Round spiral ductwork.
- D. Double wall insulated round ductwork.
- E. Kitchen hood ductwork, Type 1 grease hoods.
- F. Duct cleaning.

1.02 PERFORMANCE REQUIREMENTS

- A. No variation of duct configuration or sizes permitted except by written permission. Size round ducts installed in place of rectangular ducts in accordance with ASHRAE table of equivalent rectangular and round ducts, only after approval of the Engineer. Sizes shown on design drawings are air dimensions. Contractor may increase duct size without engineer approval, provided all ceiling and shaft clearances can be maintained. Additional charges for increased duct size will not be accepted by the owner.
- B. Report all conflicts with structure or other obstructions, prior to fabrication of any ductwork. Subsequent adjustments in the sizes of ducts shall be accommodated without any additional expense to the Owner.

1.03 SUBMITTALS

- A. Shop Drawings: Indicate duct fittings, particulars such as gages, sizes, welds, and configuration prior to start of work for all systems. No ductwork shall be fabricated until engineer approved shop drawings have been received by the Contractor. Indicate ductwork shop drawings shall be similar and equal to the shapes necessary by the obstructions of all trades.
- B. Test Reports: Indicate pressure tests performed, include date, section tested, test pressure, and leakage rate, following SMACNA (LEAK) HVAC Air Duct Leakage Test Manual.

1.04 REGULATORY REQUIREMENTS

- A. Duct construction to NFPA 90A, NFPA 90B, and NFPA 96 standards.
- B. Code or utility company requirements shall supersede any conflicting requirements of this Section.

1.05 FIELD CONDITIONS

- A. Do not install duct sealants when temperatures are less than those recommended by sealant manufacturer's instructions.
- B. Maintain temperatures within acceptable range during and after installation of duct sealants.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Galvanized Steel Ducts: Hot-dipped galvanized steel sheet, ASTM A 653/A 653M FS Type B, with G90/Z275 coating.
- B. Steel Ducts: ASTM A 1008/A 1008M, Designation CS, cold-rolled commercial steel.
- C. Aluminum Ducts: ASTM B 209 (ASTM B 209M); aluminum sheet, alloy 3003-H14.
- D. Aluminum Connectors and Bar Stock: Alloy 6061-T651 or of equivalent strength.
- E. Insulated Flexible Ducts:
- The Contractor may use any of the following ductwork materials, at his option, provided the selected material meets with the approval of all State, local authorities and utility company requirements. Verification of compliance of the selected ductwork material is the sole responsibility of the installing Contractor.
 - Two ply vinyl film supported by helically wound spring steel wire; fiberglass insulation; aluminumized vapor barrier film.
 - Pressure Rating: 10 inches WG positive and 1.0 inches WG negative.
 - Maximum Velocity: 4000 fpm.
 - Temperature Range: -20 degrees F to 160 degrees F.
 - Minimum R-Value: 4.2 or greater as required by the applicable energy codes.
- F. Black polymer film supported by helically wound spring steel wire; fiberglass insulation; aluminumized vapor barrier film.
- Pressure Rating: 4 inches WG positive and 0.5 inches WG negative.
 - Maximum Velocity: 4000 fpm.
 - Temperature Range: -20 degrees F to 175 degrees F.
 - Minimum R-Value: 4.2 or greater as required by the applicable energy codes.
- G. Multiple layers of aluminum laminate supported by helically wound spring steel wire; fiberglass insulation; aluminumized vapor barrier film.
- Pressure Rating: 10 inches WG positive and 1.0 inches WG negative.
 - Maximum Velocity: 4000 fpm.
 - Temperature Range: -20 degrees F to 210 degrees F.
 - Minimum R-Value: 4.2 or greater as required by the applicable energy codes.
- H. UL 181, Class 1, aluminum laminate and polyester film with latex adhesive supported by helically wound spring steel wire; fiberglass insulation; aluminumized vapor barrier film.
- Pressure Rating: 10 inches WG positive and 1.0 inches WG negative.
 - Maximum Velocity: 4000 fpm.
 - Temperature Range: -20 degrees F to 210 degrees F.
 - Minimum R-Value: 4.2 or greater as required by the applicable energy codes.

- I. Joint Sealers and Sealants: Non-hardening, water resistant, mildew and mold resistant.
- Type: Heavy mastic or liquid used alone or with tape, suitable for joint configuration and compatible with substrates, and recommended by manufacturer for pressure class of ducts.
 - VOC Content: Not more than 250 g/L, excluding water.
 - Surface Burning Characteristics: Flame spread of zero, smoke developed of zero, when tested in accordance with ASTM E 84.
 - For Use With Flexible Ducts: UL labeled.

- J. Hanger Rod: ASTM A 36/A 36M; steel; threaded both ends, threaded one end, or continuously threaded.

2.02 DUCTWORK FABRICATION

- A. Fabricate, support and seal in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and as indicated. Provide ductwork, gages, reinforcing, and sealing for operating pressures indicated.
- B. Construct T's, bends, and elbows with radius of not less than 1-1/2 times width of duct on centerline. Where not possible and where rectangular elbows must be used, provide turning vanes. Where acoustical lining is indicated, provide turning vanes of perforated metal with glass fiber insulation.
- C. Increase duct sizes gradually, not exceeding 15 degrees divergence wherever possible; maximum 30 degrees divergence upstream of equipment and 45 degrees convergence downstream.
- D. Fabricate continuously welded round and oval duct fittings two gages heavier than duct gages indicated in SMACNA Standard. Joints shall be minimum 4 inch cemented slip joint, brazed or electric welded. Prime the ductwork.
- E. Provide standard 45 degree lateral wye takeoffs unless otherwise indicated where 90 degree conical tee connections may be used.
- F. Where ducts are connected to exterior wall louvers and duct outlet is smaller than louver frame, provide blank-out panels sealing lower area around duct. Use same material as duct, painted black on exterior side; seal to louver frame and duct.

2.03 DUCT MANUFACTURERS

- A. Metal-Fab, Inc.; SEMCO Incorporated; United McGill Corporation.

2.04 MANUFACTURED METAL DUCTWORK AND FITTINGS

- A. Manufacture in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and as indicated. Provide duct material, gages, reinforcing, and sealing for operating pressures indicated.
- B. Round Spiral Ducts: Machine made from round spiral lockseam duct with light reinforcing corrugations; fittings manufactured of at least two gages heavier metal than duct.
- C. Double Wall Insulated Round Ducts: Round spiral lockseam duct with galvanized steel outer wall, 1 inch thick fiberglass insulation, perforated galvanized steel inner wall; fitting with solid inner, 18 x 18 inch size for shoulder access, and as indicated.
- D. Transverse Duct Connection System: SMACNA "E" rated rigidly class connection, interlocking angle and duct edge connection system with sealant, gasket, cleats, and corner clips.

2.05 KITCHEN HOOD EXHAUST DUCTWORK, TYPE 1

- A. Fabricate in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and NFPA 96.
- B. Construct of 16 gage carbon steel or 18 gage stainless steel, using continuous external welded joints.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine drawings for the Architectural, Structural, Electrical and all other trades prior to preparation of ductwork shop drawings and prior to the fabrication of any ductwork.
- B. Resolve any conflicts encountered with the Engineer prior to fabrication.
- C. Identify on ductwork shop drawings any deviations in sizes or shapes made necessary by the obstructions of all trades.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Duct joints indicated are inside clear dimensions. For lined ducts, maintain sizes inside lining.
- C. Install and seal metal and flexible ducts in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible.
- D. Provide openings in ductwork where required to accommodate thermometers and controllers. Provide pilot tube openings where required for testing of systems, complete with metal cap with screw or screw to ensure against air leakage. Where openings are provided in insulated ductwork, install insulation material inside a metal ring.
- E. Locate ducts with sufficient space around equipment to allow normal operation and maintenance activities.
- F. Use crimp joints with or without bead for joining round duct sizes 8 inch and smaller with crimp in direction of air flow.
- G. Use double nuts and lock washers on threaded rod supports.
- H. Connect flexible ducts to metal ducts with draw bands.
- I. Support flexible duct runs every five feet in the horizontal direction to avoid dips and sags.
- J. Connect terminal units to supply ducts with one foot maximum length of flexible duct. Do not use flexible duct to change direction.
- K. Connect diffusers to low pressure ducts directly or with 5 feet maximum length of flexible duct held in place with strap or clamp. Longer duct lengths are acceptable if depicted on the design drawings and allowed per local code. A maximum of one 90 degree bend, or equivalent, will be allowed in flexible duct runs.
- L. During construction provide temporary closures of metal or taped polyethylene on open ductwork to prevent construction dust from entering ductwork system.
- M. All exposed ducts in finished areas must be completely free from all dents or imperfections in the galvanized coating and shall be sealed CAREFULLY AND NEATLY with duct sealer completely contained within the joint. Duct wrap will not be permitted in exposed locations. If round duct is indicated in exposed locations, it must be spiral. No exposed duct sealer, tape or longitudinal joints will be accepted in exposed locations. Line all exposed supply air ductwork.
- N. Kitchen hood exhaust, Type 1: Use stainless steel for ductwork exposed to view and stainless steel or carbon steel for ducts where concealed.
- O. For all hood systems perform required regulatory duct leakage and weld tests in the presence of the code official, including but not limited to light tests and smoke tests, to demonstrate the integrity of the duct construction prior to the installation of any insulation that prevents visual inspection of the ductwork on all sides.
- P. Provide residue traps in kitchen hood exhaust ducts at base of vertical risers with provisions for clean out.
- Q. All roofing penetrations shall be flashed and weather sealed by the roofing manufacturer's authorized roofing contractor at this Contractor's expense. This Contractor shall contract with the factory authorized roofing contractor for the specific roofing system applicable to this Project. The use of an unauthorized roofing contractor may result in removal and replacement of the penetration systems at this Contractor's expense.

3.03 CLEANING

- A. Clean duct system and force air at high velocity through duct to remove accumulated dust or clean with high power vacuum machines. To obtain sufficient air, clean half the system at a time. Protect equipment which may be harmed by excessive dirt with temporary filters, or bypass during cleaning.

3.04 SCHEDULES

- A. Ductwork Material:
- B. The Contractor may use any of the following ductwork materials, at his option, provided the selected material meets with the approval of all State, local authorities and utility company requirements. Verification of compliance of the selected piping material is the sole responsibility of the installing Contractor.
- Low Velocity Supply (Heating Systems): Galvanized Steel, Aluminum.
 - Low Velocity Supply (System with Cooling Coils): Galvanized Steel, Aluminum.
 - Return and Relief: Galvanized Steel, Aluminum.
 - General Exhaust: Galvanized Steel, Aluminum.
 - Return Air Intake: Galvanized Steel, Aluminum.
 - Kitchen Hood Exhaust, Type 1: Carbon Steel, Stainless Steel, Constructed per NFPA 96.
- C. Ductwork Pressure Class:
- Low Velocity Supply (Heating Systems): Scheduled System ESP+0.25", round up to next higher pressure class.
 - Low Velocity Supply (Systems with Cooling): Scheduled System ESP +0.5", round up to next higher pressure class.
 - Return and Relief: 1 inch.
 - Minimum R-Value: Scheduled System ESP +1.0", round up to next higher pressure class.
 - Pressure Class: 1 inch.
 - Grid core exhaust and return grilles.
- D. See drawings for maximum fan static pressure plus 50% additional.

END OF SECTION

SECTION 233300 – AIR DUCT ACCESSORIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Air turning devices/extractors.
- B. Volume control dampers.
- C. Flexible duct connections.
- D. Duct access doors.

PART 2 PRODUCTS

2.01 AIR TURNING DEVICES/EXTRACTORS

- A. Manufacturer: Krueger; Price Industries; Nalor Industries Inc.; Ruskin Company; Tilus.
- B. Multi-blade device with blades aligned in short dimension; steel or aluminum construction; with individually adjustable blades, mounting straps.

2.02 VOLUME DAMPERS

- A. Manufacturers: Louvers & Dampers, Inc.; Nalor Industries Inc.; Ruskin Company; Prefco Inc.
- B. Fabricate in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and as indicated.
- C. Single Blade Dampers: Fabricate for duct sizes up to 6 x 30 inch.
- D. Multi-Blade Dampers: Fabricate for duct sizes up to 6 x 30 inch.
- E. End Bearings: Except in round ducts 12 inches and smaller, provide end bearings. On multiple blade dampers, provide oil-impregnated nylon or sintered bronze bearings.
- F. The contractor shall provide either a mechanical or electrical cable operated system wherever dampers are located in non-accessible areas.
- Mechanical cable operator system shall be similar and equal to Young Regulator Company, "Bowden Cable Control" system including damper, flexible cable with casing and concealed ceiling regulator control.
 - Electrically operated damper control system shall be similar and equal to United Enertech Corporation, "Power Balance" system including motor operated damper, RJ-11 plenum rated cabling and flush ceiling or wall mounted RJ-11 jack in remote plate. Include one hand held battery pack operator pack to be delivered to the Owner upon completion of the balancing.

2.03 FLEXIBLE DUCT CONNECTIONS

- A. Fabricate in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and as indicated.
- B. Flexible Duct Connections: Fabric crimped metal edging strip.
- Fabric: UL listed fire-retardant neoprene coated woven glass fiber fabric to NFPA 90A, minimum density 30 oz per sq yd.
 - Net Fabric Width: Approximately 2 inches wide.
 - Metal: 3 inches wide, 24 gage thick galvanized steel.

2.04 DUCT ACCESS DOORS

- A. Manufacturers: Acudor Products Inc.; Nalor Industries Inc.; Ruskin Company; SEMCO Incorporated.
- B. Fabricate in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and as indicated.
- C. Fabrication: Rigid and close-fitting of galvanized steel with sealing gaskets and quick fastening locking devices. For insulated ducts, install minimum 1 inch thick insulation with architectural features, symmetrical, and as indicated.
- Less than 12 inches Square: Secure with sash locks.
 - Up to 18 inches Square: Provide two hinges and two sash locks.
- D. Access doors with sheet metal screw fasteners are not acceptable.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install accessories in accordance with manufacturer's instructions, NFPA 90A, and follow SMACNA HVAC Duct Construction Standards – Metal and Flexible. Duct construction and pressure class.
- B. Provide duct access doors for inspection and cleaning before and after filters, coils, fans, automatic dampers, at fire dampers, combination fire and smoke dampers, and elsewhere as indicated. Provide minimum 8 x 8 inch size for hand inner wall; fitting with solid inner, 18 x 18 inch size for shoulder access, and as indicated.
- C. Locate all dampers and control elements in accessible areas wherever possible to avoid access doors. Provide ceiling access doors for access to all dampers and control elements located above inaccessible ceiling areas. Provide minimum 12 x 12 inch size for hand access, 18 x 18 inch size for shoulder access, and as indicated. Provide 4 x 4 inch for balancing dampers only. Review locations prior to fabrication.
- D. Provide balancing dampers at points on supply, return, and exhaust systems where

- branches are taken from larger ducts as required for air balancing. Install minimum 2 duct widths from duct take-off.
- E. Provide balancing dampers on duct take-off to diffusers, grilles, and registers, regardless of whether dampers are specified as part of the diffuser, grille, or register assembly. Do not locate dampers closer than 5 feet or 10 duct diameters from the air terminal device, whichever is greater.
- F. At fans and motorized equipment associated with ducts, provide flexible duct connections immediately adjacent to the equipment.
- G. At equipment supported by vibration isolators, provide flexible duct connections immediately adjacent to the equipment.

END OF SECTION

SECTION 233423 – HVAC POWER VENTILATORS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Roof exhausters.
- B. Kitchen range hood exhausters.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Greenheck; Loren Cook Company; PennBarry; CaptiveAir.

2.02 POWER VENTILATORS – GENERAL

- A. Performance Ratings: Determined in accordance with AMCA 210 and bearing the AMCA Certified Rating Seal.
- B. Sound Ratings: AMCA 301, tested to AMCA 300, and bearing AMCA Certified Sound Rating Seal.
- C. Fabrication: Conform to AMCA 99.
- D. UL Compliance: UL listed and labeled, designed, manufactured, and tested as suitable for the purpose specified and indicated.

2.03 ROOF EXHAUSTERS AND VENTILATORS

- A. Fan Unit: V-belt or direct driven as indicated, with spun aluminum housing; resilient mounted motor; 1/2 inch mesh, 0.62 inch thick aluminum wire birdscreen; square base to suit roof curb with continuous curb gaskets.
- B. Roof Curb: 20 inch high above the finished roof surface (compensate for roof insulation thickness of fan location) self-flashing of galvanized steel or aluminum construction with continuously welded seams, built-in cant strips, insulation and curb bottom, and factory installed roller strip.
- C. Disconnect Switch: Factory wired, non-fusible, in housing for thermal overload protection.
- D. Backdraft Damper: Motor actuated (or gravity damper if depicted on design drawings), aluminum multiple blade construction, felt edged with offset hinge pin, nylon bearings, blades linked, and line voltage motor drive, power open, spring return.
- E. Sheaves: Cast iron or steel, dynamically balanced, bored to fit shafts and keyed; variable and adjustable pitch motor sheave selected as required rpm is obtained with sheaves set at mid-position; fan shaft with self-aligning pre-lubricated ball bearings.
- F. Kitchen hood exhausters shall be upblast with grease trap, ventilated double wall curb and hinged curb adapter base for cleaning. Hood exhausters shall comply with requirements of NFPA 96.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Provide sheaves required for final air balance at no additional expense to the project.
- C. Secure roof and wall exhausters with cadmium plated steel lag screws to roof curb or structure.
- D. Extend ducts to roof and wall exhausters into roof curb or wall structure.
- E. Counterflash duct to roof or wall opening.
- F. All roofing penetrations shall be flashed and weather sealed by the roofing manufacturer's authorized roofing contractor at this Contractor's expense. This Contractor shall contract with the factory authorized roofing contractor for the specific roofing system applicable to this project. The use of an unauthorized roofing contractor may result in removal and replacement of the penetration systems at this Contractor's expense.

END OF SECTION

SECTION 233700 – AIR OUTLETS AND INLETS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Round ceiling diffusers.
- B. Rectangular ceiling diffusers.
- C. Perforated face ceiling diffusers.
- D. Grid core exhaust and return grilles.

1.02 SUBMITTALS

- A. Product Data: Provide data for equipment required for this project. Review outlets and inlets as to size, finish, and type of mounting prior to submission. Submit schedule of outlets and inlets showing type, size, location, application, accessories, and noise level.

1.03 QUALITY ASSURANCE

- A. Test and rate air outlet and inlet performance in accordance with ASHRAE Std 70.
- B. Test and rate lower performance in accordance with AMCA 500-L.
- C. Code requirements shall supersede any conflicting requirements of this Section.

1.04 QUALIFICATIONS

- A. Manufacturer: Qualifications: Company specializing in manufacturing the type of products specified in this Section, with minimum five years of documented experience.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Tilus; Krueger; Price Industries; Nalor Industries Inc.; Hart & Cooley; Ruskin.

2.02 ROUND CEILING DIFFUSERS

- A. Type: Round, adjustable pattern, stamped or spun, multi-core, or architectural plaque diffuser to discharge air in 360 degree pattern, with sectorizing baffles where indicated. Diffuser collar shall project not more than 1 inch above ceiling.
- B. In-plaster ceilings, provide plaster ring and ceiling plaques.
- C. Fabrication: Steel with baked enamel off-white finish.
- D. Accessories: Opposed blade damper and multi-louvered equalizing grid with damper adjustable from diffuser face.

2.03 RECTANGULAR CEILING DIFFUSERS

- A. Type: Square, opposed blade pattern, stamped, multi-core, or architectural plaque diffuser to discharge air in 360 degree pattern with sectorizing baffles where indicated.
- B. Frame: Inverted T-bar type. In-plaster ceilings, provide plaster frame and ceiling frame. (To allow lift-out removal of the diffuser without removal of the plaster frame).
- C. Fabrication: Steel with baked enamel off-white finish.
- D. Accessories: Opposed blade damper and multi-louvered equalizing grid with damper adjustable from diffuser face.

2.04 PERFORATED FACE CEILING DIFFUSERS

- A. Type: Perforated face with fully adjustable pattern and removable face.
- B. Frame: Inverted T-bar type. In-plaster ceilings, provide plaster frame and ceiling frame. (To allow lift-out removal of the diffuser without removal of the plaster frame).
- C. Fabrication: Steel with steel frame and baked enamel off-white finish.
- D. Accessories: Opposed blade damper and multi-louvered equalizing grid with damper adjustable from diffuser face.

2.05 GRID CORE EXHAUST AND RETURN GRILLES

- A. Type: Fixed grilles of 1/2 x 1/2 x 1 inch louvers.
- B. Fabrication: Aluminum with factory off-white enamel finish.
- C. Frame: 1-1/4 inch margin with countersunk screw mounting.
- D. Frame: Channel I-rod in-frame for suspended grid ceilings where face size exceeds 18 x 18 inch.
- E. Damper (if specified on drawings): Integral, gage-operated, opposed blade type with removable key operator, operable from face.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Check location of outlets and inlets and make necessary adjustments in position to conform with architectural features, symmetry, and as indicated.
- C. Install diffusers to ductwork with air tight connection.
- D. Provide balancing dampers on duct take-off to diffusers, and grilles and registers, regardless of whether dampers are specified as part of the diffuser, or grille and register assembly.
- E. Paint ductwork visible behind air outlets and inlets matte black.

END OF SECTION


SECTION 237413 – PACKAGED OUTDOOR ROOF TOP UNITS – GAS FIRED

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Packaged roof top units.
- B. Thermostat controls.
- C. Roof mounting curb and base.
- D. Economizer.
- E. Power exhaust.

PART 2 PRODUCTS



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE., SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (661) 326-8935
FACSIMILE: (661) 326-8037

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted in any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS:
Written dimensions on these drawings shall take precedence over noted dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT FOR



1966 WEST AVE L
LANCASTER, CA

DATE | ISSUED FOR
8-24-18 BUILDING DEPT SUBMITTAL
6-26-19

NO.	REVISIONS
▲	
▲	
▲	
▲	

PLUMBING

FILE NAME: 2366A2-0

SHEET



P-101

PLUMBING NOTES:

- THIS SPACE IS RESERVED FOR ELECTRICAL EQUIPMENT. NO PIPING SHALL PASS BELOW, ABOVE, OR AROUND ELECTRICAL EQUIPMENT. PROVIDE CODE REQUIRED MINIMUM CLEARANCE ABOVE ELECTRICAL EQUIPMENT ACCESS SPACE.
- FURNISH AND INSTALL WATER HEATER AND EXPANSION TANK AS INDICATED ON THE PLANS. REFER TO ARCHITECTURAL PLANS FOR WATER HEATER REQUIREMENTS AND EXACT LOCATION. PIPE WATER HEATER RELIEF AND SECONDARY DRAIN PAN DISCHARGE TO THE NEAREST MOP SINK OR FLOOR DRAIN BELOW THE WATER HEATER. PROVIDE A CODE APPROVED AIR GAP ON THE DISCHARGE OF THE WATER HEATER RELIEF AND SECONDARY DRAIN. REFER TO DETAILS SHEET FOR ADDITIONAL INFORMATION.
- PRESSURE/TEMPERATURE RELIEF FROM WATER HEATER SHALL BE DIRECTED TO THE FLOOR DRAIN IN ACCORDANCE WITH LOCAL REQUIREMENTS.
- 1/2" FLEXIBLE CONTINUOUS TYPE "K" COPPER TUBING BELOW GRADE FROM TRAP PRIMER TO FLOOR DRAIN. NO FITTINGS OR SPLICES ARE ALLOWED BELOW GRADE.
- INSTALL TRAP PRIMER HIGH IN THE CEILING SPACE. FURNISH AND INSTALL AN ACCESS PANEL AS NECESSARY TO MAINTAIN EQUIPMENT.
- THIS SPACE IS RESERVED FOR THE DOMESTIC WATER SERVICE ENTRANCE. REFER TO THE DETAIL SHEETS FOR ADDITIONAL INFORMATION. THE DOMESTIC WATER SERVICE ENTRANCE SHALL COMPLY WITH ALL STATE AND LOCAL REQUIREMENTS AND SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS.
- NEW NATURAL GAS METER SERVING 1,240 MBH. THE SYSTEM DESIGN IS BASED ON 7" W.C. PSI DELIVERY PRESSURE WITH A PRESSURE DROP OF 0.5 INCHES OF WATER COLUMN. THE CONTRACTOR SHALL COORDINATE THE METER PLACEMENT, AVAILABLE PRESSURE, AND NEW SERVICE REQUIREMENTS WITH THE LOCAL UTILITY PRIOR TO CONSTRUCTION. IF THE DELIVERY PRESSURE INDICATED IS NOT AVAILABLE FROM THE UTILITY COMPANY, THE CONTRACTOR SHALL NOTIFY THE ARCHITECT/ENGINEER IMMEDIATELY.
- FURNISH AND INSTALL NATURAL GAS SOLENOID VALVE MOUNTED BELOW THE FINISHED CEILING IN AN ACCESSIBLE LOCATION. THE SOLENOID VALVE SHALL BE INTERLOCKED WITH THE EXHAUST HOOD AND SHALL HAVE A MANUAL SHUT-OFF. THE VALVE SHALL BE PROVIDED AND INSTALLED BY THE PLUMBING CONTRACTOR AND SHALL BE INTERCONNECTED BY THE FIRE PROTECTION CONTRACTOR.
- PROVIDE THERMOSTATIC MIXING VALVE, POWERS #LFE480 OR EQUAL. SET TEMPERATURE AS REQUIRED BY LOCAL JURISDICTION. THERMOSTATIC MIXING VALVE SHALL BE IN ACCORDANCE WITH ANSI/ASSE 1070.
- CONNECT NATURAL GAS SERVICE TO ROOFTOP UNIT IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS. REFER TO DETAIL SHEET FOR ADDITIONAL INFORMATION. VERIFY EXACT LOCATION OF NATURAL GAS CONNECTION ON ROOFTOP UNIT WITH EQUIPMENT PRIOR TO PIPE INSTALLATION.

GENERAL NOTES:

- ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH ALL APPLICABLE GOVERNMENTAL AND LOCAL CODE REQUIREMENTS.
- PROVIDE ACCESS PANELS AS REQUIRED TO ALLOW ACCESS TO VALVES, EQUIPMENT, ETC. LOCATED ABOVE INACCESSIBLE CEILINGS AND WALL CAVITIES.
- ALL SANITARY LINES AND PLUMBING FIXTURES ON THE PROJECT SHALL HAVE AN APPROVED MEANS OF SEWAGE BACKFLOW PREVENTION. FIXTURE SPECIFIC BACKFLOW PREVENTION INCLUDING AIR GAPS AND VACUUM BREAKERS ARE AN ACCEPTABLE MEANS OF BACKFLOW PREVENTION.
- COORDINATE ALL SLAB PENETRATIONS WITH GENERAL CONTRACTOR PRIOR TO CONSTRUCTION. MAINTAIN A MINIMUM OF 2" CLEARANCE FROM THE EDGE OF THE SLAB OPENING TO ANY STRUCTURAL MEMBERS AND PIPES.
- PIPE SIZES INDICATED ON THE PLANS ARE MINIMUM. THE CONTRACTOR SHALL PROVIDE PIPE SIZES EQUAL TO OR GREATER THAN THE SPECIFIED SIZES. THE CONTRACTOR MAY INCREASE PIPE SIZES AS REQUIRED AT NO ADDITIONAL EXPENSE TO THE PROJECT.
- REFER TO THE PLUMBING FIXTURE SCHEDULE FOR INDIVIDUAL PLUMBING FIXTURE CONNECTION SIZE REQUIREMENTS.
- ALL HANDICAPPED ACCESSIBLE WATER CLOSETS SHALL HAVE THE FLUSHING HANDLE ON THE WIDE SIDE OF THE HANDICAPPED ACCESSIBLE STALL AS REQUIRED BY ADA REQUIREMENTS.
- ALL PUBLIC USE LAVATORY FAUCETS SHALL HAVE AN AUTOMATIC SAFETY WATER MIXING DEVICE IN ACCORDANCE WITH ANSI/ASSE 1017 OR 1070 AS APPLICABLE.
- ALL PIPING ON ROOF TO BE PROPERLY SUPPORTED USING APPROVED STANDS. WOOD BLOCKING IS NOT ACCEPTABLE.





PLUMBING PLAN - DOMESTIC HOT & COLD WATER

1/4"


- PLUMBING NOTES:
1. THIS SPACE IS RESERVED FOR ELECTRICAL EQUIPMENT. NO PIPING SHALL PASS BELOW, ABOVE, OR AROUND ELECTRICAL EQUIPMENT. PROVIDE CODE REQUIRED MINIMUM CLEARANCE ABOVE ELECTRICAL EQUIPMENT ACCESS SPACE.
 2. UP TO 4" VENT THROUGH ROOF. INSTALL VENT THROUGH ROOF A MINIMUM DISTANCE OF 15'-0" FROM ALL FRESH AIR INLETS AND BUILDING OPENINGS.
 3. VENT PIPING BELOW GRADE SHALL BE SLOPED BACK TOWARD SANITARY SYSTEM AT 1/4" PER FOOT.
 4. PIPE GRAVITY PRIMARY AND AUXILIARY CONDENSATE FROM EQUIPMENT TO CODE COMPLIANT DISPOSAL POINT. THE CONDENSATE SHALL BE CONNECTED TO THE EQUIPMENT IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS. DISCHARGE SHALL BE THROUGH A CODE APPROVED AIR GAP. THE PIPE ROUTING INDICATED ON THE PLANS IS FOR REFERENCE ONLY. INSTALL THE PIPING AS HIGH AS POSSIBLE AND COORDINATE ROUTING WITH STRUCTURAL, MECHANICAL, ELECTRICAL, ETC. CONDENSATE SHALL NOT BE RUN OVER ELECTRICAL EQUIPMENT.
 5. MOUNT THE DOWNSPOUT NOZZLE AT A MINIMUM OF 1'-8" ABOVE FINISHED GRADE.
 6. 4" ROOF DRAIN PIPING CONNECT TO DAYLIGHT AT CURBFACE (SEE CIVIL DRAWINGS).
 7. ROUTE THE CONDENSATE PIPING ON THE ROOF FROM THE ROOFTOP UNIT TO THE NEAREST ROOF DRAIN OR GUTTER. THE CONDENSATE SHALL BE CONNECTED TO THE ROOFTOP UNIT IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS. VERIFY CONDENSATE REMOVAL REQUIREMENTS WITH LOCAL JURISDICTION PRIOR TO INSTALLATION. IF CONFLICTS OCCUR, NOTIFY THE ARCHITECT/ENGINEER IMMEDIATELY.
 8. FURNISH AND INSTALL 4" DIAMETER PVC COMBUSTION AIR AND EXHAUST FROM THE WATER HEATER TO THE EXTERIOR. FURNISH AND INSTALL CONCENTRIC VENT KIT. THE INSTALLATION SHALL BE IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS AND ALL APPLICABLE LOCAL AND STATE CODES. COORDINATE THE MAXIMUM ALLOWABLE EXHAUST AND VENT LENGTHS WITH THE MANUFACTURER'S REQUIREMENTS.

- GENERAL NOTES:
- A. THE EXISTING CONDITIONS ARE BASED ON "AS-BUILT" DRAWINGS AND/OR LIMITED FIELD VERIFICATIONS. THE CONTRACTOR SHALL ADJUST TO ACTUAL FIELD CONDITIONS AT NO ADDITIONAL EXPENSE TO THE PROJECT. NO ADDITIONAL COMPENSATION WILL BE PROVIDED FOR ANY EXTRAS DUE TO THE CONTRACTOR'S FAILURE TO VISIT THE PROJECT SITE AND/OR PREDETERMINATION OF EXISTING CONDITIONS PRIOR TO SUBMITTING THE BID. ANY DISCREPANCIES SHALL BE IMMEDIATELY REPORTED TO THE ARCHITECT/ENGINEER FOR RESOLUTION.
 - B. THE CONTRACTOR SHALL FAMILIARIZE HIMSELF WITH THE INCIDENTAL DEMOLITION WORK PRIOR TO BIDDING AND COMMENCEMENT OF WORK. THE CONTRACTOR IS RESPONSIBLE FOR DEMOLITION OF ALL EXISTING EQUIPMENT AS REQUIRED FOR THE INSTALLATION/CONSTRUCTION OF NEW WORK.
 - C. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH ALL APPLICABLE GOVERNMENTAL AND LOCAL CODE REQUIREMENTS.
 - D. PROVIDE ACCESS PANELS AS REQUIRED TO ALLOW ACCESS TO VALVES, EQUIPMENT, ETC. LOCATED ABOVE INACCESSIBLE CEILINGS AND WALL CAVITIES.
 - E. ALL SANITARY LINES AND PLUMBING FIXTURES ON THE PROJECT SHALL HAVE AN APPROVED MEANS OF SEWAGE BACKFLOW PREVENTION. FIXTURE SPECIFIC BACKFLOW PREVENTION INCLUDING AIR GAPS AND VACUUM BREAKERS ARE AN ACCEPTABLE MEANS OF BACKFLOW PREVENTION.
 - F. COORDINATE ALL SLAB PENETRATIONS WITH GENERAL CONTRACTOR PRIOR TO CONSTRUCTION. MAINTAIN A MINIMUM OF 2" CLEARANCE FROM THE EDGE OF THE SLAB OPENING TO ANY STRUCTURAL MEMBERS AND PIPES.
 - G. PIPE SIZES INDICATED ON THE PLANS ARE MINIMUM. THE CONTRACTOR SHALL PROVIDE PIPE SIZES EQUAL TO OR GREATER THAN THE SPECIFIED SIZES. THE CONTRACTOR MAY INCREASE PIPE SIZES AS REQUIRED AT NO ADDITIONAL EXPENSE TO THE PROJECT.
 - H. REFER TO THE PLUMBING FIXTURE SCHEDULE FOR INDIVIDUAL PLUMBING FIXTURE CONNECTION SIZE REQUIREMENTS.
 - I. PROVIDE TEMPORARY COVERS, CAPS, OR PLUGS ON SANITARY SEWER SYSTEM THROUGHOUT THE DURATION OF CONSTRUCTION. RAG WADS, DUCT TAPE, OR OTHER SIMILAR METHODS OF TEMPORARY COVERS SHALL NOT BE UTILIZED. UPON COMPLETION OF CONSTRUCTION, COMPLETELY REMOVE ANY AND ALL OBSTRUCTIONS INSIDE THE ENTIRE SYSTEM BY SHAKING, RODING, OR JETTING THE SYSTEM IMMEDIATELY PRIOR TO PROJECT TURNOVER TO THE OWNER.
 - J. ALL BELOW GRADE SANITARY LINES SHALL BE A MINIMUM OF 2" OR IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS.
 - K. SANITARY TEE FITTINGS SHALL NOT BE INSTALLED IN DRAIN, WASTE, AND VENT (DWV) SYSTEMS.
 - L. INSTALL SANITARY PIPING AT A SLOPE OF 1/4" PER FOOT.
 - M. ALL STORM PIPING SHALL BE INSTALLED AS HIGH AS POSSIBLE AND AS CLOSE TO THE BOTTOM OF ROOF DECKING AS POSSIBLE. THE STORM PIPING SHALL BE SLOPED AT 1/8" PER FOOT UNLESS NOTED OTHERWISE. THE PLUMBING CONTRACTOR SHALL PROVIDE HEAT TRACING TAPE AND INSULATION AS REQUIRED FOR ALL PIPING INSTALLED WITHIN WALK-IN FREEZERS TO PREVENT PIPING FROM FREEZING. COORDINATE THE INSTALLATION OF THE HEAT TRACING WITH THE ELECTRICAL CONTRACTOR PRIOR TO INSTALLATION.
 - O. ALL HANDICAPPED ACCESSIBLE WATER CLOSETS SHALL HAVE THE FLUSHING HANDLE ON THE WIDE SIDE OF THE HANDICAPPED ACCESSIBLE STALL AS REQUIRED BY ADA REQUIREMENTS.



PLUMBING PLAN - SOIL, WASTE & VENT

1/4"





PAUL DHANENS • ARCHITECT

ARCHITECT	
<div><div><div>PAUL DHANENS NO. C-23843 GENERAL STATE OF CALIFORNIA</div></div><div>5100 CALIFORNIA AVE, SUITE 107 BAKERSFIELD, CALIFORNIA 93309 TELEPHONE: (805) 326-8936 FACSIMILE: (805) 326-8037</div></div>	
CONSULTANT	
COPYRIGHT	
<p>PAUL DHANENS ARCHITECT 7 expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted to any third party without the expressed written consent of PAUL DHANENS ARCHITECT 7.</p> <p>NOTICE TO CONTRACTORS: Written dimensions on these drawings shall take precedence over noted dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies for field verification, if discovered.</p>	
PROJECT	
TENANT IMPROVEMENT FOR	
<div><div>FAMOUS FOR Steak 'n Shake HAMBURGERS</div><div>1966 WEST AVE L LANCASTER, CA</div></div>	
DATE	ISSUED FOR
8-24-18	BUILDING DEPT SUBMITTAL
6-28-19	
NO.	REVISIONS
▲	
▲	
▲	
▲	
PLUMBING	
FILE NAME:	2366A2-0
SHEET	
P-102	

- PLUMBING NOTES:
1. THIS SPACE IS RESERVED FOR ELECTRICAL EQUIPMENT. NO PIPING SHALL PASS BELOW, ABOVE, OR AROUND ELECTRICAL EQUIPMENT. PROVIDE CODE REQUIRED MINIMUM CLEARANCE ABOVE ELECTRICAL EQUIPMENT ACCESS SPACE.
 2. FURNISH AND INSTALL WATER HEATER AND EXPANSION TANK AS INDICATED ON THE PLANS. REFER TO ARCHITECTURAL PLANS FOR WATER HEATER REQUIREMENTS AND EXACT LOCATION. PIPE WATER HEATER RELIEF AND SECONDARY DRAIN PAN DISCHARGE TO THE NEAREST MOP SINK OR FLOOR DRAIN BELOW THE WATER HEATER. PROVIDE A CODE APPROVED AIR GAP ON THE DISCHARGE OF THE WATER HEATER RELIEF AND SECONDARY DRAIN. REFER TO DETAILS SHEET FOR ADDITIONAL INFORMATION.
 3. PRESSURE/TEMPERATURE RELIEF FROM WATER HEATER SHALL BE DIRECTED TO THE FLOOR DRAIN IN ACCORDANCE WITH LOCAL REQUIREMENTS.
 4. 1/2" FLEXIBLE CONTINUOUS TYPE "K" COPPER TUBING BELOW GRADE FROM TRAP PRIMER TO FLOOR DRAIN. NO FITTINGS OR SPLICES ARE ALLOWED BELOW GRADE.
 5. INSTALL TRAP PRIMER HIGH IN THE CEILING SPACE. FURNISH AND INSTALL AN ACCESS PANEL AS NECESSARY TO MAINTAIN EQUIPMENT.
 6. THIS SPACE IS RESERVED FOR THE DOMESTIC WATER SERVICE ENTRANCE. REFER TO THE DETAIL SHEETS FOR ADDITIONAL INFORMATION. THE DOMESTIC WATER SERVICE ENTRANCE SHALL COMPLY WITH ALL STATE AND LOCAL REQUIREMENTS AND SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS.
 7. NEW NATURAL GAS METER SERVING 1,240 MBH. THE SYSTEM DESIGN IS BASED ON 7" W.C. PSI DELIVERY PRESSURE WITH A PRESSURE DROP OF 0.5 INCHES OF WATER COLUMN. THE CONTRACTOR SHALL COORDINATE THE METER PLACEMENT, AVAILABLE PRESSURE, AND NEW SERVICE REQUIREMENTS WITH THE LOCAL UTILITY PRIOR TO CONSTRUCTION. IF THE DELIVERY PRESSURE INDICATED IS NOT AVAILABLE FROM THE UTILITY COMPANY, THE CONTRACTOR SHALL NOTIFY THE ARCHITECT/ENGINEER IMMEDIATELY.
 8. FURNISH AND INSTALL NATURAL GAS SOLENOID VALVE MOUNTED BELOW THE FINISHED CEILING IN AN ACCESSIBLE LOCATION. THE SOLENOID VALVE SHALL BE INTERLOCKED WITH THE EXHAUST HOOD AND SHALL HAVE A MANUAL SHUT-OFF. THE VALVE SHALL BE PROVIDED AND INSTALLED BY THE PLUMBING CONTRACTOR AND SHALL BE INTERCONNECTED BY THE FIRE PROTECTION CONTRACTOR.
 9. PROVIDE THERMOSTATIC MIXING VALVE, POWERS #LFE480 OR EQUAL. SET TEMPERATURE AS REQUIRED BY LOCAL JURISDICTION. THERMOSTATIC MIXING VALVE SHALL BE IN ACCORDANCE WITH ANSI/ASSE 1070.
 10. CONNECT NATURAL GAS SERVICE TO ROOFTOP UNIT IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS. REFER TO DETAIL SHEET FOR ADDITIONAL INFORMATION. VERIFY EXACT LOCATION OF NATURAL GAS CONNECTION ON ROOFTOP UNIT WITH EQUIPMENT PRIOR TO PIPE INSTALLATION.

- GENERAL NOTES:
- A. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH ALL APPLICABLE GOVERNMENTAL AND LOCAL CODE REQUIREMENTS.
 - B. PROVIDE ACCESS PANELS AS REQUIRED TO ALLOW ACCESS TO VALVES, EQUIPMENT, ETC. LOCATED ABOVE INACCESSIBLE CEILINGS AND WALL CAVITIES.
 - C. ALL SANITARY LINES AND PLUMBING FIXTURES ON THE PROJECT SHALL HAVE AN APPROVED MEANS OF SEWAGE BACKFLOW PREVENTION. FIXTURE SPECIFIC BACKFLOW PREVENTION INCLUDING AIR GAPS AND VACUUM BREAKERS ARE AN ACCEPTABLE MEANS OF BACKFLOW PREVENTION.
 - D. COORDINATE ALL SLAB PENETRATIONS WITH GENERAL CONTRACTOR PRIOR TO CONSTRUCTION. MAINTAIN A MINIMUM OF 2" CLEARANCE FROM THE EDGE OF THE SLAB OPENING TO ANY STRUCTURAL MEMBERS AND PIPES.
 - E. PIPE SIZES INDICATED ON THE PLANS ARE MINIMUM. THE CONTRACTOR SHALL PROVIDE PIPE SIZES EQUAL TO OR GREATER THAN THE SPECIFIED SIZES. THE CONTRACTOR MAY INCREASE PIPE SIZES AS REQUIRED AT NO ADDITIONAL EXPENSE TO THE PROJECT.
 - F. REFER TO THE PLUMBING FIXTURE SCHEDULE FOR INDIVIDUAL PLUMBING FIXTURE CONNECTION SIZE REQUIREMENTS.
 - G. ALL HANDICAPPED ACCESSIBLE WATER CLOSETS SHALL HAVE THE FLUSHING HANDLE ON THE WIDE SIDE OF THE HANDICAPPED ACCESSIBLE STALL AS REQUIRED BY ADA REQUIREMENTS.
 - H. ALL PUBLIC USE LAVATORY FAUCETS SHALL HAVE AN AUTOMATIC SAFETY WATER MIXING DEVICE IN ACCORDANCE WITH ANSI/ASSE 1017 OR 1070 AS APPLICABLE.
 - I. ALL PIPING ON ROOF TO BE PROPERLY SUPPORTED USING APPROVED STANDS, WOOD BLOCKING IS NOT ACCEPTABLE.




PLUMBING PLAN - GAS & CONDENSATE

1/4"


GAS CALCS

GRIDDLE = 54,000 BTU
GRIDDLE = 108,000 BTU
FRYER = 218,000 BTU
WATER HTR = 199,000 BTU
MUA = 184,900 BTU
AC = 120,000 BTU
883,900/1100= 804 CFH
DISTANCE= 90 FT
USE (1)2" GAS



PAUL DHANENS • ARCHITECT

ARCHITECT
<div><div><div><div><div><div></div></div></div><div><div><div></div></div><div><div></div></div></div><div><div><div></div></div><div><div></div></div></div><div><div><div></div></div><div><div></div></div></div></div></div><div>PAUL DHANENS NO. C-23843 GENERAL STATE OF CALIFORNIA</div></div> <div><div>5100 CALIFORNIA AVE, SUITE 107 BAKERSFIELD, CALIFORNIA 93309 TELEPHONE: (661) 326-8935 FACSIMILE: (661) 326-8937</div></div>
CONSULTANT
COPYRIGHT
<div>PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.</div> <div>NOTICE TO CONTRACTORS Written dimensions on these drawings shall take precedence over noted dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.</div>
PROJECT
TENANT IMPROVEMENT FOR
<div><div><div><div><div><div></div></div></div><div><div><div></div></div><div><div></div></div></div><div><div><div></div></div><div><div></div></div></div></div></div><div>FAMOUS FOR Steak 'n Shake STEAKBURGERS</div></div> <div>1966 WEST AVE L LANCASTER, CA</div>
DATE ISSUED FOR
8-24-18 BUILDING DEPT SUBMITTAL
6-28-19
NO. REVISIONS
1
2
3
4
PLUMBING
FILE NAME: 2366A2-0
SHEET
P103



PAUL DHANENS • ARCHITECT

ARCHITECT

PAUL DHANENS

NO. C-23843

GENERAL

STATE OF CALIFORNIA

5100 CALIFORNIA AVE., SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (661) 326-8335
FACSIMILE: (661) 326-8337

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS:
Written dimensions on these drawings shall take precedence over scaled dimensions. Contractor shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT FOR

FAMOUS FOR

Steak 'n Shake



STEAKBURGERS

1966 WEST AVE L
LANCASTER, CA

DATE	ISSUED FOR
8-24-18	BUILDING DEPT SUBMITTAL
6-26-19	
NO.	REVISIONS
▲	
▲	
▲	
▲	

PLUMBING

FILE NAME:	2366A2-0
SHEET	P-104




PLUMBING ROOF PLAN

1/4"



PLUMBING FIXTURE SCHEDULE							
Mark		DESCRIPTION	FINAL CONNECTIONS				MANUFACTURER
			HW	CW	V	W	MODEL NUMBER
WC-1	WATER CLOSETS	1.28 GALLONS PER FLUSH, FLOOR MOUNTED, BOTTOM OUTLET, 12" ROUGH-IN, SLOAN ROYAL FLUSH VALVE - ADA HEIGHT, COLOR: WHITE	-	1-1/4"	1 1/2"	3"	AMERICAN STANDARD: CADET
	WATER CLOSET SEAT	COMMERCIAL DUTY, EXTRA HEAVY WEIGHT, INJECTION MOLDED SOLID PLASTIC, LARGE MOLDED BUMPERS, STAINLESS STEEL POSTS, SELF-SUSTAINING, CONCEALED STAINLESS STEEL CHECK HINGE HOLDING SEAT IN ANY RAISED POSITION UP TO 11 DEG. BEYOND VERTICAL, OPEN FRONT, LESS COVER, COLOR: WHITE					CHURCH:
	SUPPLIES	-					
WC-2	WATER CLOSETS	1.6 GALLONS PER FLUSH, FLOOR MOUNTED, BOTTOM OUTLET, 12" ROUGH-IN, LEFT HAND TRIP LEVER, 3/8" CHROME PLATED BRASS TUBING, PRESSURE ASSISTED TANK, 25 PSI MINIMUM WORKING PRESSURE, COLOR: WHITE	-	3/8"	1 1/2"	3"	AMERICAN STANDARD: CADET 2462.016
	WATER CLOSET SEAT	COMMERCIAL DUTY, EXTRA HEAVY WEIGHT, INJECTION MOLDED SOLID PLASTIC, LARGE MOLDED BUMPERS, STAINLESS STEEL POSTS, SELF-SUSTAINING, CONCEALED STAINLESS STEEL CHECK HINGE HOLDING SEAT IN ANY RAISED POSITION UP TO 11 DEG. BEYOND VERTICAL, OPEN FRONT, LESS COVER, COLOR: WHITE					CHURCH: 9500SSCT
	SUPPLIES	CHROME PLATED LEVER TYPE 1/4 TURN BALL ANGLE STOP VALVE					
UR-1	URINAL	WALL MOUNTED, ELONGATED RIM, ADA COMPLIANT, WASHOUT BOWL, TOP INLET SPUD, 2" OUTLET	-	3/4"	1 1/4"	2"	AMERICAN STANDARD: 6501.010
	URINAL FLUSH VALVE	3/4" TOP SPUD FOR URINALS, QUIET, EXPOSED MANDREL HANDLE, DIAPHRAGM TYPE, CHROME PLATED, DUAL FILTERED FIXED BYPASS, ADA COMPLIANT NON-HOLD-OPEN HANDLE, 1" I.P.S. SCREWDRIVER BACK CHECK ANGLE STOP, FREE SPINNING VANDAL RESISTANT STOP CAP, ADJUSTABLE TAILPIECE, HIGH BACK PRESSURE VACUUM BREAKER FLUSHING CONNECTION, ONE-PIECE BOTTOM HEX COUPLING					SLOAN: 186-1.0
	URINAL CARRIER	SPECIFICATION "FIXTURE CARRIER, WALL URINAL SUPPORT SYSTEM, TOP AND BOTTOM SUPPORT PLATES," COATED RECTANGULAR STEEL MOUNTING BRIGITS, WELDED FEET, ADJUSTABLE SUPPORT PLATES, MOUNTING FASTENERS, "					ZURN: Z1222
	MOUNTING HEIGHT	24" MAXIMUM A.F.F.					
LAV-1	LAVATORIES	WALL HUNG, VITREOUS CHINA, D-SHAPED BOWL, FRONT OVERFLOW, SELF-DRAINING DECK AREA WITH CONTOURED BACK AND SIDE SPLASH SHIELDS, CONCEALED WALL HANGAR, RECTANGULAR SHAPED LAVATORY, SIZE: VITREOUS CHINA, FRONT OVERFLOW, 3 FAUCET HOLES CENTERED ON 4" CENTERS, LESS SOAP DISPENSER HOLE, ADA COMPLANT, 34" TOP OF LAVATORY TO FINISHED FLOOR COLOR: WHITE	3/8"	3/8"	1 1/4"	1 1/4"	AMERICAN STANDARD: LUCERNE 0355.012
	LAVATORY FAUCET	DUAL HANDLE WITH WRIST BLADES, ADA COMPLIANT, DECK MOUNTED, SOLID BRASS BODY, CHROME PLATED, HANDLE RETURNS TO NEUTRAL POSITION WHEN TURNED OFF, METAL GRID STRAINER, 0.5 GPM AERATOR, 1/2" THREADED MALE INLET SHANKS, 95					AMERICAN STANDARD: HERITAGE 7402.000-172H-V05
	LAVATORY SUPPLIES	CHROME PLATED ANGLE STOPS WITH LOOSE KEY HANDLE, CHROME PLATED FLEXIBLE BRASS RISER, INSULATE ALL EXPOSED WATER LINES AND VALVES					
	LAVATORY WASTE	GRID DRAIN STRAINER, 1 1/4" OFFSET TAILPIECE, 1 1/4" 17 GAUGE CHROME PLATED ADJUSTABLE BRASS P-TRAP WITH CLEANOUT PLUG, 1 1/4" CHROME PLATED BRASS WASTE TO WALL					
	LAVATORY PROTECTIVE PIPE COVERS	ADA COMPLIANT, CHINA WHITE, ANTI-BACTERIA/FUNGAL, MOLDED VINYL, P-TRAP COVER, TWO ANGLE VALVE AND SUPPLY COVERS, 5" OFFSET TAILPIECE WHEEL CHAIR CARRIER COVER					TRUEBRO: 103 E-Z PLUMBEXE: X4444
K-B04	FLOOR MOP SINK	MOLDED STONE, PLAIN CURBS, ONE PIECE 24"x24"x10" SQUARE BASIN, WITH TILING FLANGE	1/2"	1/2"	1 1/4"	2"	FIAT: MSB-2424
	FLOOR MOP SINK FAUCET	WALL MOUNTED HOT AND COLD WATER SERVICE FAUCET EXTENDING 9 3/8" FROM BACK OF WALL FLANGE, VACUUM BREAKER, CHROME PLATED, 3/4" HOSE THREAD ON SPOUT, PAIL HOOK, ADJUSTABLE WALL BRACE, FLAT STAINLESS STEEL STRAINER, 24" LONG X 3" WIDE STAINLESS STEEL MOP BRACKET WITH THREE RUBBER GRIPS, 36" LONG HOSE WITH WALL HANGER					MUSTEE: 63.600A STERN WILLIAMS: T-10-VB
	SUPPLIES	1/2" HOT AND COLD WATER WITH CONCEALED STOP WITH WHEEL HANDLE, 1/2" CHROME PLATED FLEXIBLE BRASS RISER					
	WASTE	DRAIN SHALL BE INTEGRAL STAINLESS STEEL COMBINATION FLAT STRAINER AND LINT BASKET, FACTORY INSTALLED STAINLESS STEEL DRAIN BODY, CAST IRON P-TRAP					
	ACCESSORIES	24" LONG X 3" WIDE STAINLESS STEEL MOP BRACKET WITH THREE RUBBER GRIPS, 36" HOSE WITH HANGER					


Mark		DESCRIPTION	FINAL CONNECTIONS				MANUFACTURER MODEL NUMBER
			HW	CW	V	W	
K-SS3	GENERIC FIXTURE	3/4" DOMESTIC HOT AND COLD WATER CONNECTIONS FOR SHAKE STATION 110 DEG. F. HOT WATER, COORDINATE THE LOCATION AND SIZE OF ALL PLUMBING CONNECTIONS WITH KITCHEN CONNECTION PLANS, MANUFACTURER RECOMMENDATIONS, AND LOCAL REQUIREMENTS PRIOR TO ROUGH-IN. MAKE ANY ADJUSTMENTS NECESSARY TO PROVIDE A FULLY FUNCTIONING FIXTURE.	3/4"	3/4"	—	—	
K-SS3A	GENERIC FIXTURE	3/4" DOMESTIC HOT AND COLD WATER CONNECTIONS FOR SHAKE STATION 110 DEG. F. HOT WATER, COORDINATE THE LOCATION AND SIZE OF ALL PLUMBING CONNECTIONS WITH KITCHEN CONNECTION PLANS, MANUFACTURER RECOMMENDATIONS, AND LOCAL REQUIREMENTS PRIOR TO ROUGH-IN. MAKE ANY ADJUSTMENTS NECESSARY TO PROVIDE A FULLY FUNCTIONING FIXTURE.	3/4"	3/4"	—	—	
K-S10	GENERIC FIXTURE	3/4" DOMESTIC HOT AND COLD WATER CONNECTIONS FOR PREP SINK, 140 DEG. F. HOT SUPPLY, SINGLE FAUCET ROUGH-IN, COORDINATE THE LOCATION AND SIZE OF ALL PLUMBING CONNECTIONS WITH KITCHEN CONNECTION PLANS, MANUFACTURER RECOMMENDATIONS, AND LOCAL REQUIREMENTS PRIOR TO ROUGH-IN. MAKE ANY ADJUSTMENTS NECESSARY TO PROVIDE A FULLY FUNCTIONING FIXTURE.	1/2"	1/2"	—	—	
K-B07	GENERIC FIXTURE	1/2" DOMESTIC COLD WATER CONNECTION FOR SODA FOUNTAIN BAG-N-BOX, PROVIDE DUAL CHECK VALVE FOR CARBONATED BEVERAGE MACHINES (WATTS SD-2 OR EQUAL), PROVIDE BACKFLOW PREVENTION IN ACCORDANCE WITH LOCAL REQUIREMENTS IN AN ACCESSIBLE LOCATION, COORDINATE THE LOCATION AND SIZE OF ALL PLUMBING CONNECTIONS WITH KITCHEN CONNECTION PLANS, MANUFACTURER RECOMMENDATIONS, AND LOCAL REQUIREMENTS PRIOR TO ROUGH-IN. MAKE ANY ADJUSTMENTS NECESSARY TO PROVIDE A FULLY FUNCTIONING FIXTURE	—	1/2"	—	—	
K-B29	GENERIC FIXTURE	1/2" DOMESTIC HOT AND COLD WATER CONNECTIONS FOR KITCHEN HAND SINK — FIXTURE, FAUCET, AND DRAIN BY OTHERS, PROVIDE CHROME PLATED ANGLE STOPS WITH LOOSE KEY HANDLE, CHROMATED PLATED FLEXIBLE BRASS RISER, 1 1/2" 17 GAUGE CHROME PLATED ADJUSTABLE BRASS P-TRAP WITH CLEANOUT PLUG, 1 1/2" NICKEL PLATED BRASS TAILPIECE, RUN WASTE PARALLEL AND AS TIGHT TO WALL AS POSSIBLE, 110 DEG. F. HOT WATER, SINGLE FAUCET ROUGH-IN, COORDINATE THE LOCATION AND SIZE OF ALL PLUMBING CONNECTIONS WITH KITCHEN CONNECTION PLANS, MANUFACTURER RECOMMENDATIONS, AND LOCAL REQUIREMENTS PRIOR TO ROUGH-IN. MAKE ANY ADJUSTMENTS NECESSARY TO PROVIDE A FULLY FUNCTIONING FIXTURE, (1) 1 1/2" DRAIN SANITARY CONNECTION(S)	1/2"	1/2"	1 1/4"	1 1/2"	
K-B38	GENERIC FIXTURE	1/2" DOMESTIC HOT AND COLD WATER CONNECTIONS FOR 3-COMPARTMENT SINK, PROVIDE BACKFLOW PREVENTION IN ACCORDANCE WITH LOCAL REQUIREMENTS IN AN ACCESSIBLE LOCATION (WHERE APPLICABLE), PROVIDE CHEMICAL SANITATION CONNECTION IN ACCORDANCE WITH LOCAL REQUIREMENTS (WHERE APPLICABLE), 140 DEG. F. HOT SUPPLY SINGLE FAUCET ROUGH-IN, COORDINATE THE LOCATION AND SIZE OF ALL PLUMBING CONNECTIONS WITH KITCHEN CONNECTION PLANS, MANUFACTURER RECOMMENDATIONS, AND LOCAL REQUIREMENTS PRIOR TO ROUGH-IN. MAKE ANY ADJUSTMENTS NECESSARY TO PROVIDE A FULLY FUNCTIONING FIXTURE.	1/2"	1/2"	—	—	
K-B85	GENERIC FIXTURE	1/2" DOMESTIC COLD WATER CONNECTION FOR SODA DISPENSER, PROVIDE DUAL CHECK VALVE FOR CARBONATED BEVERAGE MACHINES (WATTS SD-2 OR EQUAL), PROVIDE BACKFLOW PREVENTION IN ACCORDANCE WITH LOCAL REQUIREMENTS IN AN ACCESSIBLE LOCATION, COORDINATE THE LOCATION AND SIZE OF ALL PLUMBING CONNECTIONS WITH KITCHEN CONNECTION PLANS, MANUFACTURER RECOMMENDATIONS, AND LOCAL REQUIREMENTS PRIOR TO ROUGH-IN. MAKE ANY ADJUSTMENTS NECESSARY TO PROVIDE A FULLY FUNCTIONING FIXTURE.	—	1/2"	—	—	
2"FD-1	FLOOR DRAIN	STANDARD STRAINER, COATED CAST IRON, TWO-PIECE BODY, DOUBLE DRAINAGE FLANGE, ADJUSTABLE EXTENSION AS REQUIRED BY APPLICATION, ADJUSTABLE COLLAR WITH SEEPAGE SLOTS, INVERTIBLE NON-PUNCTURING MEMBRANE CLAMP, FLASHING CLAMP WITH 24"x24" 4 LB. LEAD FLASHING FOR FLOOR DRAINS INSTALLED ABOVE SLAB ON GRADE, BOTTOM OUTLET, OUTLET CONNECTION METHOD SHALL BE COMPATIBLE WITH PIPING MATERIALS IN ACCORDANCE WITH THE SPECIFICATIONS, POLISHED NICKEL BRONZE FINISH, 5" DIAMETER ROUND STRAINER, 1/2" TRAP PRIMER CONNECTION	—	—	1 1/4"	2"	JR SMITH: 2010-NB ZURN: 2415B
3"FD-2	FLOOR DRAIN	STANDARD STRAINER, COATED CAST IRON, TWO-PIECE BODY, DOUBLE DRAINAGE FLANGE, ADJUSTABLE EXTENSION AS REQUIRED BY APPLICATION, ADJUSTABLE COLLAR WITH SEEPAGE SLOTS, INVERTIBLE NON-PUNCTURING MEMBRANE CLAMP, FLASHING CLAMP WITH 24"x24" 4 LB. LEAD FLASHING FOR FLOOR DRAINS INSTALLED ABOVE SLAB ON GRADE, BOTTOM OUTLET, OUTLET CONNECTION METHOD SHALL BE COMPATIBLE WITH PIPING MATERIALS IN ACCORDANCE WITH THE SPECIFICATIONS, POLISHED NICKEL BRONZE FINISH, 5" DIAMETER ROUND STRAINER	—	—	1 1/4"	3"	JR SMITH: 2010-NB ZURN: 2415B

Mark		DESCRIPTION	FINAL CONNECTIONS				MANUFACTURER MODEL NUMBER
			HW	CW	V	W	
3"FS-1 3"FS-2	FLOOR SINK	12" x 12" x 7 3/4" DEEP FLOOR SINK, COATED CAST IRON BODY, WHITE ACID-RESISTING PORCELAIN ENAMEL INTERIOR COATING, ABS ANTI-SPLASH DOME, WHITE STRAINER, OUTLET CONNECTION METHOD SHALL BE COMPATIBLE WITH PIPING MATERIALS IN ACCORDANCE WITH THE SPECIFICATIONS, NICKEL BRONZE 3/4 GRATE, SQUARE	—	—	1 1/2"	3"	ZURN: FD2376-T
FCO-1	CLEANOUT — FLOOR	ACID RESISTING COATED CAST IRON BODY, ADJUSTABLE, GAS AND WATER TIGHT ABS TAPERED THREADED INTERNAL CAST IRON PLUG, VANDAL-PROOF FASTENERS, OUTLET CONNECTION METHOD SHALL BE COMPATIBLE WITH PIPING MATERIALS IN ACCORDANCE WITH THE SPECIFICATIONS, MEDIUM DUTY, ROUND SCORRIATED SECURED POLISHED BRONZE FRAME AND COVER WITH ANCHOR FLANGE, WITH "CO" IN COVER, INSTALLED FLUSH WITH FINISHED FLOOR. PROVIDE CARPET MARKERS WHERE INSTALLED BELOW CARPET	—	—	—	4"	ZURN: ZB1400-VP
WCO-1	WALL CLEANOUT	ACID RESISTING COATED CAST IRON CLEANOUT TEE, COUNTERSUNK BRONZE PLUG, ROUND STAINLESS STEEL SECURED ACCESS COVER, ACID RESISTING COATED CAST IRON CLEANOUT TEE, COUNTERSUNK BRONZE PLUG, ROUND STAINLESS STEEL SECURED ACCESS COVER, STANDARD FASTENERS	—	—	—	2"	J.R. SMITH: 4710 WADE: 8480R ZURN: Z1446
TP-1	TRAP PRIMER	PRESSURE ACTIVATED TRAP PRIMER, BRASS CONSTRUCTION, PISTON OPERATED, ADJUSTMENT FOR VARIABLE PRESSURES, INSTALL TRAP PRIMER A MINIMUM OF 12" ABOVE THE TRAP BEING SERVED, PROVIDE AIR GAP FITTING WITH 1/2" MALE NPT INLET FITTING AND 1/2" FEMALE OUTLET FITTING, SINGLE TRAP APPLICATION	—	1/2"	—	—	PRECISION PRODUCTS: — P2-500
	TRAP PRIMER DISTRIBUTION UNIT	COPPER BODY DISTRIBUTION UNIT, 4 - 3/8" FPT BRASS DISCHARGE FITTINGS, 1/2" MALE NPT COMPOSITE INLET, PROVIDE PLUGS AS REQUIRED BY APPLICATION					PRECISION PRODUCTS: — DU-4
WH-1	WALL HYDRANT	ENCASED, ANTI-SIPHON, AUTOMATIC DRAINING, COPPER CASING, ALL BRONZE INTERIOR WALL HYDRANT WITH NON-TURNING OPERATING ROD WITH FREE FLOATING COMPRESSION CLOSURE VALVE, VANDAL-RESISTANT LOOSE TEE HANDLE OPERATING STEM, ADJUSTABLE PACKING NUT, INTEGRAL TAMPER PROOF VACUUM BREAKER, SINGLE TEMPERATURE 3/4" MALE END CONNECTION, CHROME-PLATED BOX AND HINGED COVER WITH LOOSE OPERATING KEY, NON-FREEZE CLIMATE.	—	1/2"	—	—	WOOD FORD: 865-CH 867-CH ZURN: Z1320-C
	MOUNTING HEIGHT	18" MAXIMUM A.F.F.					




PAUL DHANENS • ARCHITECT


ARCHITECT	
<div><p>5100 CALIFORNIA AVE. SUITE 107 BAKERSFIELD, CALIFORNIA 93309 TELEPHONE: (805) 326-8036 FACSIMILE: (805) 326-8037</p></div>	
CONSULTANT	
COPYRIGHT	
<p>PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor assigned to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.</p> <p>NOTICE TO CONTRACTORS Written dimensions on these drawings shall take precedence over scaled dimensions. Contractors shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.</p>	
PROJECT	
TENANT IMPROVEMENT FOR	
<div></div>	
1966 WEST AVE L LANCASTER, CA	
DATE	ISSUED FOR
9-24-10	BUILDING DEPT SUBMITTAL
8-28-19	
NO.	REVISIONS
▲	
▲	
▲	
▲	
PLUMBING	
FILE NAME:	2366A2-0
SHEET	
P-300	




7 PIPE CONDUIT PENETRATION THRU ROOF
NOT TO SCALE




8 WALL CLEANOUT TYPICAL
NOT TO SCALE




4 FLOOR SINK DETAIL
NOT TO SCALE




5 FLOOR DRAIN TRAP PRIMER DETAIL
NOT TO SCALE




6 VENT TERMINATION LEAD FALSHING
NOT TO SCALE



2 THREE COMPARTMENT SINK CONNECTION DETAIL
NOT TO SCALE




2 FLOOR DRAIN DETAIL
NOT TO SCALE



NOTE:
1. PROVIDE 10\"/>

3 FLOOR DRAIN TRAP PRIMER DETAIL
NOT TO SCALE



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE., SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (661) 326-8335
FACSIMILE: (661) 326-8037

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted to any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS:
Written dimensions on these drawings shall take precedence over scaled dimensions. Contractors shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT FOR



1966 WEST AVE L
LANCASTER, CA

DATE	ISSUED FOR
8-24-18	BUILDING DEPT SUBMITTAL
8-28-18	


NO.	REVISIONS
▲	
▲	
▲	
▲	

PLUMBING

FILE NAME: 2366A2-0

SHEET

P-400



PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE., SUITE 107
BAKERSFIELD, CALIFORNIA 93309
TELEPHONE: (661) 326-8936
FACSIMILE: (661) 326-8037

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted in any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS:
Written dimensions on these drawings shall take precedence over noted dimensions. Contractors shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT
FOR



1966 WEST AVE L
LANCASTER, CA

DATE | ISSUED FOR
8-24-18 | BUILDING DEPT SUBMITTAL
6-26-19 |


NO. | REVISIONS
1 |
2 |
3 |
4 |

PLUMBING

FILE NAME: 2366A2-0

SHEET


P-401



ARRANGEMENT SHOWN IS SCHEMATIC. ADJUST TO SUIT ACTUAL CONDITIONS. MAKE FINAL CONNECTION TO EQUIPMENT AS RECOMMENDED BY MANUFACTURER. PROVIDE WELDED FITTINGS/JOINTS IN ANY CONCEALED, UNSLEEVED LOCATION.


6 KITCHEN GAS EQUIPMENT DETAIL

NOT TO SCALE




5 DOMESTIC WATER SERVICE DETAIL

NOT TO SCALE




3 ICE MACHINE CONNECTION DETAIL

NOT TO SCALE




2 AUTOMATIC WATER SOFTENER

NOT TO SCALE




PDI SIZE	PIPE SIZE	FIXTURE UNIT LOAD
A	1 1/2"	1-11
B	3/4"	12-32
C	1"	33-60
D	1-1/4"	61-113
E	1-1/2"	114-154
F	2"	155-330

FIXTURE UNIT TABULATION		
FIXTURE	COLD	HOT
VALVE WATER CLOSET	10	--
TANK WATER CLOSET	5	--
URINAL	5	--
LAVATORY/SINK	1.5	1.5
JANITOR'S SINK	3	3
SHOWER/BATHTUB	2	2



4 WATER HAMMER ARRESTERS

NOT TO SCALE



1 WATER HEATER HOOK-UP

NOT TO SCALE

SECTION 22000 – PLUMBING GENERAL CONDITIONS

PART 1 GENERAL

1.01 SUMMARY

- A. This section supplements all sections of the Specifications for Division 22 and shall apply to all phases of work hereinafter specified, shown on the Contract Documents, or required to provide a complete installation of approved plumbing systems.
- B. The Drawings, General Conditions and General Provisions of the Contract apply to this Section and the other Sections of Division 22 of the specifications. Where conflicts arise between these documents, the more stringent provision will be applicable, subject to the interpretation of the Engineer.
- C. Furnish all labor, material, services, and skilled supervision necessary for the construction, erection, installation, connections, testing, and adjustment of all materials and plumbing equipment specified herein, or shown or noted on the Drawings, and its delivery to the Owner, complete in all respects and ready for use.
- D. Products furnished but not installed under this section:
- Where plans indicate fixtures or equipment will be furnished by this Contractor for installation by other Contractors, this Contractor shall furnish all such equipment, complete in all respects and ready for installation.
 - Drawings, instructions, and manuals supplied with equipment furnished under Division 22, but installed under other Divisions shall be carefully preserved and turned over to the installing Contractor.
- E. Products installed but not furnished under this section:
- Where plans indicate fixtures or equipment will be furnished by others, this Contractor shall provide all rough-in and supplies and shall connect such equipment to the plumbing systems.
 - Drawings, instructions, and manuals supplied with equipment furnished under separate Divisions but installed under Division 22 shall be carefully preserved and turned over to the Architect.

1.02 DEFINITIONS

- A. "Work" is hereby defined as, "The construction and services required by the Contract Documents whether completed or partially completed and includes all labor, materials, equipment, and services provided or to be provided by the Contractor to fulfill the Contractor's obligations. The work may constitute the whole or a part of the project."
- B. "Furnish" is hereby defined as, "To supply and deliver, unload, and inspect for damage."
- C. "Install" is hereby defined as, "To unpack, assemble, erect, apply, place, finish, cure, protect, clean, connect, and place into operation into the work."
- D. "Provide" is hereby defined as, "To furnish and install."
- E. "Connect" is hereby defined as, "To bring service to the equipment and make final attachment including necessary switches, outlets, boxes, terminations, etc."
- F. "Concealed" is hereby defined as, "Hidden from sight in chases, furred spaces, shafts, hung ceilings, embedded in construction, in crawl spaces, or buried."
- G. "Exposed" is hereby defined as, "Not installed underground nor concealed as defined by the Specifications."
- H. "Drawings" is hereby defined as, "All plans, details, equipment schedules, diagrams, sketches, etc. issued for the construction of the work."
- I. Subgrade Elevations: 4 inches below finish grade elevations indicated on drawings, unless otherwise indicated.
- J. Finish Grade Elevations: 6 inches above subgrade elevations indicated on drawings, unless otherwise indicated.

1.03 CODES AND STANDARDS

- A. Perform work in accordance with the applicable Building Code, Electrical Code, Fire Code, Mechanical Code, Plumbing Code, Energy Code, and all other applicable codes, amendments, and ordinances. Also perform all work in accordance with the Americans with Disabilities Act (ADA) and the Authority Having Jurisdiction (AHJ) including Fire Marshal(s).
- B. Perform work in accordance with Landlord requirements, including any Tenant Criteria Manuals and Lease Exhibits, where applicable.
- C. Perform work in accordance with the applicable utility companies serving the project. Make all arrangements with the utility companies for proper coordination of the work.
- D. Recognized Standards: Design, manufacture, testing and method of installation of all apparatus and materials furnished under the requirements of these Specifications shall conform to the latest publications or standard rules of Underwriters Laboratories, Inc. (U.L.), American Society for Testing and Materials (ASTM), American National Standards Institute (ANSI), and National Electrical Code (NEC).
- E. The Contract Documents shall take precedence where the Contract Documents exceed code, Landlord, utility, or recognized standards requirements.

1.04 PERMITS AND FEES

- A. Permits, licenses, fees, inspections and arrangements required for the work under this Contract shall be obtained by the Contractor at his expense, unless otherwise indicated.
- B. All fees and scheduling associated with obtaining an accurate water flow test shall be at the Contractor's expense.

1.05 CONTRACT DRAWINGS

- A. The Contractor is responsible to obtain, fully understand, and coordinate the work with the complete set of Contract Documents. Any required corrections, including all associated costs, arising from issues caused by the Contractor's failure to understand and/or coordinate the work with the complete set of Contract Documents are the Contractor's sole responsibility.
- B. Work under these sections is diagrammatic unless indicated otherwise and is intended to convey the scope of work and indicate the general arrangement of piping, equipment, and accessories. Follow these drawings in laying out the work and verify spaces for the installation of these materials and equipment. Whenever a question exists as to the exact intended location of pipe, sprinklers, or equipment, obtain instructions from the Architect before proceeding with the work.
- C. Notify the Architect/Engineer for resolution if a discrepancy is discovered within the Contract Documents. Failure of the Contractor to notify the Architect/Engineer of discrepancies shall result in the rejection because the Contractor is responsible and subject to the Architect/Engineer's review and possible rejection. Should the Architect/Engineer reject a discrepancy resolution of which they were not notified, the Contractor is fully responsible to correct the installation, including all associated costs, until approval of the installation is given by the Architect/Engineer.

1.06 EXISTING CONDITIONS

- A. Verify all existing conditions prior to beginning work.
- B. Any existing conditions indicated in the Contract Documents are based on information drawings provided by others and possibly limited field verification. The Contractor shall adjust for actual field conditions at no additional expense to the Owner.
- C. The Contractor shall visit the project site, review existing conditions against the Contract Documents, and familiarize himself with the work prior to bidding and start of the work. By signing the Contract, the Contractor acknowledges the site visit has been completed and the existing conditions are accepted.
- D. The Contractor shall notify the Architect of major discrepancies in writing so the appropriate modifications to the design can be made without delay to the project. The Contractor assumes full responsibility of adjusting for discrepancies of which the Architect is not informed.
- F. The Owner shall have first salvage right on all demolished equipment and materials. The Contractor shall dispose of all demolished equipment and materials the Owner rejects.
- G. The Contractor shall notify the Architect/Engineer of field discrepancies in writing so the appropriate modifications to the design can be made without delay to the project. The Contractor assumes full responsibility of adjusting for discrepancies of which the Architect/Engineer is not informed.
- H. Where connections are made between new work and existing work, the connections shall be made by using materials and methods to suit the actual conditions.
- I. Where existing conditions are shown to be removed, by means of a hatched pattern, on the Drawings, the Contractor shall perform all work required for removal. Existing pipe run-outs shall be removed all the way back to mains and capped using appropriate methods.
- J. Where existing work is to be modified, it shall be done in conformance with these specifications. Materials used shall be same as existing except where specified otherwise.

1.07 SUBMITTALS

- A. Shop Drawings:
- Furnish the Architect/Engineer shop drawing portfolios containing names of manufacturer and cut sheets of equipment to be used on the project. Use manufacturer's specification sheets identified by number indicated on drawings or schedules. Indicate catalog number on the cut sheets. As applicable, provide construction data, weight and dimensional data, performance data and listing data as part of the shop drawing submittal. Provide shop drawings for:
 - Plumbing fixtures and equipment.

- b. Plumbing materials and accessories.
- c. Product Data: Provide manufacturers catalogue information. Indicate valve data and ratings.
2. Submittals are reviewed only for general compliance with the Contract Documents. Dimensions, quantities and details are not checked during submittal review. Review of the submittals does not relieve the Contractor of the responsibility for providing all materials, equipment and accessories necessary for a complete and operational system meeting the requirements of the project and the intent of the Contract Documents. The responsibility for coordination of substituted materials and equipment lies solely with the substituting Contractor.
3. Approval shall not relieve the Contractor from responsibility for errors on the shop drawings.
4. If the shop drawings deviate from the contract documents, the Contractor shall advise the Engineer of the deviations in writing accompanying the shop drawings, including the reasons for the deviations.
- B. Project Record Documents: Record actual locations of components and tag numbering.
- C. Operation and Maintenance Data: Include installation instructions and spare parts lists.
- D. Maintenance Data: Include assembly drawings, bearing data including replacement sizes, and lubrication instructions.

1.08 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum five years experience.
- B. Installer Qualifications: Company specializing in performing the work of this section with minimum five years experience, approved by manufacturer.
- C. Products:
- Listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.
 - Listed and classified by the local Department of Buildings and furnished with an acceptance number, where applicable.
 - Listed and classified by the Landlord's and/or Owner's insurance carrier, where applicable.
- D. All equipment and components shall be free of all rust/corrosion or any visible damage. All items not complying with this requirement shall be replaced without any change in the Contract amount.
- E. Equipment performance and accessories shall be as scheduled on the Drawings and specified herein. Inclusion in both locations is not a prerequisite to inclusion in the Contract. Equipment and accessories specified in either location shall be included in the Contract. Provide all necessary accessories and connections as required for a complete, functional system, including all required components reasonably inferred to as necessary although such components may or may not be specifically indicated in the Contract Documents.
- F. Code or utility company requirements shall supersede any conflicting requirements of this section.
- G. Fill Composition Test Reports: Results of laboratory tests on actual materials used; Compaction Density Test Reports.
- 1.09 DELIVERY, STORAGE, AND HANDLING
- A. Deliver and store valves in shipping containers, with labeling in place.
- B. Provide temporary protective coating on cast iron and steel valves.
- C. Provide temporary end caps and closures on piping and fittings. Maintain in place until installation.
- D. Protect motors stored on site from weather and moisture by maintaining factory covers and suitable weather-proof covering. For extended outdoor storage, remove motors from equipment and store separately.
- E. Equipment: Protect equipment from physical damage by storing off site until the project is ready for immediate installation. Provide temporary caps on all pipes to prevent debris from entering the pipe.

1.10 WARRANTY AND GUARANTEE

- A. Additional warranty and guarantee terms in excess of this requirement are specified within the individual sections of Division 22.
- B. Provide five year manufacturer warranty for domestic water heaters and packaged water heating systems.
- C. Provide one year manufacturer warranty for pumps.

PART 2 PRODUCTS

2.01 SUBSTITUTIONS

- A. The manufacturers listed are listed to set minimum standards for quality, design, and functionality. The products of other manufacturers may be submitted, at the Contractor's option, during shop drawing review unless indicated otherwise. The products of other manufacturers shall meet or exceed all requirements of the Contract Documents. The Contractor accepts all responsibility for costs and coordination issues arising out of the substitution of materials or equipment, and the coordination of such substitutions with all other contractors and subcontractors.

PART 3 EXECUTION

3.01 COORDINATION OF WORK

- A. Examine the Contract Documents as a whole for the work of other trades. Coordinate all work accordingly.
- B. Work lines and established heights shall be in strict accordance with architectural drawings and specifications insofar as these drawings and specifications extend. Verify all dimensions shown and establish all elevations and detailed dimensions not shown.
- C. Promptly report to the Architect any delay or difficulties encountered in the installation of the work, which might prevent prompt and proper installation, or make it unsuitable to connect with or receive the work of others. Failure to so report shall constitute an acceptance of the work of other trades as being fit and proper for the execution of this work.
- D. Plan, lay out, and coordinate the work with all trades well enough in advance so that it proceeds with a minimum of interference to work that has not been completed and work that is in progress. Inform all trades of openings required for the work and provide all special frames, sleeves, and anchor bolts required. The fire suppression system layout may be altered to suit the conditions, prior to the installation of any work and without additional cost to the Owner. Conflicts arising from lack of coordination shall be this Contractor's responsibility.
- E. Wherever pipe runs in or above ceilings or walls, the Contractor shall arrange the run of pipe in such a manner that it does not interfere with grilles, diffusers, outlet boxes, luminaires, or other ceiling mounted items.
- F. Install systems, materials and equipment to provide for maximum headroom, where no ceiling height is established or indicated on the Drawings. Maintain access to equipment requiring service when selecting mounting elevations.
- G. Install systems, materials and equipment level and plumb, parallel and perpendicular to building lines where exposed to view, unless otherwise indicated.
- H. Conflicts arising from lack of coordination shall be this Contractor's responsibility. The Plumbing Contractor shall pay for all extra cutting and patching made necessary by his failure to properly direct such work at the correct time.
- I. Perform all work in conformity with the Contract Documents and afford other trades reasonable opportunity for the execution of their work. Properly connect and coordinate this work with the work of other trades at such time and in such a manner as not to delay or interfere with their work.
- J. Manufacturer's instruction sheets shall be followed explicitly in the installation of all equipment. Where manufacturer's instruction sheets conflict with requirements of these specifications or the Drawings, such conflicts shall be brought to the attention of the Architect/Engineer for clarification.
- K. All roofing penetrations shall be flashed and weather sealed by the roofing manufacturer's authorized roofing contractor at this Contractor's expense. This Contractor shall contract with the factory authorized roofing contractor for the specific roofing system applicable to this Project. The use of an unauthorized roofing contractor may result in removal and replacement of the penetration systems at this Contractor's expense.
- L. Although all such work is not specifically indicated, furnish and install all supplementary or miscellaneous items, appurtenances and devices incidental to or necessary for a sound, secure and complete installation.
- M. Verify and coordinate all requirements and installation details of all materials and equipment that are to be furnished under other Divisions and installed or connected under Division 22 prior to rough-in. Conflicts arising from lack of coordination shall be this Contractor's responsibility. As such, the Contractor is responsible to:
- Obtain and review shop drawings, product data, manufacturer's wiring diagrams, and manufacturer's instructions for equipment furnished under other sections.
 - Determine connection locations and requirements.
 - Sequence rough-in of plumbing connections to coordinate with installation of equipment.

3.02 COORDINATION DRAWINGS

- A. Prepare coordination drawings to a scale of 1/4"=1'-0" or larger; detailing major elements, components, and systems of plumbing equipment and materials in

locations where space is limited for installation and access and where sequencing and coordination of installations are of importance to the efficient flow of the work, including (but not necessarily limited to) the following:

- Indicate the proposed locations of conduits, equipment, and materials. Include the following:
 - Clearances required for maintaining Code required working space.
 - Equipment connections and support details.
 - Exterior wall and foundation penetrations.
 - Fire-rated wall and floor penetrations.
 - Sizes and location of required concrete pads and bases.
 - Indicate scheduling, sequencing, movement, and positioning of large equipment into the building during construction.
 - Prepare floor plans, elevations, and details to indicate penetrations in floors, walls, and ceilings and their relationship to other penetrations and installations.

3.03 EXAMINATION

- A. Verify field measurements are as indicated on the Drawings.
- B. Verify all pipe locations and sizes in field prior to fabrication or installation.
- C. Verify all equipment locations in field prior to installation. Coordinate final locations with all trades.

3.04 INTERFACE WITH OTHER PRODUCTS

- A. Install all pipe, equipment, and accessories to preserve fire resistance rating of partitions and other elements, using materials and methods specified.

3.05 FIELD QUALITY CONTROL

- A. Provide tests as necessary to establish the adequacy, quality, safety, completed status, and suitable operation of each system. Tests shall be conducted under the supervision of the Architect.
- B. Install all equipment, devices, pipe, and materials securely and in a neat and workmanlike manner in accordance with all applicable standards and codes.
- C. Install all equipment, pipe, and materials plumb and level and align and adjust for satisfactory operation.
- D. Install all equipment, pipe, and materials in accordance with the manufacturer's instructions and recommendations.
- E. Inspect all equipment, pipe, and materials for defects.

3.06 ERECTION

- A. Rigging:
- The Plumbing Contractor shall arrange for all labor and equipment required for the proper installation of the plumbing equipment in the locations indicated on the Drawings. Where crane rental or other erection is required, such costs shall be included in the Plumbing Contract, unless specific arrangements are made with the General Contractor to cover these costs.
- B. Supplemental Framing:

- Provide the design, fabrication, and erection of supplementary structural framing required for attachment of hangers or other devices supporting plumbing equipment. Provide framing members of standard rolled steel shapes, A-36 steel. Provide members welded to structural members equal to the specification for the main structural member. Provide "simple beam" type framing with end connections welded or bolted for shear loads. Use cantilevers when detailed or specifically approved by the Architect/Engineer. The Architect/Engineer's approval is required for location of supplementary framing. Use only certified welders. Design framing members for their actual loads, with allowable stresses specified by AISI, without excessive deflection and with consideration for rigidity under vibration, in accordance with standard structural practices. Show on shop drawing supplementary framing, including design loads, member size and location.

3.07 CUTTING, PATCHING, AND PIERCING

- A. Cutting of openings and installation of sleeves or frames through walls and surfaces shall be done in a neat workmanlike manner. Openings shall be cut only as large as required for the installation; sleeves and/or frames installed flush with finished surfaces and grouted in place. Surfaces around openings shall be left smooth and finished to match surrounding surface.
- B. Obtain written permission of the Architect/Engineer before cutting or piercing structural members. Use craftsmen skilled in their respective trades for cutting, fitting, repairing, patching of plaster, and finishing of materials including carpentry work, metal work or concrete work required for this work.
- C. Do not weaken walls, partitions, or floors with cutting. Holes required to be cut in floors must be drilled without breaking out around the holes. The Architect/Engineer will determine suitability of patching and/or refinishing requirements.
- D. The Plumbing Contractor is responsible for patching of all openings resulting from the installation or removal of plumbing equipment or materials.
- E. Provide all partitions or dust barriers adequate to prevent the spread of dust and dirt to adjacent areas.
- F. Patch existing finished surfaces and building components using new materials matching existing materials and experienced Subcontractors.
- G. Fire and Smoke Partition Penetrations: The Contractor shall familiarize himself with all fire rated construction and install his work so as to maintain the integrity of the fire code rating. Maintain rating of fire rated and smoke rated construction. Seal annular space around conduits. For fire and smoke rated floors, walls and partitions, use UL listed material that maintains fire rated wall and floor integrity.

3.08 CLEANING AND REPAIR

- A. Clean plumbing parts to remove harmful materials.
- B. Clean exposed surfaces of all pipe, equipment, and accessories of all dirt, debris, splatter, and other deleterious materials. Follow the manufacturer's recommendations for cleaning as applicable.
- C. Repair or replace damaged pipe, equipment, and accessories, as directed by and to the satisfaction of the Architect, where marring or disfigurement has occurred. All pipe, equipment, and accessories shall be new.

3.09 TESTING AND INSPECTION

- A. Upon completion, the entire system shall be tested under operating conditions.
- All equipment shall be tested under service conditions and proven to operate properly and noiselessly.
 - All additional tests as required throughout this Specification shall be completed with results reported back to the Architect/Engineer for review.
- B. Operate all equipment, after installation and connection, to inspect for improper connections and operation and correct deficiencies as required.
- C. Inspection:
- Upon completion of the work, the Contractor shall obtain certificates of inspection and approval from all City and State Authorities Having Jurisdiction.

3.10 PROJECT CLOSEOUT

- A. Project Record Documents: At project closeout, provide one printed copy and one electronic copy of project record drawings to the Owner. Information contained on project record drawings shall include, as a minimum,:
- Actual locations of all pipe, equipment, accessories, etc.
 - Actual pipe sizes and elevations.
 - Actual routing of all underfloor or below grade piping.
- B. Operation and Maintenance Data: At project closeout, submit to the Architect two copies of descriptive literature, maintenance and operation data for all piping, equipment, accessories, and materials used. Include maintenance procedures, intervals, and parts list of each item installed under this contract. Include all manufacturer's guarantees and warranties.

END OF SECTION

SECTION 220516 – EXPANSION FITTINGS AND LOOPS FOR PLUMBING PIPING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Flexible pipe connectors; Pipe loops, offsets, and swing joints.

PART 2 PRODUCTS

2.01 FLEXIBLE PIPE CONNECTORS – COPPER PIPING

- A. Manufacturer: Mercer Rubber Company; Metraflex Company.
- B. Inner Hose: Bronze; Exterior Sleeve: Braided bronze; Pressure Rating: 125 psi and 450 degrees F; Joint: As specified for pipe joints; Size: Use pipe sized units; Maximum offset: 1 inch on each side of installed center line; Application: Copper piping.


2.02 FLEXIBLE PIPE CONNECTORS – STEEL PIPING

- A. Manufacturer: Mercer Rubber Company; Metraflex Company.
- B. Inner Hose: Pressure Rating: 125 psi and 450 degrees F; Joint: As specified for pipe joints; Size: Use pipe sized units; Maximum offset: 1 inch on each side of installed center line; Application: Steel piping.



PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.



PAUL DHANENS • ARCHITECT

ARCHITECT	
	
5100 CALIFORNIA AVE., SUITE 107 BAKERSFIELD, CALIFORNIA 93309 TELEPHONE: (805) 338-8395 FAC SIMILE: (805) 326-8037	
CONSULTANT	
COPYRIGHT	
PAUL DHANENS ARCHITECT 7 expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, electronic or other form, nor may they be used in any way without the express written consent of PAUL DHANENS ARCHITECT 7.	
NOTICE TO CONTRACTORS: Neither the drawings nor these drawings shall take precedence over accepted dimensions. Contractors shall verify all dimensions and shall notify the architect of all discrepancies or any discrepancies or field variations discussed.	
PROJECT	
TENANT IMPROVEMENT FOR	
	
1966 WEST AVE L LANCASTER, CA	
DATE	ISSUED FOR
8-24-18	BUILDING DEPT SUBMITTAL
8-28-18	
NO. REVISIONS	
▲	
▲	
▲	
▲	
PLUMBING	
FILE NAME:	2366A2-0
SHEET	
P-500	

- Push-on, using ASTM F 477 elastomeric gaskets.
- 2.11 STORM WATER PIPING, ABOVE GRADE
- A. Cast Iron Pipe: CSDI 301, hubless, service weight; Fittings: Cast iron; Joints: Neoprene gaskets and stainless steel clamp-and-shield assemblies.
- D. ABS Pipe: ASTM D 2680 or ASTM D 2751; Fittings: ABS; Joints: Solvent welded with ASTM D 2235 cement.
- 2.14 NATURAL GAS PIPING, ABOVE GRADE
- A. Steel Pipe: ASTM A 53/A 53M Schedule 40 black; Fittings: 3" and larger shall be ASME B16.3, malleable iron, or ASTM A 234/A 234M, wrought steel welding type. Threaded fittings may be used on piping 2 1/2" and smaller, except where noted on the drawings or required by code to be welded; Joints: NFPA 54, threaded or welded to ASME B31.1.
- B. Copper Tube: ASTM B 88 (ASTM B 88M), Type K (A) or L (B) annealed; Fittings: ASME B16.28, cast bronze joints: Flared.
- 2.18 FLANGES, UNIONS, AND COUPLINGS
- A. Unions for Pipe Sizes 3 Inches and Under: Ferrous pipe: Class 150 malleable iron threaded unions; Copper tube and pipe: Class 150 bronze unions with soldered joints.
- B. Flanges for Pipe Size Over 1 Inch: Ferrous pipe: Class 150 malleable iron threaded or forged steel slip-on flanges; preformed neoprene gaskets; Copper tube and pipe: Class 150 slip-on bronze flanges; preformed neoprene gaskets.
- C. Grooved and Shouldered Pipe End Couplings: Housing: Malleable iron clamps to engage and lock, designed to permit some angular deflection, contraction, and expansion; steel bolts, nuts, and washers; galvanized for galvanized pipe; Sealing gasket: C shape composition sealing gasket.
- D. Dielectric Unions with polyimide or plated steel threaded end, copper solder end, water impervious isolation barrier.
- 2.19 PIPE HANGERS AND SUPPORTS
- A. Plumbing Piping – Drain, Waste, and Vent: Conform to MSS SP–58; Hangers for Pipe Sizes 1/2 Inch to 1–1/2 Inches: Malleable iron, adjustable swivel, split ring; Hangers for Pipe Sizes 2 Inches and Over: Carbon steel, adjustable, clevis; Multiple or Trapeze Hangers: Steel channels with welded spacers and hanger rods; Wall Support for Pipe Sizes to 3 Inches: Cast iron hook; Wall Support for Pipe Sizes 4 Inches and Over: Welded steel bracket and wrought steel clamp; Vertical Support: Steel riser clamp; Floor Support: Cast iron adjustable pipe saddle, lock nut, nipple, floor flange, and concrete pier or steel support; Copper Pipe Support: Carbon steel ring, adjustable, copper plated.
- B. Plumbing Piping – Water and Gas: Conform to MSS SP–58; Hangers for Pipe Sizes 1/2 inch to 1–1/2 inches: Malleable iron, adjustable swivel, split ring; Hangers for Cold Pipe Sizes 2 Inches and Over: Carbon steel, adjustable, clevis; Hangers for Hot Pipe Sizes 2 Inches to 4 Inches: Carbon steel, adjustable, clevis; Hangers for Hot Pipe Sizes 6 Inches and Over: Adjustable steel yoke, cast iron pipe roll, double hanger; Multiple or Trapeze Hangers: Steel channels with welded supports or spacers and hanger rods; Multiple or Trapeze Hangers: Steel channels with welded supports or spacers and hanger rods, cast iron roll; Wall Support for Pipe Sizes to 3 Inches: Cast iron hook; Wall Support for Pipe Sizes 4 Inches and Over: Welded steel bracket and wrought steel clamp; Wall Support for Hot Pipe Sizes 6 Inches and Over: Welded steel bracket and wrought steel clamp with adjustable steel yoke and cast iron pipe roll; Vertical Support: Steel riser clamp; Floor Support for Cold Pipe: Cast iron adjustable pipe saddle, lock nut, nipple, floor flange, and concrete pier or steel support; Floor Support for Hot Pipe Sizes to 4 Inches: Cast iron adjustable pipe saddle, locknut, nipple, floor flange, and concrete pier or steel support; Floor Support for Hot Pipe Sizes 6 Inches and Over: Adjustable cast iron pipe roll and stand, steel screws, and concrete pier or steel support; Copper Pipe Support: Carbon steel ring, adjustable, copper plated.
- 2.20 GATE VALVES (Exterior Utility Service Only)
- A. Manufacturers: Conbraco Industries; Nibco, Inc.; Milwaukee Valve Company.
- B. Up To and Including 3 Inches: MSS SP–80, Class 125, bronze body, bronze trim, rising stem, handwheel, inside screw, solid wedge disc, solder or threaded ends. Provide extension to grade and valve box per local jurisdiction and utility company standards. Post-indicator type were used for fire protection service or when indicated on the Drawings.
- C. 2 Inches and Larger: MSS SP–70, Class 125, iron body, bronze trim, outside screw and yoke, handwheel, solid wedge disc, flanged ends. Provide extension to grade and valve box per local jurisdiction and utility company standards. Post-indicator type were used for fire protection service or when indicated on the Drawings.
- 2.22 BALL VALVES
- A. Manufacturers: Conbraco Industries; Nibco, Inc.; Milwaukee Valve Company.
- B. Construction, 4 Inches and Smaller: MSS SP–110, Class 150, 400 psi CWP, bronze, two piece body, chrome plated brass ball, regular port, teflon seats and stuffing box ring, blow-out proof stem, lever handle, solder or threaded ends.
- 2.24 BUTTERFLY VALVES
- A. Manufacturers: Hammond Valve; Crane Co.; Milwaukee Valve Company.
- B. Construction 1–1/2 Inches and Larger: MSS SP–67, 200 psi CWP, cast or ductile iron body, nickel-plated ductile iron disc, resilient replaceable EPDM seat, wafer, lug, or grooved ends, extended neck, 10 position lever handle.
- C. Provide gear operators for valves 8 inches and larger, and chain-wheel operators for valves mounted over 8 feet above floor.
- 2.25 FLOW CONTROLS
- A. Manufacturers: ITT Bell & Gossett; Griswold Controls; Taco, Inc.
- B. Construction: Class 125, brass or bronze body with union on inlet, temperature and pressure test plug on inlet and outlet.
- C. Calibration: Automatically control flow within 5 percent of selected rating, over operating pressure range of 10 times minimum pressure required for control, maximum minimum pressure 3.5 psi.
- 2.26 SWING CHECK VALVES
- A. Manufacturers: Hammond Valve; Nibco, Inc.; Milwaukee Valve Company.
- B. Up to 3 Inches: MSS SP–80, Class 125, bronze body and cap, bronze swing disc with rubber seat, solder or threaded ends.
- C. Over 2 Inches: MSS SP–71, Class 125, iron body, bronze swing disc, renewable disc seal and seat, flanged or grooved ends.
- 2.28 WATER PRESSURE REDUCING VALVES
- A. Manufacturers: Amtrol Inc; Cla-Val Co; Watts Regulator Company.
- B. Up to 2 Inches: MSS SP–80, bronze body, stainless steel and thermoplastic internal parts, fabric reinforced diaphragm, strainer, threaded single union ends.
- C. Over 2 Inches: MSS SP–85, cast iron body, bronze body, bronze flanged, elastomeric diaphragm and seat disc, flanged.
- 2.29 RELIEF VALVES
- A. Pressure Relief: Manufacturers: Cla-Val Co; Henry Technologies; Watts Regulator Company; AGA Z21.22 certified, bronze body, teflon seat, steel stem and springs, automatic, direct pressure actuated.
- B. Temperature and Pressure Relief: Manufacturers: Cla-Val Co; Henry Technologies; Watts Regulator Company; AGA Z21.22 certified, bronze body, teflon seat, stainless steel stem and springs, automatic, direct pressure actuated, temperature relief maximum 210 degrees F, capacity ASME (BPV IV) certified and labeled.
- 2.30 STRAINERS
- A. Manufacturers: Armstrong International, Inc.; Green County Filtration; WEAMCO.
- B. Size 2 inch and Under: Threaded brass body for 175 psi CWP; Y pattern with 1/32 inch stainless steel perforated screen.
2. Class 150, threaded bronze body 300 psi CWP; Y pattern with 1/32 inch stainless steel perforated screen.
- C. Size 1–1/2 inch to 4 inch: Class 125, flanged iron body, Y pattern with 1/16 inch stainless steel perforated screen.
- D. Size 5 inch and Larger: Class 125, flanged iron body, basket pattern with 1/8 inch stainless steel perforated screen.
- PART 3 EXECUTION
- 3.01 EXAMINATION
- A. Verify that excavations are to required grade, dry, and not over-excavated.
- 3.02 PREPARATION
- A. Ream pipe and tube ends. Remove burrs. Bevel plain end ferrous pipe.
- B. Remove scale and dirt, on inside and outside, before assembly.
- C. Prepare piping connections to equipment with flanges or unions.
- 3.03 INSTALLATION
- A. Install in accordance with manufacturer's instructions.
- B. Provide non-conducting dielectric connections wherever jointing dissimilar metals.
- C. Route piping in orderly manner and maintain gradient. Route parallel and perpendicular to walls.
- D. Install piping to maintain headroom, conserve space, and not interfere with use of space.
- E. Group piping whenever practical at common elevations.
- F. Install piping to allow for expansion and contraction without stressing pipe, joints, or connected equipment.
- G. Provide clearance in hangers and from structure and other equipment for installation of insulation and access to valves and fittings.
- H. Locate all valves and control elements in accessible areas wherever possible to avoid access doors. Provide access where valves and fittings are not exposed or located in accessible areas. Provide ceiling access doors for access to all valves and control elements located above inaccessible ceiling areas. Provide minimum 12



- x 12 inch size for hand access, 18 x 18 inch size for shoulder access, and as indicated. Provide 4 x 4 inch for shut off valves only. Provide rated access doors where installed in fire rated construction. Review locations prior to fabrication.
- I. Establish elevations of buried piping outside the building to ensure not less than the maximum local frost depth cover. Install tracer wire on all plastic piping outside the building.
- J. Install vent piping penetrating roofed areas to maintain integrity of roof assembly.
- K. All roofing penetrations shall be flashed and weather sealed by the roofing manufacturer's authorized roofing contractor at this Contractor's expense. This Contractor shall contract with the factory authorized roofing contractor for the specific roofing system applicable to this Project. The use of an unauthorized roofing contractor may result in removal and replacement of the penetration systems at this Contractor's expense.
- L. All sanitary vent system terminations shall be a minimum of ten feet from any fresh air intake and twenty-five feet on medical facilities (hospitals, clinics, etc.)
- M. Where pipe support members are welded to structural building framing, scrape, brush clean, and apply one coat of zinc rich primer to welding.
- N. Provide support for utility meters in accordance with requirements of utility companies.
- O. Prepare exposed, unfinished pipe, fittings, supports, and accessories ready for finish painting.
- P. Paint all exterior above grade piping with a minimum of two coats of paint, color to match roof or wall surface to which it is attached; Copper pipe Apply vinyl etch primer immediately following cleaning, EXT 5.54 Alkyd: Vinyl Wash Primer MPI #80, Alkyd MPI #8, 9 or 94, Semi-gloss; Steel pipe: Apply alkyd metal primer immediately following cleaning, EXT 5.10 Alkyd: Alkyd Metal Primer MPI #79, Alkyd MPI # 94, semi-gloss; Plastic pipe: Apply alkyd bonding primer immediately following cleaning, EXT 6.8B Alkyd: Bonding Primer MPI #17 or 63, Alkyd MPI #8, 9 or 94.
- Q. Excavate, bedding and backfill shall be in accordance with applicable sections of this Specification.
- R. Pipe vents from gas pressure reducing valves to outdoors and terminate in weather proof hood, unless of the ventless design and approved by the local jurisdiction and the local utility company regulates.
- S. The use of sanitary tee fittings will not be permitted. Utilize wye fittings in lieu of tee fittings for all intersections of drainage piping.
- T. Provide sleeves when penetrating footings, masonry walls and floors. Seal and fire stop pipe and sleeve penetrations to achieve fire resistance equivalent to fire separation required. All penetrations through footings and floors shall be sealed water tight.
- U. Wherever piping is located within 1.5 inches of the nearest edge of studs, joists, rafters or similar members, provide minimum 0.062 inch thick steel protective shield plates extending 2" above and below the pipe being protected. Shield plates may be omitted on cast iron piping only.
- V. Inserts: Provide inserts for placement in concrete formwork; Provide inserts for suspending hangers from reinforced concrete slabs and sides of reinforced concrete beams; Provide hooked rod to concrete reinforcement section for inserts carrying pipe over 4 inches; Where concrete slabs form finished ceiling, locate inserts flush with slab surface; Where inserts are omitted, drill through concrete slab from below and provide through-bolt with recessed square steel plate and nut recessed into and grouted flush with slab.
- W. Pipe Hangers and Supports: Install in accordance with ASME B31.9, ASTM F 708, and MSS SP–89; Support horizontal piping as scheduled; Install hangers to provide minimum 1/2 inch space between finished covering and adjacent work; Place hangers within 12 inches of each horizontal elbow; Use hangers with 1–1/2 inch minimum vertical adjustment. Design hangers for pipe movement without disengagement of supported pipe; Support vertical piping at every other floor. Support riser piping independently of connected horizontal piping; Where several pipes can be installed in parallel and at same elevation, provide multiple or trapeze hangers; Provide copper plated hangers and supports for copper piping; Prime cast exposed steel hangers and supports. Hangers and supports located in crawl spaces, pipe shafts, and suspended ceiling spaces are not considered exposed; Provide hangers adjacent to motor driven equipment with vibration isolation; Support cast iron drainage piping at every joint.
- 3.04 APPLICATION
- A. Install unions downstream of valves and at equipment or apparatus connections.
- B. Install ball or butterfly valves for shut-off and to isolate equipment, part of systems, or vertical risers.
- C. Install globe, ball, or butterfly valves for throttling, bypass, or manual flow control services.
- D. Provide lug and butterfly valves adjacent to equipment when provided to isolate equipment.
- E. Provide spring loaded check valves on discharge of water pumps.
- F. Provide plug or gas service rated ball valves in natural gas systems for shut-off service.
- G. Provide plug or gas service rated ball valves in propane gas systems for shut-off service.
- H. Provide automatic flow controls valves in water recirculating systems where indicated.
- I. Provide spring loaded check valves when located on the discharge of pumps.
- 3.05 TOLERANCES
- A. Interior Drainage Piping: Establish invert elevations within 1/2 inch vertically of location indicated and slope to drain at minimum of 1/4 inch per foot slope, unless noted otherwise on the Drawings.
- B. Exterior Drainage Piping: Establish invert elevations within 1/2 inch vertically of location indicated and slope to drain at a minimum of 1% grade, unless noted otherwise on the Drawings. Verify all invert elevations prior to commencing work.
- C. Water Piping: Slope at minimum of 1/32 inch per foot and arrange to drain at low draft head.
- 3.06 DISINFECTATION OF DOMESTIC WATER PIPING SYSTEM
- A. Prior to starting work, verify system is complete, flushed and clean.
- B. Ensure Ph of water to be treated is between 7.4 and 7.6 by adding alkali (caustic soda or soda ash) or acid (hydrochloric).
- C. Inject disinfectant, free chlorine in liquid, powder, tablet or gas form, throughout system to obtain 50 to 80 mg/L residual.
- D. Bleed water from outlets to ensure distribution and test for disinfectant residual at minimum 15 percent of outlets.
- E. Maintain disinfectant in system for 24 hours.
- F. If final disinfectant residual tests less than 25 mg/L, repeat treatment.
- G. Flush disinfectant from system until residual equal to that of incoming water or 1.0 mg/L.
- H. Take samples no sooner than 24 hours after flushing, from 10 percent of outlets and from water entry, and analyze in accordance with AWWA C651.
- 3.07 SERVICE CONNECTIONS
- A. Provide new sanitary and storm sewer services as indicated on the Drawings. Before commencing work check invert elevations required for sewer connections, confirm inverts and ensure that these can be properly connected with slope for drainage and cover to avoid freezing. Removal, rework or corrections to sewer services as a result of the Contractor's failure to confirm invert elevations prior to the start of construction, regardless of the information contained on the Drawings, shall be the sole responsibility of the Contractor. Report any discrepancies difficulties to the Engineer prior to the start of construction.
- B. Provide new water service complete with approved reduced pressure backflow preventer and water meter with by-pass valves (where permitted by local authorities), pressure reducing valve (where pressure exceeds 80 psi); Provide sleeve in wall for service main and support at wall with reinforced concrete bridge. Calk enlarged sleeve and make watertight with pliable material. Anchor service main inside to concrete wall; Provide 18 gage galvanized sheet metal sleeve around service main to 2 inches above floor and 3 feet minimum below grade. Size for minimum of 2 inches of loose batt insulation stuffing.
- C. Provide new gas services complete with gas meter and regulators. Gas service distribution piping shall have initial minimum pressure as indicated on the drawings. Provide appropriately sized regulators on each line serving gas appliances, sized in accordance with the manufacturers recommendations based on the sizing parameters indicated on the Drawings. The entire gas service and piping installation shall comply with the local jurisdiction and the regulations of the serving utility.
- 3.08 SCHEDULES
- A. Pipe Hanger Spacing:
1. Metal Piping:
- a. Pipe size: 1/2 inches to 1–1/4 inches: Maximum hanger spacing: 6.5 ft; Hanger rod diameter: 3/8 inches.
- b. Pipe size: 1–1/2 inches to 2 inches: Maximum hanger spacing: 10 ft; Hanger rod diameter: 3/8 inch.
- c. Pipe size: 2–1/2 inches to 3 inches: Maximum hanger spacing: 10 ft; Hanger rod diameter: 1/2 inch.
- d. Pipe size: 4 inches to 6 inches: Maximum hanger spacing: 10 ft; Hanger rod diameter: 5/8 inch.
2. Plastic Piping:
- a. Pipe size: 1/2 inches to 6 inches: Maximum hanger spacing: 6 ft;

- Hanger rod diameter: 3/8 inch.
- END OF SECTION
- SECTION 221006 – PLUMBING PIPING SPECIALTIES
- PART 1 GENERAL
- 1.01 SECTION INCLUDES
- A. Drains; Cleanouts; Hose bibbs; Hydrants; Backwater valves; Backflow preventers; Water hammer arrestors; Interceptors; Thermostatic mixing valves.
- PART 2 PRODUCTS
- 2.01 BACK WATER VALVES
- A. Manufacturers: Joy R. Smith Manufacturing Company; Savko Plastic Pipe & Fittings, Inc.; Zurn Industries.
- B. Cast Iron Back Water Valves: ANSI A112.21.2M; lacquered cast iron body and cover, brass valve, extension sleeve, and access cover.
- C. Plastic Back Water Valves: ABS or PVC body and valve, extension sleeve, and access cover.
- 2.02 BACKFLOW PREVENTERS
- A. Manufacturers: Conbraco Industries; Watts Regulator Company; Zurn Industries, Inc.
- 2.03 WATER HAMMER ARRESTORS
- A. Manufacturers: Joy R. Smith Manufacturing Company; Watts Regulator Company; Zurn Industries, Inc.
- B. Water Hammer Arrestors: Stainless steel or copper construction, bellows type sized in accordance with FDI-WH 201, precharged suitable for operation in temperature range 34 to 250 degrees F and maximum 150 psi working pressure.
- PART 3 EXECUTION
- 3.01 INSTALLATION
- A. Install in accordance with manufacturer's instructions.
- B. Extend cleanouts to finished floor or wall surface. Lubricate threaded cleanout plugs with mixture of graphite and linseed oil. Ensure clearance at cleanout for rodding of drainage system.
- C. Encase exterior cleanouts in concrete flush with grade.
- D. Install floor cleanouts at elevation to accommodate finished floor for a completely flush installation.
- E. Install approved potable water protection devices on plumbing lines where contamination of domestic water may occur; on boiler feed water lines, janitor rooms, fire sprinkler systems, premise isolation, irrigation systems, flush valves, interior and exterior hose bibbs and all other locations required by Codes.
- F. Pipe relief from backflow preventer to nearest drain.
- G. Install water hammer arrestors complete with accessible isolation valve on hot and cold water supply piping to all fixtures and equipment.
- END OF SECTION
- SECTION 223000 – PLUMBING EQUIPMENT
- PART 1 GENERAL
- 1.01 SECTION INCLUDES
- A. Water Heaters; Commercial gas fired water heaters; Commercial gas fired instantaneous water heaters; Commercial electric water heaters; Electric instantaneous water heaters; Water softeners; Pumps; Circulators; Sewage Ejectors; Sump Pumps; Water pressure booster system.
- PART 2 PRODUCTS
- 2.01 WATER HEATER MANUFACTURERS
- A. A.O. Smith Water Products Co.; Bock Water Heaters, Inc.; Rheem Manufacturing Company; F.W.
- 2.02 COMMERCIAL GAS FIRED WATER HEATERS
- A. Type: Automatic, natural gas-fired, vertical storage
- B. Performance: Maximum working pressure: 150 psig; Equipment performance and accessories shall be as scheduled on the Drawings and specified herein. Inclusion in both locations is not a prerequisite to inclusion in the Contract. Equipment and accessories specified in either location shall be included in the Contract. Provide all necessary accessories and connections as required for a complete, functional system.
- C. Tank: Glass or copper lined welded steel ASME labeled when required by code; multiple flue passages, 4 inch diameter inspection port, thermally insulated with minimum 2 inches polyurethane, encased in corrosion-resistant steel jacket; baked-on enamel finish; floor shield and legs.
- D. Accessories: Brass water connections and dip tube, drain valve, magnesium anode, and ASME rated temperature and pressure relief valve and heat trap fittings for hot and cold water connections; Water Connections: Brass; Dip tube: Crosslinked polyethylene (PEX) or brass; Drain Valve; Anode: Magnesium; Temperature and Pressure Relief Valve: ASME labeled.
- E. Certification: As automatic storage water heater and for operation at 180 degrees F (82 degrees C) for operation on combustible floors.
- F. Controls: Automatic water thermostat with temperature range adjustable from 110 to 180 degrees F (43 to 82 degrees C), automatic reset high temperature limiting thermostat factory set at 195 degrees F, gas pressure regulator, multi-ribbon or tubular burner, 100 percent safety shut-off pilot and thermocouple, flue baffle and draft hood.
- 2.03 COMMERCIAL GAS FIRED INSTANTANEOUS WATER HEATERS
- A. Type: Automatic, natural gas-fired, fully modulating, tankless.
- B. Performance: Maximum working pressure: 150 psig (1000 kPa); Equipment performance and accessories shall be as scheduled on the Drawings and specified herein. Inclusion in both locations is not a prerequisite to inclusion in the Contract. Equipment and accessories specified in either location shall be included in the Contract. Provide all necessary accessories and connections as required for a complete, functional system.
- C. Accessories: Brass or bronze water connections and waterways, integral flow regulator, and ASME rated temperature and pressure relief valve and heat trap fittings for hot and cold water connections; Water Connections: Brass; Coil: Copper; Burners: Stainless steel.
- D. Certification: As automatic fully modulating tankless water heater and for operation at 180 degrees F (82 degrees C) for operation on combustible floors.
- E. Controls: Automatic water thermostat with temperature range adjustable from 110 to 180 degrees F (43 to 82 degrees C), automatic reset high temperature limiting thermostat factory at 195 degrees F (90 degrees C), gas pressure regulator, 100 percent safety shut-off pilot and thermocouple, flue baffle and draft hood.
- 2.04 COMMERCIAL ELECTRIC WATER HEATERS
- A. Type: Factory-assembled and wired, electric, vertical or horizontal storage as specified.
- B. Performance: Maximum working pressure: 150 psig; Equipment performance and accessories shall be as scheduled on the Drawings and specified herein. Inclusion in both locations is not a prerequisite to inclusion in the Contract. Equipment and accessories specified in either location shall be included in the Contract. Provide all necessary accessories and connections as required for a complete, functional system.
- C. Electrical Characteristics: As indicated on the Drawings; Verify that proper power supply is available prior to ordering equipment. Verify proper voltage, phase and current rating of power supply and inform Engineer of any deviations prior to order, connection of equipment or start-up. Responsibility for verification of proper power supply voltage and any product returns or damage resulting from incorrect connections shall rest with this Contractor.
- D. Tank: Glass lined or copper lined welded steel; ASME labeled pressure vessel when required by code, 4 inch diameter inspection port, thermally insulated with minimum 2 inches polyurethane encased in corrosion-resistant steel jacket; baked-on enamel finish.
- E. Controls: Automatic immersion water thermostat; externally adjustable temperature range from 60 to 180 degrees F, flanged or screw-in nichrome elements, high temperature limit thermostat.
- F. Accessories: Brass water connections and dip tube, drain valve, magnesium anode, and ASME rated temperature and pressure relief valve and heat trap fittings for hot and cold water connections; Water connections: Brass; Dip tube: Crosslinked polyethylene (PEX) or brass; Drain Valve; Anode: Magnesium; Temperature and Pressure Relief Valve: ASME labeled.
- G. Controls: Ventilated control cabinet, factory-wired with solid state progressive sequencing step controller, fuses, magnetic contactors, control transformer, pilot lights indicating main power and heating stages, control circuit toggle switch, electronic low-water (probe-type) cut-off, high temperature limit thermostat, flush-mounted temperature and pressure gauges.
- H. Heating Elements: Flange-mounted immersion elements; individual elements sheathed



PAUL DHANENS • ARCHITECT

ARCHITECT	
<div><div><div><div><div><div></div></div></div><div><div><div></div></div><div><div></div></div></div><div><div><div></div></div><div><div></div></div></div><div><div><div></div></div><div><div></div></div></div></div></div><div>CERTIFICATE OF ADOPTION NO. C-23643 JANUARY 2018 STATE OF CALIFORNIA</div></div>	
5100 CALIFORNIA AVE., SUITE 102 BAKERSFIELD, CALIFORNIA 93309 TELEPHONE: (805) 326-8335 FACSIMILE: (805) 326-8037	
CONSULTANT	
COPYRIGHT	
PAUL DHANENS ARCHITECT 7 expressly reserves its copyright and other property rights in these documents and shall not be reproduced, changed or copied in any written, electronic or other form, nor may they be stored in a retrieval system, without the prior written consent of PAUL DHANENS ARCHITECT 7.	
PROJECT	
1666 WEST AVE L LANCASTER, CA	
TENANT IMPROVEMENT FOR	
<div><div><div><div><div><div></div></div></div><div><div><div></div></div><div><div></div></div></div><div><div><div></div></div><div><div></div></div></div><div><div><div></div></div><div><div></div></div></div></div></div><div>FAMOUS FOR Steak 'n Shake HAMBURGERS</div></div>	
1966 WEST AVE L LANCASTER, CA	
DATE	ISSUED FOR
8-24-18	BUILDING DEPT SUBMITTAL
8-28-18	
NO.	REVISIONS
▲	
▲	
▲	
▲	
▲	
PLUMBING	
FILE NAME:	2366A2-0
SHEET	
P-502	



EQUIPMENT FLOOR PLAN
SCALE: 1/4" = 1'-0"

1 CROSSCHECK 6/11/19 SA



FOODSERVICE CONSULTANT
LANDMARK
KITCHEN DESIGN, L.L.C.
ARCHITECT: ANDREW ENGEL AND
TODD ANDERSON
WWW.LANDMARKKITCHENDESIGN.COM

TENANT IMPROVEMENT
FOR



1966 WEST AVE. L
LANCASTER, CA

4-24-18	BUILDING DEPT SUBMITTAL
1	
2	
3	
4	

EQUIPMENT
FLOOR
PLAN

FS-1.0

FOODSERVICE EQUIPMENT SCHEDULE

ITEM	QTY	BUY OUT	FABRICATED	MILLWORK	N.I.E.C.	PROVIDED BY	INSTALLED BY	DESCRIPTION	MANUFACTURE	MODEL NO.	REMARKS
A01	1	X				KEC	KEC	WALK-IN COOLER / FREEZER	THERMALRITE/NORLAKE	CUSTOM	w/ LED LIGHT FIXTURES
A02	1	X				KEC	KEC	COOLER CONDENSING UNIT	THERMALRITE/NORLAKE	CUSTOM	
A03	1	X				KEC	KEC	COOLER EVAP COIL	THERMALRITE/NORLAKE	CUSTOM	
A04	1	X				KEC	KEC	FREEZER CONDENSING UNIT	THERMALRITE/NORLAKE	CUSTOM	
A05	1	X				KEC	KEC	FREEZER EVAP COIL	THERMALRITE/NORLAKE	CUSTOM	
A14	1				X	O	GC	GRIDDLE LINE EXHAUST HOOD	CAPTIVE AIRE	5430ND-2-PSP-F	
A14A	1				X	O	GC	FIRE SUPPRESSION SYSTEM	CAPTIVE AIRE	R-102	
A14B	1				X	O	GC	ELECTRICAL CONTROL PACKAGE	CAPTIVE AIRE	DCV-2111	
A15	1				X	O	GC	GRIDDLE LINE EXHAUST FAN	CAPTIVE AIRE	DU180HFA	
A16	1				X	O	GC	MAKE-UP AIR UNIT	CAPTIVE AIRE	A1-150-MPU	
A17	1				X	O	GC	FRY EXHAUST HOOD	CAPTIVE AIRE	3044BD-2-PSP-F	
A18	1				X	O	GC	FRY EXHAUST FAN	CAPTIVE AIRE	DUS0HFA	
B01A	1	X				KEC	GC	AIR CURTAIN	MARS	NH236-1UA-PW	
B02	2	X				KEC	GC	LOCKERS	WIN-HOLT	WL-66	
B03	1	X				KEC	KEC	MOP SINK	AERO MANUFACTURING	3MP-2116-6	
B03A	1	X				KEC	KEC	MOPS INK SHELF w/ MOP HANGER	AERO MANUFACTURING	SNS-B03A	
B04	1	X				KEC	KEC	FAUCET	T&S	B-0655-BSTP	
B06	4	X				KEC	KEC	WIRE SHELVING UNITS	FOCUS FOODSERVICE	GREEN EPOXY	SEE FS-1.0 FOR SIZE & CONFIGURATION
B07	1				X	V	V	SODA SYSTEM	BY VENDOR		
B11	1				X	V	V	BULK CO2 TANK	BY VENDOR		
B15	1	X				KEC	KEC	REACH-IN FREEZER (HINGED RIGHT)	TRAULSEN	G12000	
B16	2				X	O	O	BREAD RACKS	BY OTHERS		
B20	1				X	V	GC	SAFE	BLUE DOT	SM282016DD	
B21	1	X				KEC	KEC	OFFICE CHAIR	G & A COMMERCIAL SEATING	891	
B23B	2	X				KEC	KEC	WALL SHELF	AERO MANUFACTURING	3W-1236	WALL BACKING BY G.C. REQ'D
B24	3				X	O	O	P.O.S. SYSTEM	BY OWNER		
B25	3				X	O	O	P.O.S. PRINTER	BY OWNER		
B28	2	X				KEC	KEC	DROP BOX	PERMA VAULT	PRO-10	
B29	2	X				KEC	KEC	HAND SINK	AERO MANUFACTURING	HSF25	
B34A	1	X				KEC	KEC	SORTING RACK	AERO MANUFACTURING	3SW-2122	WALL BACKING BY G.C. REQUIRED
B38	1	X				KEC	KEC	3 COMP. SINK	AERO MANUFACTURING	3F3-2418-18RL	w/ FAUCETS AND LEVERWASTES
B39B	1	X				KEC	KEC	OVERSHELF	AERO MANUFACTURING	3W-1272	WALL BACKING BY G.C. REQ'D
B40	1	X				KEC	KEC	FAUCET	T & S BRASS	B-0230	
B41	3	X				KEC	KEC	LEVER WASTE	T & S BRASS	B-3940	
B42	2	X				KEC	KEC	WIRE WALL SHELVING	FOCUS FOODSERVICE	GREEN EPOXY	WALL BACKING BY G.C. REQ'D
B44	2				X	O	GC	SOAP DISPENSER	BY OTHERS		
B45	2				X	O	GC	ICE CUBBER	BY OTHERS		
B47A	2	X				KEC	KEC	MANITOWOC	MANITOWOC	IBT-1020C	
B48A	2	X				KEC	KEC	REMOTE CONDENSING UNIT	MANITOWOC	CVDT-1200	
B49	2	X				KEC	KEC	WATER FILTER SYSTEM	3M PURIFICATION	ICE190-S	
B50	1				X	V	V	OIL STORAGE TANK	MAHONEY		
B54	2	X				KEC	KEC	WALL SHELF	AERO MANUFACTURING	3W-1254	WALL BACKING BY G.C. REQ'D
B55	1	X				KEC	KEC	FAUCET	T & S BRASS	B-0230	w/ B-0230-K
B56	2	X				KEC	KEC	LEVERWASTE	T & S BRASS	B-3940	
B57	1				X	O	O	CONDIMENT DISPENSER	SERVER PRODUCTS	85783	SMALL WARES ITEM
B58	1	X				KEC	KEC	CUP DISPENSERS	DISPENSE RITE	(2)ADJ-NW-81/(1)ADJ-NW-31	w/ EZ-3EZ STAND
B58A	2	X				KEC	KEC	PRINTER SHELF	SAN JAMAR	C2010C	
B58B	1	X				KEC	KEC	CUP DISPENSER	DISPENSE RITE	LID-4BT	
B59	1	X				KEC	KEC	DRIP TRAY TROUGH	SERVER PRODUCTS	7291	
B61	1	X				KEC	KEC	SLICER	SLICE CHIEF	947	
B63A	1	X				KEC	KEC	WORK TABLE 30X72	AERO MANUFACTURING	SNS-63A	PATTIAL UNDERSHELVES
B64A	1	X				KEC	KEC	WORK TABLE 30X34	AERO MANUFACTURING	3TSB-3034	
B66	1	X				KEC	KEC	REACH-IN FREEZER	TRAULSEN	G12000	SET TO +10 DEG SHAKE CONDITIONING
B68	4	X				KEC	KEC	TRASH CAN	RUBBERMAID	FG354000BRN	
B69	1	X				KEC	KEC	MILK SHELF w/ NOTCH	AERO MANUFACTURING	SNS-MM-B69	WALL BACKING BY G.C. REQ'D
B69A	1	X				KEC	KEC	PRINTER SHELF	AERO MANUFACTURING	SNS-MM-69A	
B69B	1	X				KEC	KEC	SHAKE STATION SHELF	AERO MANUFACTURING	3W-248	WALL BACKING BY G.C. REQ'D
B76	1	X				KEC	KEC	MILK DISPENSER	SILVER KING	SKMAJ1/C4	
B80A	1	X				KEC	KEC	WALL SHELF	AERO MANUFACTURING	3W-1230	WALL BACKING BY G.C. REQ'D
B81	1	X				KEC	KEC	CONDIMENT CADDY	DISPENSE RITE	NLO-1B	
B82	2	X				KEC	KEC	LID DISPENSER	SAN JAMAR	L1014	
B83	2	X				KEC	KEC	STRAW HOLDER	SAN JAMAR	L1035	
B85	2				X	V	V	SODA DISPENSER	BY VENDOR		
B86A	1	X				KEC	KEC	CONDIMENT CADDY	DISPENSE-RITE	NLO-SWNH	
B86B	1	X				KEC	KEC	CONDIMENT CADDY	DISPENSE-RITE	NLO-LDNH	
B86C	1	X				KEC	KEC	CONDIMENT CADDY	DISPENSE-RITE	SWCH-1BT	
B90	6	X				KEC	KEC	CUP DISPENSER	SAN JAMAR	C5450C18	
B91B	1	X				KEC	KEC	DOUBLE OVERSHELF	AERO MANUFACTURING	3DO-1272	
B96	1	X				KEC	KEC	WORK TABLE	AERO MANUFACTURING	3TSS-3036	
B97A	2	X				KEC	KEC	SQUEEZE BOTTLE	SERVER PRODUCTS	86988	
B98	2				X	O	O	P.O.S. REMOTE PRINTER	BY OWNER		
B100	1	X				KEC	KEC	OVERSHELF	AERO MANUFACTURING	3W-1224	WALL BACKING BY G.C. REQ'D
B100A	1	X				KEC	KEC	OVERSHELF	AERO MANUFACTURING	3DO-1672	w/ PAPER HOLDERS
B101	1	X				KEC	KEC	STAB BOXES	TRAULSEN	UPT3212	
B102	1	X				KEC	KEC	GRIDDLE	VULCAN	924RX-XX	w/ REAR TROUGH
B102A	1	X				KEC	KEC	GAS CONNECTOR	DORMONT	1675KIT48	
B103	1	X				KEC	KEC	VERTICAL TOASTER	ROUNDUP	VCT22000	
B103A	1		X			KEC	KEC	TOASTER CART	ALL SOUTHERN STAINLESS	CUSTOM	
B105	1	X				KEC	KEC	GRIDDLE	VULCAN	948RX-XX	w/ REAR TROUGH
B105A	1	X				KEC	KEC	GAS CONNECTOR	DORMONT	1675KIT48	
B106A	1	X				KEC	KEC	DRESSING TABLE	TRAULSEN	UPT7224-DD	
B107E	1		X			KEC	KEC	6" GRILL STAND	ALL SOUTHERN STAINLESS	CUSTOM	COUNTER SERV CONFIG
B112A	4	X				KEC	KEC	PENDANT HEAT LAMPS	HATCO	DLH-500SN	GLOSSY GRAY FINISH
B112B	1	X				KEC	KEC	HEAT LAMP	MARSHALL AIR SYSTEMS	500794	
B113	1	X				KEC	KEC	DRAWER WARMER	HATCO	HDW-2N	
B114A	2	X				KEC	KEC	COUNTER TOP WARMER	SERVER	B6090	
B116	1	X				KEC	KEC	PRODUCT HOLDING UNIT	DUKE MANUFACTURING	FWM3-22-22437	
B119	1	X				KEC	KEC	HOT FOOD DISPENSER	STAR MANUFACTURING	SPDE1HP	WALL MOUNT
B123	1	X				KEC	KEC	SMALL DUMP STATION	MARSHALL AIR SYSTEMS	RR5C	
B124	1	X				KEC	KEC	FRYER BATTERY	PITCO	SSHLY14C-3/FDATO	
B124A	1	X				KEC	KEC	GAS CONNECTOR	DORMONT	16100KIT48	
B127	5	X				KEC	KEC	WALK-IN SHELVING UNITS	FOCUS FOODSERVICE	GREEN EPOXY	SEE FS-1.0 FOR SIZE & CONFIGURATION
B128	3	X				KEC	KEC	DUNNAGE RACK	FOCUS FOODSERVICE	FADR482412/FADR602412/FADR362412	
B132	4				X	O	V	KDS MONITORS	BY OWNER		
B133	1	X				KEC	KEC	AIR CURTAIN	BERNER	DTU1018AA	w/ DOOR MICROSWITCH & MOUNTING BRACKET
B134	1	X				KEC	KEC	18" TICKET RAILS	SAN JAMAR	CK6518A	
B134B	1	X				KEC	KEC	60" TICKET RAIL	SAN JAMAR	CK6560A	
B140	1	X				KEC	KEC	TRIPLE SHAKE MIXER	HAMILTON BEACH	HMD400	
B141	1	X				KEC	KEC	MIX 'N CHILL	HAMILTON BEACH	94950	
S03	LOT		X			O	GC	S/S FLASHING (FRYERS)	CAPTIVE AIRE	CUSTOM	
S07	LOT		X			O	GC	S/S WALL FLASHING (GRILL LINE)	CAPTIVE AIRE	CUSTOM	
S08A	1		X			KEC	KEC	S/S TABLE 18X32	AERO MANUFACTURING	SNS-S08A	
S10A	1		X			KEC	KEC	TWO COMP. SINK	AERO MANUFACTURING	3F2-2418-18L	
S12	LOT				X	GC	GC	WINDOW SILL CAPS	BY G.C.		
S20B	1			X	X	GC	GC	BEVERAGE COUNTER	MILLWORK	BY G.C.	
S21A	1		X			KEC	KEC	BEVERAGE COUNTER (DRIVE THRU)	AERO MANUFACTURING	SNS-21A	
S22	6		X			KEC	KEC	CORNER GUARDS	AERO MANUFACTURING	SNS-S22	
S25	1		X			KEC	KEC	FRY CUP HOLDER	ALL SOUTHERN STAINLESS	CUSTOM	
S26	1		X			KEC	KEC	WALL SHELF w/ LOWER SHELF	ALL SOUTHERN STAINLESS	CUSTOM	WALL BACKING BY G.C. REQ'D
S32	1		X			KEC	KEC	PAPER HOLDER	ALL SOUTHERN STAINLESS	CUSTOM	
S33	1		X			KEC	KEC	BAG HOLDER	ALL SOUTHERN STAINLESS	CUSTOM	
SS3	1		X			KEC	KEC	SHAKE STATION LITE	ALL SOUTHERN STAINLESS	CUSTOM	
M01	1			X	X	O	V	OFFICE DESK	BY MILLWORK VENDOR		
M03	1			X	X	O	V	OFFICE SHELVING	BY MILLWORK VENDOR		
M7	1			X	X	O	V	NON-TRAD FRONT SERVICE COUNTER	BY MILLWORK VENDOR		

NOTES:

1. ALL CONNECTIONS SHOWN IN THE SCHEDULE ARE SIZED AS THEY ACTUALLY OCCUR ON THE EQUIPMENT.

2. CONNECTIONS SHOWN ARE FOR ONE UNIT. TO DETERMINE TOTAL REQUIREMENTS, MULTIPLY BY NUMBER IN QUANTITY COLUMN.

3. WHEN EQUIPMENT IS NOTED AS EXISTING, UTILITY REQUIREMENTS SHOULD MATCH EXISTING AS INDICATED ON THE MANUFACTURER'S DATA PLATE.

4. WHERE INDICATED TO CONNECT IN OR THROUGH A VALVE COMPARTMENT, CONTRACTOR SHALL STUB-UP INTO VALVE COMPARTMENT AT HEIGHT INDICATED ON ROUGH-IN PLAN, CAP HIS WORK AND MAKE FINAL CONNECTIONS AFTER EQUIPMENT IS IN PLACE.
5. THE INTENT OF THE DRAWINGS AND SPECIFICATIONS REGARDING ELECTRICAL PRE-WIRING AND PLUMBING PRE-PIPING IS TO HAVE THE K.E.C. EXTEND TO AND TERMINATE ALL CONNECTIONS FOR THE EQUIPMENT IN THE LOCATIONS INDICATED IN THE EQUIPMENT SCHEDULE AND SPOT PLANS.

6. ALL ITEMS SHOWN WITH P.I. CONNECTIONS PLUG INTO RECEPTACLES FURNISHED BY THE K.E.C. AS PART OF THE EQUIPMENT.

7. ELECTRICAL, PLUMBING AND MECHANICAL CONTRACTORS TO PROVIDE ALL ROUGH-IN BUILDING SERVICES AND FINAL CONNECTION TO ALL FOOD SERVICE EQUIPMENT.

CONTRACT CODE:


E - EXISTING GC - GENERAL CONTRACTOR FURNISHED P - PURCHASE
F - FABRICATE O - OWNER FURNISHED V - VENDOR FURNISHED
OT - BY OTHERS

NOTE:

1. ALL S/S CUSTOM FABRICATION TO BE MANUFACTURED TO NSF STANDARDS BY APPROVED FABRICATOR.
2. CUSTOM REFRIGERATION TO BE FABRICATED TO NSF STANDARDS BY CERTIFIED NSF FABRICATOR.



FOODSERVICE CONSULTANT



LANDMARK
KITCHEN DESIGN, LLC

ALLIANCE WITH CH2M HILL
185 WEST AVENUE
LANCASTER, CA 93534
www.landmarkkds.com

TENANT IMPROVEMENT
FOR



1966 WEST AVE. L
LANCASTER, CA

4-24-18 BUILDING DEPT SUBMITTAL

1


2

3

4

EQUIPMENT
SCHEDULE

FS-2.0


















nda

TENANT IMPROVEMENT
FOR

	EQUIPMENT
	ELECTRICAL
	ROUGH-INS

CLARIFICATIONS

- | ELECTRICAL LEGEND | | |
|-------------------------------------------------------------------------------------|-----------------------------------|------------------------------------------------------|
| SYMBOLS | | ABBREVIATIONS |
|  | JUNCTION BOX (J BOX) | A AMPERES |
|  | ELECTRICAL ROUGH-IN | V VOLTS |
|  | STUB-UP | W WATTS |
|  | DROP CORD | PH PHASE |
|  | EQUIPMENT CONNECTION | AFB ABOVE FINISHED FLOOR |
|  | FLUORESCENT LIGHT FIXTURE | DN DOWN FROM ABOVE |
|  | INCANDESCENT LIGHT INDICATION | BTC BRANCH TO CONNECTION POINT AND CONNECT EQUIPMENT |
|  | BREAKER PANEL BOARD | HP HORSE POWER |
|  | SWITCH AS NOTED | KW KILOWATTS |
|  | FLOOR BOX (FL BOX) | DC DIRECT CONNECTION |
|  | TELEPHONE OUTLET | K.E.G. KITCHEN EQUIPMENT CONTRACTOR |
|  | FOURPLEX CONVENIENCE OUTLET (FCO) | E.C. ELECTRICAL CONTRACTOR |
|  | DUPLEX CONVENIENCE OUTLET (DCO) | |
|  | SINGLE CONVENIENCE OUTLET (SCO) | |



ELECTRICAL ROUGH-IN SCHEDULE					
TAG	QUA	ROUGH-IN	LOAD	SERVICE TO	REMARKS
EA01	2	120V 1PH JB DN + 108"	5.0A	WALK-IN COOLER/FREEZER	
EA01A	1	120V 1PH DR + 114"	20.0A	WALK-IN COOLER/FREEZER	FOR HEAT TAPE WIRE
EA02	1	208V 3PH JB (ON ROOF)	4.2A	COOLER CONDENSING UNIT	
EA03	1	120V 1PH JB DN + 108"	1.8A	COOLER EVAP COIL	
EA04	1	208V 3PH JB (ON ROOF)	8.3A	FREEZER CONDENSING UNIT	
EA05	1	208V 1PH JB DN + 108"	8.7A	FREEZER EVAP COIL	
EA14	1	120V 1PH JB DN + 108"	5.0A	GRIDDI LINE EXHAUST HOOD	FOR HOOD LIGHTS ONLY
EA14A	1	120V 1PH JB + 96"	15.0A	FIRE SUPPRESSION SYSTEM	
EA14B	1	120/208V 3PH JB + 96"	*	ELECTRICAL CONTROL PACKAGE	
EA15	1	208V 3PH JB (ON ROOF)	3.8A	GRIDDI LINE EXHAUST FAN	VERIFY EXACT LOCATION
EA16	1	208V 3PH JB (ON ROOF)	6.1A	MUA FAN	VERIFY EXACT LOCATION
EA16A	2	208V 3PH JB (ON ROOF)	11.2A	MUA CONDENSING UNITS	
EA17	1	120V 1PH JB DN + 108"	5.0A	FRY LINE EXHAUST HOOD	
EA18	1	208V 3PH JB (ON ROOF)	2.0A	FRY EXHAUST FAN	FOR HOOD LIGHTS ONLY
EB01	1	120V 1PH JB + 86"	9.0A	AIR CURTAIN	CONN THRU DOOR MICROSWITCH
EB07	1	120V 1PH DR + 86"	20.0A	SODA SYSTEM	
EB15	1	120V 1PH DR + 86"	9.7A	REACH-IN FREEZER	
EB24	1	120V 1PH DR + 56"	7.5A	P.O.S. SYSTEM	DC/IG
EB24A	2	120V 1PH DR STUB-UP + 8"	7.5A	P.O.S. SYSTEM	DC/IG
EB24B	3	EMPTY BOX & CONDUIT FOR P.O.S. COMM CABLE BY E.C.			
EB25	1	120V 1PH DR + 56"	3.0A	P.O.S. PRINTER	DC/IG
EB25A	2	120V 1PH DR STUB-UP + 8"	3.0A	P.O.S. PRINTER	DC/IG
EB25B	3	EMPTY BOX & CONDUIT FOR P.O.S. COMM CABLE BY E.C.			
EB47	2	120V 1PH JB + 64"	1.1A	ICE MACHINE	
EB48	2	208V 3PH JB (ON ROOF)	9.3A	REMOTE CONDENSING UNITS	INTERCONNECT w/ EB47 CONTROL WIRING
EB50	1	120V 1PH DR + 48"	20.0A	USED OIL TANK	
EB50A	1	EMPTY BOX & CONDUIT FOR COMM CABLE BY E.C.			
EB66	1	120V 1PH DR + 86"	9.7A	REACH-IN FREEZER	
EB76	1	120V 1PH DR + 68"	1.5A	MILK DISPENSER	
EB85	2	120V 1PH DR + 56"	3.5A	SODA DISPENSER	
EB98	2	120V 1PH DR + 66"	7.5A	P.O.S. SYSTEM	DC/IG
EB98A	2	EMPTY BOX & CONDUIT FOR P.O.S. COMM CABLE BY E.C.			
EB101	1	120V 1PH DR + 18"	7.5A	STAB BOXES	
EB102	1	120V 1PH DR + 18"	1.0A	GRIDDI	
EB103	1	208V 1PH SR + 45"	15.8A	VERTICAL TOASTER	
EB105	2	120V 1PH DR + 18"	1.0A	GRIDDI	
EB106	1	120V 1PH DR + 18"	7.5A	DRESSING TABLE	
EB112A	5	120V 1PH JB (AT CEILING)	3.2A	PENDANT HEAT LAMP	
EB112	1	120/208V 1PH JB + 68"	10.0A	HEAT LAMP	
EB113	1	120V 1PH DR + 12"	7.5A	DRAWER WARMER	
B114A	1	120V 1PH DR + 56"	(2)4.2A	COUNTER TOP WARMER	
EB116	1	120V 1PH DR + 66"	10.0A	PRODUCT HOLDING UNIT	
EB119	1	120V 1PH DR + 72"	7.0A	HOT FOOD DISPENSER	
EB121	1	120V 1PH DR STUB-UP + 8"	6.0A	U/C REFRIGERATOR	
EB123	1	120V 1PH DR + 48"	9.0A	SMALL DUMP STATION	
EB124	1	120V 1PH DR + 22"	5.1A	FRYER BATTERY CONTROLS	
EB131	1	120V 1PH DR + 16"	15.0A	CRANE GAMES	
EB132	4	120V 1PH DR + 75"	7.5A	KDS SYSTEM	DC/IG
EB132A	4	EMPTY BOX & CONDUIT FOR P.O.S. COMM CABLE BY E.C.			
EB133	1	120V 1PH JB + 86"	1.6A	AIR CURTAIN	CONN THRU DOOR MICROSWITCH
ES10	1	120V 1PH DR + 56"	15.0A	PREP TABLE	CONVENIENCE OUTLET
ESS3	2	120V 1PH DR + 12"	9.3A	DRIVE THRU STAKE STATION	
ESS3A	2	120V 1PH DR + 54"	8.5A	SHAKE STATION ACCESSORY	
ESS3B	1	120V 1PH DR + 54"	1.5A	SHAKE STATION ACCESSORY	

CLARIFICATIONS	
A	MECHANICAL GAS VALVE FURNISHED WITH FIRE SUPPRESSION AND IS TO BE INSTALLED BY THE PLUMBING CONTRACTOR
B	PLUMBER TO SPECIFY AND LOCATE EQUIPMENT AND UTILITIES FOR MOP SINKS. (SINKS FURNISHED BY PLUMBER).
C	ROUGH-IN PLUMBING PERFORMED BY THE PLUMBING CONTRACTOR SHALL INCLUDE ALL MATERIAL, PIPES, VALVES, FITTINGS, UNDERGROUND TRAPS, FLOOR SINKS, FLOOR DRAINS, VENTS, FLOOR DRAIN AND FLOOR SINK COVERS AND STOPS AT THE ENDS OF WATER AND STEAM LINES.
D	FINAL CONNECTIONS USUALLY PERFORMED BY THE PLUMBING CONTRACTOR SHALL INCLUDE ALL MATERIALS, PIPING, VALVES, FITTINGS, TRAPS, EXTENDED WASTES AND WHATEVER IS NECESSARY TO PROPERLY CONNECT THE EQUIPMENT ITEM TO THE ROUGH-IN OUTLET. THIS INCLUDES STOPS ON ALL WATER LINES, CLEANOUTS ON ALL DIRECT CONNECTED DRAIN LINES AND HARD COPPER DRAINS TO FLOOR SINKS FROM EQUIPMENT.
E	ALL WORK TO BE PERFORMED IN FULL ACCORDANCE WITH THE APPLICABLE CODES RELATING TO INSTALLATION AND HOOK-UP OF EQUIPMENT. OMISSIONS OR ERRORS ON THE SCHEDULE DO NOT RELIEVE THE PLUMBING CONTRACTOR FROM COMPLETE FINAL PLUMBING RESPONSIBILITY.
F	ALL CONNECTIONS SHOWN RELATE TO KITCHEN EQUIPMENT ONLY. REFER TO ARCHITECTURAL/ENGINEERING PLANS FOR ADDITIONAL REQUIREMENTS.
G	ALL DIMENSIONS GIVEN ARE FROM COLUMN CENTERLINES AND/OR FINISHED WALLS AND ARE IN INCHES TO 4'-0". ELEVATIONS GIVEN ARE FROM FINISHED FLOORS. ALL ROUGH-INS SHOWN ARE TO BE RUN INSIDE WALLS (EXCEPT STUB-UPS) LOCATIONS INDICATE POINT OF EXIT FROM WALLS, CEILINGS OR FLOORS.
H	ALL FLOOR DRAINS TO SET 1/2" BELOW FINISHED FLOOR UNLESS OTHERWISE NOTED. DO NOT SLOPE FLOORS SO CLOSE TO DRAINS AS TO CREATE "PITS" OR "DIPS" IN FLOOR. MINIMUM RADIUS OF SLOPE TO BE 24" FROM CENTERLINE OF DRAIN.

NOTE:

IT IS THE INTENTION OF THIS PLAN TO SHOW UTILITY REQUIREMENTS AND CONNECTION POINTS. DO NOT USE FOR ROUGHING-IN LOCATIONS. FOR ACTUAL ROUGHING-IN LOCATIONS REFER TO THE SHOP DRAWINGS PROVIDED BY THE KITCHEN EQUIPMENT CONTRACTOR.

INDIRECT WASTE LINES REQUIRED FOR STANDARD AND/OR FABRICATED ITEMS OF KITCHEN EQUIPMENT SHALL BE FURNISHED AND INSTALLED BY THE KITCHEN EQUIPMENT CONTRACTOR, EXCEPT FOR SINKS.

WATER INLET FITTINGS AND VALVE FOR THE SOILED DISHTABLE TROUGHS SHALL BE FURNISHED AND INSTALLED BY THE KITCHEN EQUIPMENT CONTRACTOR. PLUMBING CONTRACTOR SHALL PROVIDE COLD WATER SERVICE, ALL INTERCONNECTING PIPING, VACUUM BREAKERS AND MAKE FINAL CONNECTIONS.


THE KITCHEN EQUIPMENT CONTRACTOR TO PROVIDE ALL EQUIPMENT TRIM, INCLUDING FAUCETS, SINK WASTES AND SWING FAUCETS AT KETTLES AND RANGES, ALL TO BE INSTALLED BY THE PLUMBING CONTRACTOR.

ALL HORIZONTAL PIPING LINES CONNECTED AND EXTENDED FROM EQUIPMENT SHALL BE RUN AT THE HIGHEST POSSIBLE ELEVATION AND NOT LESS THAN 6" ABOVE THE FINISHED FLOOR TO PROVIDE AMPLE CLEARANCE FOR CLEANING. AT WALL OR COLUMN LOCATIONS, PIPING ROUGH-INS SHOULD BE STUBBED UP IN WALLS WHEREVER POSSIBLE.

COLD AND HOT WATER AT DISPOSER TO CONNECT TO MIXING VALVE AT 3'-AFF, THEN, FROM MIXING VALVE BACK INTO WALL WITH 3/4" PIPE TO HOSE REEL AT 8'-AFF. THE COLD WATER TO DISPOSER BEFORE CONNECTING TO MIXING VALVE.

PLUMBER SHALL INSTALL AUTOMATIC SHUT-OFF VALVE FOR FUEL GAS. VALVE SHALL BE SOLENOID TYPE WIRED TO FIRE EXTINGUISHER


PLUMBING LEGEND		
SYMBOLS	ABBREVIATIONS	
●	HOT/COLD WATER	HW HOT WATER
●	STUB-UP WATER	CW COLD WATER
●	DRAIN	DR DRAIN
○	CONNECTION	AFF ABOVE FINISHED FLOOR
□	FLOOR DRAIN AS NOTED	FD FLOOR DRAIN
■	FLOOR SINK (IF NOT)	FS FLOOR SINK
■	FLOOR SINK (SINK GRATE)	FT FLOOR TROUGH
—	GAS LINE	HD HUB DRAIN
⊕	GAS CONNECTION	GPH GALLONS PER HOUR
—	FLEX CONNECT HOSE	GPM GALLONS PER MINUTE
—	INDIRECT WASTE LINE	BTC BRANCH TO CONNECT
—	PLUMBING INTERCONNECTION	PSI POUNDS PER SQUARE INCH
⊙	STEAM SUPPLY	DFA DOWN FROM ABOVE
⊙	STEAM RETURN	SS STEAM SUPPLY
○	STEAM CONNECTION	SR STEAM RETURN
PLUMBING GENERAL NOTES		
1. SEE EQUIPMENT PLAN AND SCHEDULE OF EQUIPMENT FOR ADDITIONAL INFORMATION.		
2. P.C. TO PROVIDE ALL ROUGH-IN AND FINAL CONNECTIONS TO ALL EQUIPMENT SHOWN HEREIN.		
3. SOLID DOT REPRESENTS ROUGH-IN LOCATION. (FURNISHED BY P.C.) DOTTED LINE REPRESENTS FINAL CONNECTION. (FURNISHED BY P.C.) CIRCLE REPRESENTS CONNECTION TO EQUIPMENT. (FURNISHED BY P.C.)		
4. PLUMBING CONTRACTOR (P.C.) TO KEEP ALL PLUMBING LINES CLEAR OF WALLBACKING AREAS.		
5. P.C. TO PROVIDE AND INSTALL REGULATORS AS REQUIRED.		



1 DISCONNECT GAS HOSE DETAIL
FS-4.0 NOT TO SCALE

REFER TO SPECIAL CONDITIONS PLAN SHEET FOR FLOOR SINK, FLOOR TROUGH & SLAB PENETRATION DIMENSIONS

NOTE: ALL GAS EQUIPMENT ON LEGS OR CASTERS SHALL HAVE RESTRAINT CABLES & QUICK DISCONNECT HOSES



FLOOR PLAN
SCALE: 1/4" = 1'-0"

PLUMBING ROUGH-IN SCHEDULE					
TAG	QUA	ROUGH-IN	CONNECTION	SERVICE TO	REMARKS
PB04	1	1/2" HW & CW + 36"	1/2" HW & CW	SERVICE FAUCET	
PB07	1	1/2" CW + 24"	1/2" CW	SODA SYSTEM	w/ BACKFLOW DEVICE BY P.C.
PB29	1	1/2" HW & CW + 18"	1/2" HW & CW	HAND SINK	
PB38	1	1/2" HW & CW + 18"	1/2" HW & CW	3 COMPT. SINK	
PB47	2	1/2" CW + 72"	1/2" CW	ICE MACHINES	CONNECT THRU FILTER
PB49	2	1/2" CW + 72"	1/2" CW	FILTER SYSTEM	
PS10	1	1/2" HW & CW + 18"	1/2" HW & CW	PREP SINKS	
PSS3	1	3/4" HW & CW + 12"	3/4" HW	DRIVE THRU STAKE STATION	PC TO PROVIDE 100' F WATER w/ MIX VALVE

WASTE ROUGH-IN SCHEDULE					
TAG	QUA	ROUGH-IN	CONNECTION	SERVICE TO	REMARKS
WA03	1	FLOOR SINK	1" I.W.	COOLER EVAP COIL	
WA05	1	FLOOR SINK	1" I.W.	FREEZER EVAP COIL	
WA16	1	FLOOR SINK	1" I.W.	MUA UNIT	
WB03	1	2" W (IN FLOOR)	2" W	MOP SINK	
WB07	1	FLOOR SINK	1/2" I.W.	SODA SYSTEM	
WB29	1	1-1/2" W + 16"	1-1/2" W	HAND SINK	FOR BACKFLOW DEVICE BY P.C.
WB38	1	FLOOR SINK	(3) 2" I.W.	3 COMPT. SINK	
WB47	3	FLOOR SINK	3/4" I.W.	ICE MACHINES	
WB85	2	FLOOR SINK	1" I.W.	SODA DISPENSER	
WS10	1	FLOOR SINK	(2) 2" W	PREP SINKS	
WSS3	1	FLOOR SINK	(2) 1-1/2" I.W.	DRIVE THRU STAKE STATION	

GAS ROUGH-IN SCHEDULE					
TAG	QUA	CONNECTION	BTUH	SERVICE TO	REMARKS
GB102	1	3/4" G + 10"	54 MBTU	GRIDDLE	w/ Q.D. HOSE & RESTRAINING DEVICE
GB105	1	3/4" G + 10"	104 MBTU	GRIDDLE	w/ Q.D. HOSE & RESTRAINING DEVICE
GB124	1	1-1/4" G + 10"	217 MBTU	FRYER BATTERY	w/ Q.D. HOSE & RESTRAINING DEVICE



FOODSERVICE CONSULTANT
LANDMARK
KITCHEN DESIGN, LLC
ARIZONA, ARKANSAS, CALIFORNIA, CONNECTICUT, ILLINOIS, INDIANA, IOWA, KANSAS, KENTUCKY, LOUISIANA, MAINE, MARYLAND, MASSACHUSETTS, MICHIGAN, MINNESOTA, MISSISSIPPI, MISSOURI, MONTANA, NEBRASKA, NEVADA, NEW HAMPSHIRE, NEW JERSEY, NEW YORK, NORTH CAROLINA, NORTH DAKOTA, OHIO, OKLAHOMA, OREGON, PENNSYLVANIA, RHODE ISLAND, SOUTH CAROLINA, SOUTH DAKOTA, TENNESSEE, TEXAS, UTAH, VERMONT, VIRGINIA, WASHINGTON, WEST VIRGINIA, WISCONSIN, WYOMING

TENANT IMPROVEMENT
FOR





1966 WEST AVE. L
LANCASTER, CA

4-24-18 BUILDING DEPT SUBMITTAL

1
2
3
4

EQUIPMENT
PLUMBING
ROUGH-INS

FS-4.0




FLOOR PLAN
SCALE: 1/4" = 1'-0"


MECHANICAL ROUGH-IN SCHEDULE											
ITEM	QUA	TAG	HOOD SIZE			AIR FLOW REQUIREMENTS					HOOD WEIGHT (LBS.)
						EXHAUST C.F.M.	SUPPLY C.F.M.	EXHAUST SIZE	SUPPLY SIZE	TOTAL HOOD INCHES W.C.	
A14	1	MEA14	87"	54"	30"	1,812		14" Ø		-0.785"	705
A14	3	MSA14	100"	14"	6"		770 (EA)		12" X 28"	0.222"	
A17	1	MEA17	52"	30"	14"	900		10" Ø		-0.844"	257
A17	1	MSA17	52"	18"	6"		630		8" x 36"	0.177"	

MECHANICAL SYSTEM NOTES:

- EXHAUST HOOD REQUIREMENTS AND DUCT COLLAR SIZES SHALL BE COORDINATED WITH FINAL SHOP DRAWINGS PRIOR TO FABRICATION.
- ALL FINAL DUCT WELDING AND CONNECTIONS TO BE INCLUDED IN THE GC CONTRACT.
- DUCTWORK, EXHAUST AND MUA FANS TO BE INSTALLED BY THE GC'S MECHANICAL CONTRACTOR.
- PROVIDE DISCONNECT ON ROOF FOR EXHAUST AND M.U.A. FANS.
- ELECTRICAL EQUIPMENT UNDER EXHAUST HOOD MUST HAVE SHUNT TRIP BREAKERS AT ELECTRICAL PANEL CONNECTED TO MICROSWITCHES IN THE FIRE SYSTEM.
- K.E.C. IS TO PROVIDE CLOSURE TRIM PANELS FROM TOP OF HOOD TO CEILING & S/S WALL PANELS



2 TYPICAL FIRE PROTECTION SYSTEM
NOT TO SCALE



3 RECESSED REMOTE FIRE PULL DETAIL
NOT TO SCALE

NOTE:
REFER TO ENGINEERING HOOD DATA SHEETS FOR COMPLETE CFM REQUIREMENTS.

- NOTE:
- REFRIGERATION LINES ARE FOR SCHEMATIC PURPOSES ONLY.
 - K.E.C. AND G.C. TO VERIFY EXACT LOCATION OF REFRIGERATION UNITS ON ROOF WITH ARCHITECT PRIOR TO INSTALLATION.



POSSIBLE CONSULTANT
LANDMARK
KITCHEN DESIGN, L.L.C.
ARCHITECT ANDERSON ANDERSON
1000 1000 1000
www.landmarkkitchen.com

TENANT IMPROVEMENT
FOR



1966 WEST AVE. L
LANCASTER, CA

4-24-18 BUILDING DEPT SUBMITTAL

1
2
3
4

EQUIPMENT
MECHANICAL
PLAN

FS-5.0

DuctWork #2 Parts - Job#3864344


Tag	Part #	CFM	S.P.	Weight	Velocity	QTY	Description
P1	DW1045ASY	900	-0.0438	4.62	1650.12	1	Single Wall Duct 45 Degree Elbow, 10" Duct, Assembly.
P2	DW1045ASY	900	-0.0625	4.62	1650.12	1	Single Wall Duct 45 Degree Elbow, 10" Duct, Assembly.
P3	DW1047LT	900	-0.0268	15.72	1650.12	1	Single Wall Duct 10" diameter, 47" long, flange at both ends. Stainless Steel.
P4	DW1029LT	900	-0.0165	9.75	1650.12	1	Single Wall Duct 10" diameter, 29" long, flange at both ends. Stainless Steel.
P5 Assembled w/P6	DW1048AJDKIT	900	-0.0137	18.63	1650.12	1	Single Wall Duct Adjustable, 10" diameter, 47.5" long, flange at one end With a 10" Adjustable Collar - Stainless Steel.
P6 Assembled w/P5	DW1910TP	900	0	6.62	1650.12	1	Duct to Curb Transition, 19-1/2" Curb to 10" Duct, 16 GA Aluminized. Misc. non-standard transition plate.
System at P6		900	-1.0073				
	3M-2000PLUS			0.80		1	Duct - 3M Fire Barrier 2000 Plus Silicone - Used as sealant to Seal Duct Joints.
	735602000			52.00		3	Duct - Duct insulation for zero clearance to combustibles - 300" x 24" x 1-1/2" Roll. Unifrax FyreWrap Elite 1.5.
	BANDING.5			5.00		1	Duct - Fire Barrier Wrap Stainless Steel Banding .5" Width - 200 FT Per Roll.
	DW10CLASY			1.10		5	Duct "V" Clamp With new design 14 Ga Brackets, 10" Duct, Assembly.
	SEAL.50-50			0.50		2	Duct - Fire Barrier Wrap Stainless Steel Banding Seal .5" Width. Quantity of 50.
	TAPEALUM			0.25		1	Duct - Fire Barrier Wrap Aluminum Foil Tape - 3" x 150' Roll.
Total Weight				228.51			

SINGLE WALL FACTORY BUILT DUCTWORK


- ALL DUCTWORK IS REQUIRED TO BE INSTALLED WITH THE MAXIMUM SUPPORT SPACING LISTED BELOW.
- FOR A COMPLETE LIST OF APPROVED SUPPORT METHODS, SEE THE INSTALLATION AND OPERATION MANUAL.
- DUCTWORK SHALL SLOPE NOT LESS THAN 1/16" PER LINEAR FOOT TOWARDS THE HOOD OR AN APPROVED GREASE COLLECTION RESERVOIR.
- WHERE HORIZONTAL DUCTS EXCEED 75 FEET IN LENGTH, THE SLOPE SHALL NOT BE LESS THAN 3/16" PER LINEAR FOOT.

DUCT DIAMETER	HORIZONTAL SUPPORT (ft)	VERTICAL WALL SUPPORT (ft)	VERTICAL CURB SUPPORT (ft)
8"	10'	10'	24'
10"	10'	10'	24'
12"	10'	10'	24'
14"	10'	10'	24'
16"	10'	10'	24'
18"	10'	10'	24'
20"	10'	10'	24'
22"	10'	10'	24'
24"	10'	10'	24'


DuctWork #2 SE View




DuctWork #2 Front View



DuctWork #2 Top View




DuctWork #2 Side View



REVISIONS

REVISIONS	DATE:
DESCRIPTION	




INDIANA OFFICE

20 E. Airport Rd. Ste. 100, Brownsburg, IN 46112 PHONE: (317) 852-3770 FAX: (919) 227-5929 EMAIL: reg56@captiveair.com

SNS LANCASTER, CA
LANCASTER, CA, 93536

DATE: 6/11/2019
DWG.#: 3864344
DRAWN BY: DCM-56
SCALE: 3/4" = 1'-0"
MASTER DRAWING

SHEET NO.
10



TENANT IMPROVEMENT
FOR




1966 WEST AVE. L
LANCASTER, CA

4-24-18 BUILDING DEPT SUBMITTAL


- 1
- 2
- 3
- 4

EXHAUST
HOOD SHOP
DRAWING


FS-5.10




SECTION VIEW - MODEL 5430ND-2-PSP-F
HOOD - #1



SECTION VIEW - MODEL 3044BD-2-PSP-F
HOOD - #2



PLAN VIEW - Hood #1
7' 3.00" LONG 5430ND-2-PSP-F



PLAN VIEW - Hood #2
4' 4.00" LONG 3044BD-2-PSP-F

REVISIONS	
DESCRIPTION	DATE

INDIANA OFFICE

WWW.CAPTIVEDESIGN.COM

SNS LANCASTER, CA
LANCASTER, CA, 93536

DATE:	6/11/2019
DWG.#:	3864344
DRAWN BY:	DCM-56
SCALE:	3/4" = 1'-0"
MASTER DRAWING	

SHEET NO.
2



FOODSERVICE CONSULTANT

LANDMARK
KITCHEN DESIGN, LLC

ARCHITECT ANDERSON AND ASSOCIATES
185 WEST HANCOCK
PO BOX 1000
www.architectsland.com

TENANT IMPROVEMENT
FOR




1966 WEST AVE. L
LANCASTER, CA

4-24-18	BUILDING DEPT SUBMITTAL
1	
2	
3	
4	

EXHAUST
HOOD SHOP
DRAWING

FS-5.2



TENANT IMPROVEMENT
FOR



1966 WEST AVE. L
LANCASTER, CA

4-24-18 BUILDING DEPT SUBMITTAL

1
2
3
4

EXHAUST
HOOD SHOP
DRAWING








FS-5.3

Fire System Information - Job#3864344

FIRE SYSTEM NO.	Tag	TYPE	SIZE	FLOW POINTS	INSTALLATION	
					SYSTEM	LOCATION ON HOOD
1		Ansul R102	3.0/3.0	17	Fire Cabinet Right	Right

GAS VALVE(S)

FIRE SYSTEM NO.	TAG	TYPE	SIZE	SUPPLIED BY
1		Mechanical	1.500	Distributor



NOTES


- FIELD PIPE DROPS AS SHOWN
- SLEEVING, ELBOWS, TEES, AND NOZZLES SUPPLIED BY CAS
- RELOCATE NOZZLES IF FLOW PATTERN IS BLOCKED BY SHELVEING, SALAMANDERS, ETC.
- MAXIMUM 9 ELBOWS IN SUPPLY LINE.
- MINIMUM 72 INCHES OF AGENT LINE FROM TANK TO FIRST NOZZLE.
- IF APPLICABLE, PRE-PIPED CHARBROILER DROPS ARE SHIPPED LOOSE.
- FACTORY PIPING EXTENDS A MAXIMUM OF 6" ABOVE THE TOP OF THE HOOD.

- APPLIANCE DIMENSIONS LISTED REPRESENT THE COOKING SURFACE SIZE, NOT THE OVERALL APPLIANCE SIZE.

- THIS FIRE SYSTEM COMPLIES WITH U.L. 300 REQUIREMENTS

Job #: 3864344
Job Name: SNS LANCASTER, CA

System Size: ANSUL-3.0/3.0 Total FP required: 17
Hood # 1 7' 3.00" Long x 54" Wide x 30" High
Riser # 1 Size: 14" Dia.
Hood # 1 Metal Blow-Off Caps included.
Hood # 2 4' 4.00" Long x 30" Wide x 44" High
Riser # 1 Size: 10" Dia.
Hood # 2 Metal Blow-Off Caps included.



TYPICAL ANSUL R-102 SYSTEM LAYOUT

REVISIONS

DESCRIPTION	DATE:
Δ	
Δ	
Δ	
Δ	
Δ	

INDIANA OFFICE

WWW.CAPTIVEFIRE.COM

20 E. Airport Rd. Ste. 100, Brownsburg, IN 46112 PHONE: (317) 852-3770 FAX: (919) 227-5929 EMAIL: reg56@captivefire.com

SNS LANCASTER, CA

LANCASTER, CA, 93536

DATE: 6/11/2019

DWG.#: 3864344

DRAWN BY: DCM-56

SCALE: 3/4" = 1'-0"

MASTER DRAWING

SHEET NO. 3

EXHAUST FAN INFORMATION - Job#3864344

FAN UNIT NO.	TAG	FAN UNIT MODEL #	CFM	ESP.	RPM	H.P.	B.H.P.	Ø	VOLT	FLA	DISCHARGE VELOCITY	WEIGHT (LBS.)	SONES
1		DU50HFA	900	1.100	1500	0.500	0.3680	3	208	2.0	342 FPM	87	15.9
2		DU180HFA	1812	1.150	1062	1.000	0.5440	3	208	3.8	418 FPM	148	12.4

CONDENSER DETAILS

FAN UNIT NO.	TAG	FAN UNIT MODEL #	CONDENSER NO.	TONNAGE	VOLTAGE	PHASE	FREQUENCY	MCA	RLA	MAX. FUSE SIZE	MIN. WIRE SIZE	SEER
3		A1-15D-MPU	1	2.5	208-230	3 PHASE	60 Hz	11.2 Amps	9.07 Amps	20 Amps	14 AWG	14
			2	2.5	208-230	3 PHASE	60 Hz	11.2 Amps	9.07 Amps	20 Amps	14 AWG	14

MUA FAN INFORMATION - Job#3864344

FAN UNIT NO.	TAG	FAN UNIT MODEL #	BLOWER	HOUSING	MIN CFM	DESIGN CFM	ESP.	RPM	H.P.	B.H.P.	Ø	VOLT	FLA	COOLING COIL ENTERING DB TEMP.	COOLING COIL ENTERING WB TEMP.	COOLING COIL LEAVING DB TEMP.	COOLING COIL LEAVING WB TEMP.	COOLING COIL TOTAL CAPACITY	COOLING COIL SENSIBLE CAPACITY	COOLING COIL LATENT CAPACITY	WEIGHT (LBS.)	SONES
3		A1-15D-MPU	15MF-1-MOD	A1	-	2170	0.575	2168	2.000	1.4340	3	208	6.1	100.0°F	65.0°F	73.2°F	55.9°F	54.1 MBH	54.1 MBH	0.0 MBH	1238	31

FAN OPTIONS

FAN UNIT NO.	TAG	OPTION (Qty. - Descr.)
1		1 - Grease Box 1 - Fan Base Ceramic Seal - Ship Loose - For Grease Ducts
2		1 - Grease Box
3		1 - 5 Ton 2 Circuit (2.5/2.5) Modular Packaged Cooling Option for Size 1 MUA (1,800 to 3,000 cfm), 208V/230V, 3 phase, Cooling Thermostat or Programmable Stat Required for Proper Operation. 1 - Insulated Blower Section Size 1-2 Commercial 1 - Mod Package Unit AC Controls for Untempered Fans 1 - Condenser Support for Size 1 Mod Package Unit 1 - Motorized Backdraft Damper for Size 1 Housing 1 - Condenser Sled Option for size 1 double condenser MPUs. 1 - Condensing Unit Locking Caps For Double Condenser Units. 1 - Separate 120V Wiring Package (Required and used only for DCV or Prewire with VFD) - Three Phase Only


FAN ACCESSORIES

FAN UNIT NO.	TAG	EXHAUST				SUPPLY		
		GREASE CUP	GRAVITY DAMPER	WALL MOUNT	SIDE DISCHARGE	GRAVITY DAMPER	MOTORIZED DAMPER	WALL MOUNT
1		YES						
2		YES						
3							YES	

CURB ASSEMBLIES

NO.	ON FAN	WEIGHT	ITEM	SIZE
1	# 1	53 LBS	Curb	19.500"W x 19.500"L x 24.000"H Vented Hinged 16 Gauge
2	# 2	92 LBS	Curb	26.500"W x 26.500"L x 20.000"H Vented Hinged 16 Gauge
3	# 3	186 LBS	Rail	6.000"W x 21.000"L x 15.000"H
	# 3		Rail	6.000"W x 21.000"L x 15.000"H
	# 3		Rail	6.000"W x 21.000"L x 15.000"H
	# 3		Rail	6.000"W x 21.000"L x 15.000"H
3	# 3	186 LBS	Curb	21.000"W x 21.000"L x 15.000"H 16 Gauge

FAN #1 DU50HFA - EXHAUST FAN



FEATURES:

- DIRECT DRIVE CONSTRUCTION (NO BELTS/PULLEYS)
- ROOF MOUNTED FANS
- RESTAURANT MODEL
- UL705 AND UL762 AND ULC-S645
- VARIABLE SPEED CONTROL
- INTERNAL WIRING
- WEATHERPROOF DISCONNECT
- THERMAL OVERLOAD PROTECTION (SINGLE PHASE)
- HIGH HEAT OPERATION 300°F (149°C)
- GREASE CLASSIFICATION TESTING


NORMAL TEMPERATURE TEST
EXHAUST FAN MUST OPERATE CONTINUOUSLY WHILE EXHAUSTING AIR AT 300°F (149°C) UNTIL ALL FAN PARTS HAVE REACHED THERMAL EQUILIBRIUM, AND WITHOUT ANY DETERIORATING EFFECTS TO THE FAN WHICH WOULD CAUSE UNSAFE OPERATION.

ABNORMAL FLARE-UP TEST
EXHAUST FAN MUST OPERATE CONTINUOUSLY WHILE EXHAUSTING BURNING GREASE VAPORS AT 600°F (316°C) FOR A PERIOD OF 15 MINUTES WITHOUT THE FAN BECOMING DAMAGED TO ANY EXTENT THAT COULD CAUSE AN UNSAFE CONDITION.

OPTIONS

GREASE BOX.
FAN BASE CERAMIC SEAL - SHIP LOOSE - FOR GREASE DUCTS.

FAN #2 DU180HFA - EXHAUST FAN



FEATURES:


- DIRECT DRIVE CONSTRUCTION (NO BELTS/PULLEYS)
- ROOF MOUNTED FANS
- RESTAURANT MODEL
- UL705 AND UL762 AND ULC-S645
- VARIABLE SPEED CONTROL
- INTERNAL WIRING
- WEATHERPROOF DISCONNECT
- THERMAL OVERLOAD PROTECTION (SINGLE PHASE)
- HIGH HEAT OPERATION 300°F (149°C)
- GREASE CLASSIFICATION TESTING

NORMAL TEMPERATURE TEST
EXHAUST FAN MUST OPERATE CONTINUOUSLY WHILE EXHAUSTING AIR AT 300°F (149°C) UNTIL ALL FAN PARTS HAVE REACHED THERMAL EQUILIBRIUM, AND WITHOUT ANY DETERIORATING EFFECTS TO THE FAN WHICH WOULD CAUSE UNSAFE OPERATION.

ABNORMAL FLARE-UP TEST
EXHAUST FAN MUST OPERATE CONTINUOUSLY WHILE EXHAUSTING BURNING GREASE VAPORS AT 600°F (316°C) FOR A PERIOD OF 15 MINUTES WITHOUT THE FAN BECOMING DAMAGED TO ANY EXTENT THAT COULD CAUSE AN UNSAFE CONDITION.



OPTIONS

GREASE BOX.




PITCHED CURBS ARE AVAILABLE FOR PITCHED ROOFS.

SPECIFY PITCH:
EXAMPLE: 7/12 PITCH = 30° SLOPE




PITCHED CURBS ARE AVAILABLE FOR PITCHED ROOFS.

SPECIFY PITCH:
EXAMPLE: 7/12 PITCH = 30° SLOPE



REVISIONS

DESCRIPTION	DATE:
Δ	
Δ	
Δ	
Δ	
Δ	



CAPTIVE
Indiana Office
20 E. Airport Rd. Ste. 100, Brownsburg, IN 46112 PHONE: (317) 852-3770 FAX: (919) 227-5929 EMAIL: reg56@captiveair.com

SNS LANCASTER, CA
LANCASTER, CA, 93536

DATE: 6/11/2019

DWG.#:
3864344

DRAWN BY:
DCM-56

SCALE:
3/4" = 1'-0"

MASTER DRAWING

SHEET NO.
4



TENANT IMPROVEMENT FOR



1966 WEST AVE. L
LANCASTER, CA

4-24-18 BUILDING DEPT SUBMITTAL

1
2
3
4

EXHAUST
HOOD SHOP
DRAWING

FS-5.4



TENANT IMPROVEMENT
FOR



1966 WEST AVE. L
LANCASTER, CA


4-24-18 BUILDING DEPT SUBMITTAL

1
2
3
4

EXHAUST
HOOD SHOP
DRAWING

FS-5.5

REVISIONS	
DESCRIPTION	DATE
Δ	
Δ	
Δ	
Δ	
Δ	



INDIANA OFFICE
20 E. Airport Rd. Ste. 100, Brownsburg, IN 46112
PHONE: (317) 852-3770 FAX: (919) 227-5929
EMAIL: reg56@captiveaire.com
WWW.CAPTIVEAIR.COM

SNS LANCASTER, CA
LANCASTER, CA, 93536

DATE: 6/11/2019

DWG.#:
3864344

DRAWN BY:
DCM-56



SCALE:
3/4" = 1'-0"

MASTER DRAWING

SHEET NO.
5


- FAN #3 A1-150-MPU - SUPPLY FAN
1. SUPPLY UNIT WITH 15" DIRECT DRIVE FAN IN SIZE #1 HOUSING
2. INTAKE HOOD WITH EZ FILTERS
3. DOWN DISCHARGE - AIR FLOW RIGHT -> LEFT
4. 5 TON, DUAL CIRCUIT (2.5/2.5) MODULAR PACKAGED COOLING OPTION FOR SIZE 1 MODULAR PACKAGED UNIT. INCLUDES CONDENSER, DX COIL, FILTER/DRYER KIT, THERMAL EXPANSION VALVE, R410A REFRIGERANT, AND REFRIGERANT PIPING. (1,800 TO 3,000 CFM) NOT BUILT WITH OPPOSITE SIDE CONTROLS OR OPPOSITE AIRFLOW DIRECTION. CONDENSERS REQUIRE SEPARATE 208V, 3 PHASE POWER SUPPLY UNLESS ORDERED WITH SINGLE POINT CONNECTION. COIL = 2E20902ME
5. INSULATED BLOWER HOUSING SIZES 1-2 COMMERCIAL MODULAR
6. CONTROL PACKAGE FOR MOD PACKAGE UNIT COOLING ONLY UNIT. INCLUDES AIRFLOW PROVING SWITCH, RTULINK-ACHP BOARD AND TERMINAL BLOCKS.
7. SUPPORT SHELL FOR SIZE 1 MODULAR PACKAGE UNIT. INCLUDES CONTROL VESTIBULE. INCLUDES CONDENSER SUPPORTS. DOES NOT INCLUDE RETURN AIR OR INLET AIR DAMPER.
8. MOTORIZED BACK DRAFT DAMPER 16" X 16" FOR SIZE 1 UNTEMPERED UNITS W/EXTENDED SHAFT, STANDARD GALVANIZED CONSTRUCTION, 3/4" REAR FLANGE, LOW LEAKAGE, TYPED ACTUATOR INCLUDED
9. CONDENSER SLED OPTION FOR SIZE 1 DOUBLE CONDENSER MPUS. CONDENSERS MOUNTED ON OPPOSITE SIDE OF UNIT CONSTRUCTION. OPTION REDUCES HEIGHT OF UNIT. SKID WIDTH IS 79".
10. LOCKING CAPS FOR DOUBLE CONDENSER UNITS. CONSISTS OF 4 LOCKING CAPS, PART# MCP-4, AND 1 KEY. PART# NC-KEY.
11. SEPARATE 120VAC WIRING PACKAGE FOR MAKE-UP AIR UNITS. OPTION MUST BE SELECTED WHEN MOUNTING VFD IN PREWIRE PANEL OR WITH DCV PACKAGE. PROVIDES SEPARATE 120VAC INPUT TO SUPPLY FAN. THIS 120V SIGNAL MUST BE RUN BY ELECTRICIAN FROM DCV TO MUA SWITCH.

*NOTE: SUPPLY DUCT MUST BE INSTALLED TO MEET SMACNA STANDARDS. A MINIMUM STRAIGHT DUCT LENGTH MUST BE MAINTAINED DOWNSTREAM OF UNIT DISCHARGE AS OUTLINED IN AMCA PUBLICATION 201. DO NOT RELY ON UNIT TO SUPPORT DUCT IN ANY WAY. FAILURE TO PROPERLY SIZE DUCTWORK MAY CAUSE SYSTEM EFFECTS AND REDUCE PERFORMANCE OF THE EQUIPMENT.
SUGGESTED STRAIGHT DUCT SIZE IS 14" x 14"




PITCHED CURBS ARE AVAILABLE FOR PITCHED ROOFS.


SPECIFY PITCH:
EXAMPLE: 7/12 PITCH = 30° SLOPE



Typical Drain Trap Install




Recommended Cooling Coil Drain Trap Configuration



Notes:


- 1) 1" diameter PVC Pipe only
- 2) Use only low profile couplings
- 3) Add clean out as shown

Seismic Exhaust Curb




- Curbs are built in the following way.
- Metal is .060" Aluminized Sheet Metal
 - All seams are welded with MIG using ER70S-6 wire.
 - Top Flange is 100" wide.
 - Bottom Flange is 300" wide.
 - Widths and lengths vary by product installed.
 - Max curb pitch is 5" on 12"

Curb Dimensions		
Unit Type	DIM 'A'	DIM 'B'
Exhaust	19.5'-42.5"	19.5'-42.5"




Seismic Supply Curb




- Curbs are built in the following way.
- Metal is .060" Aluminized Sheet Metal
 - All seams are welded with MIG using ER70S-6 wire.
 - Top Flange is 100" wide.
 - Bottom Flange is 300" wide.
 - Widths and lengths vary by product installed.
 - Max curb pitch is 5" on 12"

Curb Dimensions		
Unit Type	DIM 'A'	DIM 'B'
Supply	19.5'-52.75"	19.5'-52.75"



Seismic Support Rails




- For support rails are built in the following way.
- Metal is .060" Aluminized Sheet Metal
 - All seams are welded with MIG using ER70S-6 wire.
 - Top is capped.
 - Bottom Flange is 300" wide.
 - Lengths vary by product installed.
 - Max curb pitch is 5" on 12"

Rail Dimensions	
Unit Type	DIM 'A'
Rails	21'-69"

Seismic Hardware


Rooftop Curb Attachment Plate

Steel Support Block, 3' x 3' by .250" Thick steel plate and galvanized for weather resistance.
Part number for the plate is 911334140 (McCollum A0017326)



Lag Bolt for Rooftop Curb Attachment

Steel Lag Bolt, .500" Diameter, 1 1/2" of Bolt must be installed into the wooden support structure.
Lag bolt must not be installed in the end grain.
Part Number for the bolt is 914764722 (McCollum A0017380)



REVISIONS

REVISION	DATE:

CAPTIVE
INDIANA OFFICE
WWW.CAPTIVEIND.COM

20 E. Airport Rd. Ste. 100, Brownsburg, IN 46112 PHONE: (317) 852-3770 FAX: (919) 227-5929 EMAIL: reg56@captiveinc.com

SNS LANCASTER, CA
LANCASTER, CA, 93536

DATE: 6/11/2019

DWG.#:
3864344

DRAWN BY:
DCM-56

SCALE:
3/4" = 1'-0"

MASTER DRAWING

SHEET NO.
6



FOODSERVICE CONSULTANT
LANDMARK
KITCHEN DESIGN, LLC
AMERICAN ARCHITECTS AND
DESIGNERS
1155 WEST 10TH AVENUE
DENVER, CO 80202
www.landmarkkitchen.com

TENANT IMPROVEMENT
FOR



1966 WEST AVE. L
LANCASTER, CA

4-24-18 BUILDING DEPT SUBMITTAL

1
2
3
4

EXHAUST
HOOD SHOP
DRAWING



FS-5.6

NO.	TAG	PACKAGE #	LOCATION	SWITCHES		OPTION	FANS CONTROLLED			
				LOCATION	QUANTITY		TYPE	#	H.P.	VOLT
1	DCV-2111	Utility Cabinet Right	04 - Utility Cabinet Right	1 Light	Smart Controls DCV	Exhaust	3	0.550	208	2.0
			Hood # 1	1 Fan		Exhaust	3	1.000	208	3.8
						Supply	3	2.000	208	6.1




MONITORING AND CONTROL POINTS LIST

SCV Packages	Function	SC Packages	Function
Room Temperature	MONITOR	Room Temperature	MONITOR
Duct Temperature	MONITOR	Duct Temperature	MONITOR
MUA Discharge Temperature	MONITOR	MUA Discharge Temperature	MONITOR
Kitchen RTU Discharge Temperature	MONITOR	Kitchen RTU Discharge Temperature	MONITOR
Free Space	MONITOR	Control Faults	MONITOR
Free Airspace	MONITOR	Free Airspace	MONITOR
Free Power	MONITOR	Free Status	MONITOR
VFD Faults	MONITOR	PCU Faults	MONITOR
Compressor Faults	MONITOR	PCU Filter Clog Percentages	MONITOR
Free Faults	MONITOR	Free Condition	MONITOR
Free Status	MONITOR	COPE Free System	MONITOR
PCU Faults	MONITOR	Building Faults	MONITOR
PCU Filter Clog Percentages	MONITOR	Free Buttons	MONITOR & CONTROL
Free Condition	MONITOR	Legs Buttons	MONITOR & CONTROL
COPE Free System	MONITOR	Wash Buttons	MONITOR & CONTROL
Building Pressures	MONITOR		
Free Free Button	MONITOR & CONTROL		
Free Buttons	MONITOR & CONTROL		
Legs Buttons	MONITOR & CONTROL		
Wash Buttons	MONITOR & CONTROL		



- ## Demand Control Ventilation Hood Control Panel Specifications:
- Controls shall be listed by ETL (UL 508A) and shall comply with demand ventilation system turnaround requirements outlined in IECC 403.2.8 (2015).
 - The control enclosure shall be NEMA 1 rated and listed for installation inside of the exhaust hood utility cabinet. The control enclosure may be constructed of stainless steel or painted steel.
 - Temperature probe(s) located in the exhaust duct riser(s) shall be constructed of stainless steel.
 - A digital controller shall be provided to activate the hood exhaust fans dynamically based on a fixed differential between the ambient and duct temperature sensors. This function shall meet the requirements of IMC 507.1.1.
 - A digital controller shall provide adjustable hysteresis settings to prevent cycling of the fans after the cooking appliances have been turned off and/or the heat in the exhaust system is reduced.
 - A digital controller shall provide an adjustable minimum fan run-time setting to prevent fan cycling.
 - Variable Frequency Drives (VFDs) shall be provided for fans as required. The digital controller shall modulate the VFDs between a minimum setpoint and a maximum setpoint on demand. The duct temperature sensor input(s) to the digital controller shall be used to calculate the speed reference signal.
 - The VFD speed range of operation shall be from 0% to 100% for the system, with the actual minimum speed set as required to meet minimum ventilation requirements.
 - An internal algorithm to the digital controller shall modulate supply fan VFD speed proportional to all exhaust fans that are located in the same fan group as the supply fan.
 - The system shall operate in PREP Mode during light cooking load or COOL DOWN Mode sufficient heat remains underneath the hood system after cooking operations have completed. Operation during either of these periods will disable the supply fans and provide an exhaust fan speed that is equal to the minimum ventilation requirement.
 - A digital controller shall disable the supply fan(s), activate the exhaust fan(s), activate the appliance shunt trip, and disable an electric gas valve automatically when fire condition is detected on a covered hood.
 - A digital controller shall allow for external BMS fan control via Dry Contact (external control shall not override fan operation logic as required by code).
 - An LCD interface shall be provided with the following features:
 - a. On/Off push button fan & light switch activation
 - b. Integrated gas valve reset for electronic gas valves (no reset relay required)
 - c. VFD Fault display with audible & visual alarm notification
 - d. Duct temperature sensor failure detection with audible & visual alarm notification
 - e. Mix-wired duct temperature sensor detection with audible & visual alarm notification
 - f. A single low voltage Cat-5 RJ45 wiring connection
 - g. An energy usage indicator that utilizes measured kWh from the VFDs



TYPICAL HOOD CONTROL PANEL INSTALLATION

Sequence of Operations:

The hood control panel is capable of operating in one or more of the following states at any given time:

- **Automatic:** The system operates based on the differential between room temperature and the temperature at the hood cavity or exhaust duct collar. Fans activate at a configurable temperature differential threshold. Depending on the job configuration each fan zone can be configured as static or dynamic. Static fans will operate at a constant variable motor (such as EC Motors or VFD driven motors) modulate with temperature. If the panel is equipped with variable speed fans and the zone is defined as "dynamic," these will modulate within a user-defined range based on the temperature differential. Panels equipped with variable speed fans and a fan zone defined as "static," fans will run at a set speed calculated for the demand. Command ventilation systems are capable of modulating exhaust and make up air fan speeds per the requirements outlined in IECC 403.2.8.
- **Manual:** The system operates based on human input from an HMI.
- **Schedule:** A weekly schedule can be set to run fans for a specified period throughout the day. There are three occupied times per day to allow for the user to set up a time that is suitable to their needs. Any time that is within the defined occupied time, the system will run at modulation mode and follow the fan procedure algorithm based on temperature during this time. During unoccupied time, the system will have an extra offset to prevent unintended activation of the system during a time where the system is not being occupied.
- **Other:** The system operates based on the input from an external source (DDC, BMS or hard-wired interlock)

REVISIONS	
DESCRIPTION	DATE:

TENANT IMPROVEMENT
FOR

1966 WEST AVE L
LANCASTER, CA

9-24-18	BUILDING DEPT SUBMITTAL
1	
2	
3	
4	

EXHAUST HOOD SHOP DRAWING

FS-5.8

DuctWork #1 Parts - Job#3864344


Tag	Part #	CFM	S.P.	Weight	Velocity	QTY	Description
P1	DW1445ASY	1812	-0.0473	7.22	1695.02	1	Single Wall Duct 45 Degree Elbow, 14" Duct, Assembly.
P2	DW1445ASY	1812	-0.0675	7.22	1695.02	1	Single Wall Duct 45 Degree Elbow, 14" Duct, Assembly.
P3	DW1447LT	1812	-0.0199	21.79	1695.02	1	Single Wall Duct 14" diameter, 47" long, flange at both ends. Stainless Steel.
P4 Assembled w/P5	DW1448AJDKIT	1812	-0.0131	26.62	1695.02	1	Single Wall Duct Adjustable, 14" diameter, 47.5" long, flange at one end With a 14" Adjustable Collar - Stainless Steel.
P5 Assembled w/P4 System at P5	DW2614TP	1812	0	12.53	1695.02	1	Duct to Curb Transition, 26-1/2" Curb to 14" Duct, 16 GA Aluminized. Used on BDU18.
	3M-2000PLUS			0.80		1	Duct - 3M Fire Barrier 2000 Plus Silicone - Used as sealant to Seal Duct Joints.
	735602000			52.00		3	Duct - Duct insulation for zero clearance to combustibles - 300" x 24" x 1-1/2" Roll. Unifrax FyreWrap Elite 1.5.
	BANDING.5			5.00		1	Duct - Fire Barrier Wrap Stainless Steel Banding .5" Width - 200 FT Per Roll.
	DW14CLASY			1.37		4	Duct "V" Clamp With new design 14 Ga Brackets, 14" Duct, Assembly.
	SEAL.50-50			0.50		1	Duct - Fire Barrier Wrap Stainless Steel Banding Seal .5" Width. Quantity of 50.
	TAPEALUM			0.25		1	Duct - Fire Barrier Wrap Aluminum Foil Tape - 3" x 150' Roll.
Total Weight				243.41			

SINGLE WALL FACTORY BUILT DUCTWORK


- ALL DUCTWORK IS REQUIRED TO BE INSTALLED WITH THE MAXIMUM SUPPORT SPACING LISTED BELOW.
- FOR A COMPLETE LIST OF APPROVED SUPPORT METHODS, SEE THE INSTALLATION AND OPERATION MANUAL.
- DUCTWORK SHALL SLOPE NOT LESS THAN 1/16" PER LINEAR FOOT TOWARDS THE HOOD OR AN APPROVED GREASE COLLECTION RESERVOIR.
- WHERE HORIZONTAL DUCTS EXCEED 75 FEET IN LENGTH, THE SLOPE SHALL NOT BE LESS THAN 3/16" PER LINEAR FOOT.

DUCT DIAMETER	HORIZONTAL SUPPORT (ft)	VERTICAL WALL SUPPORT (ft)	VERTICAL CURB SUPPORT (ft)
8"	10'	10'	24'
10"	10'	10'	24'
12"	10'	10'	24'
14"	10'	10'	24'
16"	10'	10'	24'
18"	10'	10'	24'
20"	10'	10'	24'
22"	10'	10'	24'
24"	10'	10'	24'


DuctWork #1 SE View




DuctWork #1 Front View



DuctWork #1 Top View



DuctWork #1 Side View



REVISIONS

DESCRIPTION	DATE:

WWW.CAPTIVEIND.COM



INDIANA Office

20 E. Airport Rd. Ste. 100, Brownsburg, IN 46112 PHONE: (317) 852-3770 FAX: (919) 227-5929 EMAIL: reg56@captiveind.com

SNS LANCASTER, CA

LANCASTER, CA, 93536

DATE: 6/11/2019

DWG.#: 3864344

DRAWN BY: DCM-56

SCALE: 3/4" = 1'-0"

MASTER DRAWING

SHEET NO. 9



TENANT IMPROVEMENT FOR





1966 WEST AVE. L
LANCASTER, CA


4-24-18	BUILDING DEPT SUBMITTAL
1	
2	
3	
4	

EXHAUST
HOOD SHOP
DRAWING

FS-5.9



FLOOR PLAN
SCALE: 1/4" = 1'-0"



SYMBOLS


--- SODA LINE CONDUIT (BY GENERAL CONTRACTOR)

--- WALL BACKING FOR EQUIPMENT ABOVE 36" (BY GENERAL CONTRACTOR)



--- S/S WALL FLASHING (BY K.E.C.)

NOTE:


- SODA CONDUIT LINES ARE FOR SCHEMATIC PURPOSES ONLY.
- G.C. TO COORDINATE CONDUIT LINE RUNS WITH ARCHITECTURAL & STRUCTURAL PLANS.



4-24-18	BUILDING DEPT SUBMITTAL
1	
2	
3	
4	



FLOOR PLAN
SCALE: 1/4" = 1'-0"



FOODSERVICE CONSULTANT
LANDMARK
KITCHEN DESIGN, LLC
ARCHITECT ANDERSON ENGLISH
1815 WEST 10TH AVENUE
DENVER, COLORADO 80202
WWW.LANDMARKKITCHENDESIGN.COM

TENANT IMPROVEMENT
FOR




1966 WEST AVE. L
LANCASTER, CA


4-24-18	BUILDING DEPT SUBMITTAL
1	
2	
3	
4	

FOOD SERVICE
CRITICAL
DIMENSION PLAN


FS-7.0




A BEVERAGE COUNTER ELEVATION
FS-1.0 1/2"=1'-0"




B FRONT COUNTER ELEVATION
FS-1.0 1/2"=1'-0"




C SHAKE STATION ELEVATION
FS-1.0 1/2"=1'-0"




D P.O.S. @ DRIVE THRU ELEV
FS-1.0 1/2"=1'-0"




E WARE WASH / PREP / FRY / DRIVE THRU ELEVATION
FS-1.0 1/2"=1'-0"



F COOK LINE ELEVATION
FS-1.0 1/2"=1'-0"



G STORAGE WALL ELEVATION
FS-1.0 1/2"=1'-0"



H OFFICE ELEVATION
FS-1.0 1/2"=1'-0"



FOODSERVICE CONSULTANT
LANDMARK
KITCHEN DESIGN, LLC
ARCHITECT: ANDREW CHANG AND
TODD HARRIS
DESIGN: ANDREW CHANG
www.landmarkkitchen.com

TENANT IMPROVEMENT
FOR



1966 WEST AVE. L
LANCASTER, CA

4-24-18 BUILDING DEPT SUBMITTAL

EQUIPMENT
ELEVATIONS

FS-8.0

GENERAL CONTRACTOR NOTES:

- General Contractor to cut and provide holes through ceiling,roofs, walls and floors for ducts, refrig. lines etc. in accordance with local fire and building codes and in accordance with duct sizes specified. General Contractor to provide the resealing of all holes (including the "moping-in" of fan curbs and roof jacks.) General Contractor to provide all duct fire separation enclosures, wrappings, etc. as may be required by local building and fire codes.
- Where noise or vibration producing equipment (dish machine, disposer, etc. is located adjacent to dining areas and/or any public areas. Provisions should be made by the General Contractor to "double stud" and sound proof common walls.
- All roof curb and roof jacks to be provided, located and installed by G.C. including resealing of roof and roof penetrations.
- "FS" Drawings are provided for the sole purpose of indicating outlet locations and equipment requirements only and do not relieve the General Contractor or subcontractor of the responsibility of complying with all applicable codes. Please see architect's drawings for all other requirements and codes.
- It is the responsibility of the Owner, Architect and/or General Contractor to inform the K.E.C. in writing, any and all changes and all addendums to plans which are made prior to and during construction. K.E.C. assumes no responsibility for equipment deviations of size and/or utilities from lack of this information. The Owner will be responsible for all cost incurred by failure to give K.E.C. notice of changes.
- Last dated revisions void all previous plans.
- General Contractor to provide floor recesses (flat and level). Vapor Barriers and built in insulated floors (as shown on plans). If applicable.
- Floor finish, cove base and interior cove in walk-in boxes to be provided by General Contractor unless otherwise specified by K.E.C.
- Sleeves & Conduits to be provided by General Contractor in walls, floors & ceiling for lines (drains, refrigeration, etc.) to pass through and G.C.to reseal after lines are run.
All conduit to be round metal, transite, P.V.C. or equal diameter as indicated on plan, minimum bending radius to be 24", factory "L's" will not be permitted. Conduit to meet local codes.
- General Contractor to provide access to hoods at area above hoods for mounting of hood supports. If access is not provided, General Contractor to provide hood supports.
All roof curb & jacks to be provided, located & installed by G.C., including resealing of roof & roof penetrations.
- General Contractor to provide sprinkler heads in walk-in boxes and adequately protected against freezing.
- Removal of window glass, window frames, doors, door frames and center post for entry of equipment shall be the responsibility of the General Contractor and at no expense to K.E.C. if necessary.
- General Contractor to provide all wall backing per location and specification by K.E.C.
- All dimensions shown are measured from finished walls, floors, ceilings and/or column to center lines of stubs or outlets. Allowances shall be made for miscellaneous obstructions, structures, venting, electrical, plumbing and thickness of finishes when framing and/or roughing-in as required.
- When equipment is noted as existing or by vendor, utility requirements should match as indicated on the manufacturer's data plate. If existing equipment is not relocated, reconnect as required by code.
- Where indicated to connect in or through valve compartment, contractor shall stub-up into valve compartment at height indicated on rough-in plan, cap their work and make final connections after equipment is in place.
- General Contractor to provide all duct chases from hood thru roof, sized & constructed, conforming to codes.
- General Contractor to provide waste container at job site for K.E.C.
- Slope floors to floor drains.
- Provide door wall openings and or passages to assure access for all kitchen equipment and front end items. Coordinate sizes with K.E.C.
- Provide walk-in refrigerator/freezer depressions, to detail.
- G.C. to provide enclosures from top of walk-in to ceiling (if required).
- G.C. to provide enclosures from top of exhaust hood to ceiling (if required).
- Provide coved base-molding or coved integral floor materials as required at all vertical surfaces for kitchen floors.

VENTILATION NOTES

- Mechanical Contractor to provide fans, duct work, (all welding of hood and duct required) controls, duct collar, final connection, hanging of hoods, permits and make-up air equipment. The above furnished by H.V.A.C. contractor unless noted on drawing or contracted with K.E.C.
- Mechanical contractor (H.V.A.C.) to balance exhaust system.
- All duct collars, cutouts and penetrations in hoods to be located and provided by Mechanical Contractor in field.

REFRIGERATION CONTRACTORS NOTES

- Refrigeration line to be installed and protected from damage. Refrigeration lines for walk-in refrigerators & freezers, to run overhead and drop down from compressors to evaporators.
- All built-in walk-in refrigeration boxes shall be complete with insulation with proper vapor barrier and interior lights and switches outside. Electrical connection and mounting by E.C.
- Do Not Scale. Use written dimensions shown on "K" plans.

FIRE PROTECTION SYSTEM NOTES

- Where indicated on drawings a dry or liquid chemical system shall be provided to protect all cooking exhaust hoods, ducts, and cooking appliances against fire and re-flash by a fire control system. The size and number of systems shall be in conformance with N.F.P.A Pamphlet 96, and local and state codes. The system shall be installed by authorized installers.
- The system shall be of the cartridge operated type, automatic actuated or be manually operable at the nozzle release and a remote manual pull operator shall be located as shown on the drawing. Actuation of the system shall provide automatic gas and/or electric fuel line cut-off.
- Electrically controlled or manually controlled gas solenoid valve shall be installed by the plumbing contractor. The electrical contractor shall furnish and install line voltage wiring and conduit from cut-off relay to solenoid valve and connect cut-off relay and solenoid valve as required.
- Electrical cooking equipment shall be shutoff at the electrical panel by means of shunt trips. Electrical contractor shall furnish and install shunt trips, line voltage wiring and conduit from fir protection micro-switch, or equivalent, to panels, to meet all local codes.
- All hand held fire extinguishers to be provided by General Contractor.

MASONRY CONTRACTORS NOTES

- All curbs & or recessed mat area dimensions are finished dimensions. Verify face and top finishes (where curb is exposed) with Architect, General Contractor or Owner.
- All curb heights to be taken from finished floor to top of finished curb.
- All curb dimensions are taken from finished wall to face of finished curb, or from finished face of curb to finished face of curb.
- Provide a 3" - 4" radius cove where finished face of curb intersects the finished floor.
- See Plumbing plan(s) for exact location of floor sinks and floor drains. Verify with P.C.
- Do Not Scale, Use written dimensions shown on "K" plans.
- Provide masonry curbs with trowel-smooth and level finish as required.

PLUMBING CONTRACTOR NOTES

- All rough-ins related to foodservice equipment only. Please see architectural/engineering plans for additional plumbing requirements and codes.
- Final connections to all equipment to be by plumbing contractor, ALL required materials, such as stops, valves, filters, check valves, pressure reducing valves, gate valves, solenoid valves, syphon breakers, piping, tubing, misc. fittings, traps, etc. shall be supplied by the Plumbing Contractor unless otherwise specified.
- Water quality requirement. The recommended minimum water quality standards whether untreated or pre-treated, based upon 10 hours of use per day, and a daily blow-down, are as follows:

A. Total dissolved solids	less than 300 parts per million
B. Total alkalinity	less than 85 parts per million
C. Silica	less than 13 parts per million
D. pH Factor	greater than 7.5
- Verify all plumbing rough-ins and location with owner, vendor or G.C. on existing equipment or other equipment not provided by K.E.C.
- Plumbing Contractor to Furnish and Install the following as per code:

A. All water, waste, gas, and steam service to point of rough-in as shown on plan. Rough-in outlets to stub 4" out of walls at height indicated from finished floor to center line of outlet.								
B. Pressure reducing and/or regulating valves for dishwashers, booster heaters, and as otherwise noted, in kitchen areas.								
C. All floor sinks, complete with top grates, and removable sediment buckets set flush with finished floor, unless noted or as per local code.								
D. All waste lines, direct or indirect, except as noted, shall be pitched downward. All waste lines shall have adequate clean-out provisions.								
E. Indirect waste lines for walk-in refrigerators/freezers, pitched 4"/12" (minimum) and with a "P" trap at end over floor sink as required by local code.								
F. Heater tape, with 35 watts per lineal foot of drain line, and insulation of all drain lines inside freezer compartments.								
G. Install in an accessible location the fire control gas shutoff valve as supplied by Fire Protection System Supplier. (if gas cooking equipment is used).								
H. Vacuum breakers as required.								
I. Insulation of all steam, hot water and condensate lines in kitchen.								
J. Clean-out valves for steam condensate, and air lines.								
K. All piping condensate & drain lines, to and from equipment must be kept a minimum of (6") above finished floor to allow for cleaning, & or prevailing local code.								
L. In line water filters are recommended for the following equipment: (Water filter by P.C. unless otherwise noted) <table><tr><td>Water Heaters</td></tr><tr><td>Booster Heaters</td></tr><tr><td>Sink Heaters</td></tr><tr><td>Dish Washers</td></tr><tr><td>Glass Washers</td></tr><tr><td>Soda Systems</td></tr><tr><td>Ice Machines</td></tr><tr><td>Steam Equipment</td></tr></table>	Water Heaters	Booster Heaters	Sink Heaters	Dish Washers	Glass Washers	Soda Systems	Ice Machines	Steam Equipment
Water Heaters								
Booster Heaters								
Sink Heaters								
Dish Washers								
Glass Washers								
Soda Systems								
Ice Machines								
Steam Equipment								
- Plumbing Contractor to interconnect dish machine with booster heater and water-type ventilators with control panels as per manufacturer's instruction, when applicable and noted.
- All lines routed through equipment shall not interfere with intended use of, or servicing of equipment.
- All vent pipes are to be concealed in walls or column chases.
- Interconnection between steam equipment and steam generator.
- Grease trap to be specified and located by mechanical engineer and provided and installed by mechanical or plumbing contractor.
- Where equipment is noted as existing, utility requirements should be verified and match as indicated on manufacturer's date plate. If equipment is not relocated, reconnect as required by code. Plumbing Contractor to verify existing utilities and equipment requirements and re-use if possible.
- All plumbing locations are shown at optimum spots. Utilize all existing services where applicable.
- All plumbing to be concealed within walls where possible.
- Hot water heater to provide a minimum of 140 degree water to all kitchen equipment.
- All dimensions shown are measured from finished walls, floors ceilings and/or column to center lines of stubs or outlets. The plumbing contractor shall make allowances for miscellaneous obstructions such as piping mains, electrical components, structures, venting and thickness of finishes when roughing-in as required.
- All faucets and/or disposers located on Food Service Plan shall be provided by K.E.C. and installed by Plumbing Contractor, unless otherwise noted.
- Hand sinks are to be mounted and installed by Plumbing Contractor.

ELECTRICAL CONTRACTOR NOTES

- The electrical specifications and connections shown on these plans are for food service equipment requirements only. It is the responsibility of the ELECTRICAL CONTRACTOR to consult the architect's, mechanical engineers and/or general contractor's plans and the owner for further building electrical requirements.
- Access areas and cut-ins on custom and buyout equipment and fixtures shall be provided by the K.E.C. as required for proper installation of electrical outlets, junction boxes, home runs, etc. The electrical contractor shall provide and install shields and extension boxes as required.
- The Electrical Contractor shall connect all compressors and provide fused disconnects, magnetic starters and thermo overload protection as required.
- Vapor proof light fixtures for exhaust hoods shall be furnished by the HOOD SUPPLIER. The Electrical Contractor shall supply and install pull boxes,conduit, wire, bulbs, etc. Provide and connect to a wall mounted switch (with pilot light) located per plans.
- Vapor proof light fixtures for walk-in coolers and freezers shall be furnished with an exterior pilot light switch by the Walk-in Supplier. It shall be the responsibility of the Electrical Contractor to interconnect and install these items as required. Electrical Contractor shall connect door heaters, relief ports. E.C. to supply install, & connect all drain line heater tape.
- Electrical Contractor to interconnect the Remote Refrig-erations' Compressor, Evaporator, T-stat, Solenoid and Defrost Timer (All Controls) where required.
- All electrical materials including wiring, flex, conduit, switches, disconnects, magnetic starters, thermo-overload protectors, transformers, electrical panels, cords, plugs, receptacles, bulbs, etc. shall be supplied by the electrical contractor unless specified in these plans or in writing by the Food Service Equipment Contractor.
- It shall be the responsibility of the Electrical Contractor to provide water proof power outlet(s) on the roof for exhaust system fan(s) make-up air fan(s) and refrigeration system(s) as required. Low voltage (or common voltage) wiring shall also be supplied and installed by the electr-ical contractor when necessary to control and interconnect the above systems.
- The electrical contractor shall furnish and install any and all electrical contractors as required by applicable codes and ordinances.
- All dimensions shown on these plans are measured from finished walls, floors, ceilings and/or column center lines or grid lines to enter lines of outlets and pull boxes. The Electrical Contractor shall make allowances for finishes when roughing-in as required.
- The Electrical Contractor shall provide and install element contractor (relay) shutoffs (shunt trip) and/or solenoid shutoff valve and interconnect with the fire suppression system for the cooking equipment, to shut off all equipment automatically in case of fire. Verify with local codes for shutdown of exhaust fan(s) and or make-up air fan(s) requirements.
- All 115 volt convenience outlets not designated with spec-ific loads are to be rated 20.0 amps. Electrical Contractor is to provide any additional outlets as called for by architect, owner and/or general contractor.
- Electrical Contractor to provide caps and cords for all equipment where caps and cords are not standard with manufa-cture. Electrician to also shorten any cords supplied with equipment if requested to do so by owner or Food Service Equipment Contractors' representative.
- Electrical Contractor to provide all rough-in building services and make final connections to all food service equipment provided by K.E.C. This shall include the instal-lation mounting of the Air Curtain(s),/Microswitch(s).
- Electrical Contractor to provide temporary power to Food Service Equipment Contractors' installers, as required.
- All rough-ins are shown in optimum spots, utilize all existing services when applicable.
- All receptacles and junction boxes to be flushed mounted in walls with stainless steel cover plate.
- Verify all electrical rough-ins and locations with owner, vendor, or General Contractor on existing equipment or other equipment not provided by K.E.C.
- Where applicable, Electrical Contractor to provide conduit wiring, install electrical components, and interwire, between the following:

A. Control panels to ventilators and exhaust/supply fans per manufacture's instructions.
B. Kitchen exhaust hood/ventilators to fire control system and hood controls.
C. Call lights and waitress control systems.
D. Light fixture, chandeliers, etc. Lamps for any light fixtures are to be provided and installed by the Electrical Contractor unless indicated on the lighting schedules or drawings.
E. Module counters and components or equipment mounted on counters.
F. Heat Lamps are to be connected thru remote controls, pilot lights, etc.
- Electrical Contractor to provide and install all light bulbs for fixtures, where applicable.
- All item's shown with P.I. connections, plug into receptacles furnished by the K.E.C. as part of the equipment.
- Where connection is shown as J.B., Electrical Contractor shall connect to J.B. furnished as part of the equipment.
- All horizontal dimensions are from face of finished wall to center-line of outlet or from center-line of outlet to center-line of outlet unless otherwise noted.
- All symbols for outlet on walls are indicated at a specific height. Height of outlet is given from finished floor TO CENTERLINE OF OUTLET.



TENANT IMPROVEMENT FOR



1966 WEST AVE. E. LANCASTER, CA

4-24-18 BUILDING DEPT SUBMITTAL

1
2
3
4

FOOD SERVICE GENERAL NOTES

FS-9.0