








Fire System Information - Job#3864344

FIRE SYSTEM NO.	Tag	TYPE	SIZE	FLOW POINTS	INSTALLATION	
					SYSTEM	LOCATION ON HOOD
1		Ansul R102	3.0/3.0	17	Fire Cabinet Right	Right

GAS VALVE(S)

FIRE SYSTEM NO.	TAG	TYPE	SIZE	SUPPLIED BY
1		Mechanical	1.500	Distributor




- NOTES
- FIELD PIPE DROPS AS SHOWN
 - SLEEVING, ELBOWS, TEES, AND NOZZLES SUPPLIED BY CAS
 - RELOCATE NOZZLES IF FLOW PATTERN IS BLOCKED BY SHELVEING, SALAMANDERS, ETC.
 - MAXIMUM 9 ELBOWS IN SUPPLY LINE.
 - MINIMUM 72 INCHES OF AGENT LINE FROM TANK TO FIRST NOZZLE.
 - IF APPLICABLE, PRE-PIPED CHARBROILER DROPS ARE SHIPPED LOOSE.
 - FACTORY PIPING EXTENDS A MAXIMUM OF 6" ABOVE THE TOP OF THE HOOD.

- APPLIANCE DIMENSIONS LISTED REPRESENT THE COOKING SURFACE SIZE, NOT THE OVERALL APPLIANCE SIZE.

- THIS FIRE SYSTEM COMPLIES WITH U.L. 300 REQUIREMENTS


Job #: 3864344
Job Name: SNS LANCASTER, CA

System Size: ANSUL-3.0/3.0 Total FP required: 17
Hood # 1 7' 3.00" Long x 54" Wide x 30" High
Riser # 1 Size: 14" Dia.
Hood # 1 Metal Blow-Off Caps included.
Hood # 2 4' 4.00" Long x 30" Wide x 44" High
Riser # 1 Size: 10" Dia.
Hood # 2 Metal Blow-Off Caps included.



TYPICAL ANSUL R-102 SYSTEM LAYOUT

REVISIONS	
DESCRIPTION	DATE:



SNS LANCASTER, CA
LANCASTER, CA, 93536

DATE: 6/11/2019

DWG.#:
3864344

DRAWN BY:
DCM-56

SCALE:
3/4" = 1'-0"

MASTER DRAWING

SHEET NO.
3



TENANT IMPROVEMENT
FOR



1966 WEST AVE. L
LANCASTER, CA

4-24-18 BUILDING DEPT SUBMITTAL

1
2
3
4

EXHAUST
HOOD SHOP
DRAWING

FS-5.3