SECTION 260000 – ELECTRICAL GENERAL CONDITIONS

PART 1 GENERAL

1.01 SUMMARY

A. This Section supplements all Sections of the Specifications for Division 26, Division 27, and Division 28 and shall apply to all phases of work hereinafter specified, shown on the Drawings, or required to provide a complete installation of approved electrical systems.

B. The Drawings, General Conditions and General Provisions of the Contract apply to this Section and the other Sections of Division 26, Division 27, and Division 28 of the specifications. Where conflicts arise between these documents, the more stringent provision will be applicable, subject to the interpretation of the Engineer.

C. Furnish all labor, materials, services, and skilled supervision necessary for the construction, erection, installation, connections, testing, and adjustment of all materials and electrical equipment specified herein, or shown or noted on the Drawings, and its delivery to the Owner, complete in all respects and ready for use.

D. Where plans indicate fixtures or equipment will be furnished by this Contractor for installation by other Contractors, this Contractor shall furnish all such equipment, complete in all respects and ready for installation. Drawings, instructions, and manuals supplied with equipment shall be carefully preserved and turned over to the Installing Contractor.

E. Where plans indicate fixtures or equipment will be furnished by others, this Contractor shall provide all rough-in and supplies and shall connect such equipment to the electrical system. Drawings, instructions, and manuals supplied with equipment shall be carefully preserved and turned over to the Architect.

1.02 DEFINITIONS

A. Work: The construction and services required by the Contract Documents whether completed or partially completed and includes all labor, materials, equipment, and services provided or to be provided by the Contractor to fulfill the Contractor's obligations. Work may constitute the whole or a part of the project.

B. Install: To supply and deliver, unload, and inspect for damage.

C. Install: To unpack, assemble, erect, apply, place, finish, cure, protect, clean, connect, and place into operation into the work.

D. Provide: To furnish and Install.

E. Connect: To bring service to the equipment and make final attachment including necessary switches, outlets, boxes, terminations, etc.

F. Concealed: Hidden from sight in chases, furred spaces, shafts, hung ceilings, embedded in construction, in crawl spaces, or buried.

G. Exposed: Not installed underground nor concealed as defined.

H. Drawings: All plans, details, equipment schedules, diagrams, sketches, etc. issued for the construction of the work.

I. Conduit: Conduit, and all required fittings, pull boxes, hangers, and other supports and accessories related to such conduit.

1.03 CODES AND STANDARDS

A. Perform work in accordance with the applicable Building Code, Electrical Code, Fire Code, Mechanical Code, Plumbing Code, Energy Code, and all other applicable codes, amendments, and ordinances. Also perform all work in accordance with the Occupational Safety and Health Administration (OSHA) Regulations, Americans with Disabilities Act (ADA), the Authority Having Jurisdiction, Landlord requirements including Tenant Criteria Manuals and Lease Exhibits, and utility company requirements.

B. Recognized Standards: Design, manufacture, testing and method of installation of all apparatus and materials furnished under the requirements of these Specifications shall conform to the latest publications of the standard rules of Institute of Electrical and Electronic Engineers (IEEE), National Electrical Manufacturers Association (NEMA), Underwriters Laboratories, Inc. (U.L.), National Fire Protection Association (NFPA), American Society for Testing and Materials (ASTM), American National Standards Institute (ANSI), National Electrical Code (NEC), National Electrical Safety Code (NESC), National Electrical Contractors Association (NECA), and American Institute of Steel Construction (AISC).

C. Code or utility company requirements supersede any requirements of the Drawings and/or Specifications. The Contract Documents take precedence where the Contract Documents exceed code, Landlord, utility, or recognized standards requirements.

1.04 PERMITS AND FEES: Permits, licenses, fees, inspections and arrangements required for the work under this Contract shall be obtained by the Contractor at his expense.

1.05 TEMPORARY SERVICES FOR CONSTRUCTION

A. Provide a temporary electrical service, including all required equipment such as transformers, generators and fuel, panelboards, etc. as required by all trades. Coordinate power requirements for the temporary service with the General Contractor and the utility company prior to the start of construction. The Contractor is responsible to develop all temporary service plans and specifications as required by the Authority Having Jurisdiction, submit those plans and specifications for review by the Authority Having Jurisdiction, and to pay for all temporary service energy consumption.

B. Provide all temporary lighting necessary to provide lighting levels in compliance with OSHA Regulations and as required by all trades.

1.06 CONTRACT DRAWINGS

A. Obtain, fully understand, and coordinate the work with the complete set of Contract Documents. Any required corrections, including all associated costs, arising from lack of coordination with the complete set of Contract Documents is the Contractor's sole responsibility.

B. Work under these Sections is diagrammatic and is intended to convey the scope of work and indicate the general arrangement of equipment, conduit, and outlets. Obtain instructions from the Architect/Engineer on any rough-in wherever a question exists as to the exact intended location of outlets or equipment.

C. Promptly report and discrepancies discovered within the Contract Documents. Failure of the Contractor to report discrepancies shall result in the resolution becoming the contractor's responsibility and at no cost to the Architect/Engineer's review and possible rejection. Should the Architect/Engineer reject a discrepancy resolution of which they were not notified, the Contractor is fully responsible to correct the installation, including all associated costs, until approval of the installation is given by the Architect/Engineer.

1.07 SHOP DRAWINGS: Furnish the Architect shop drawing portfolios containing names of manufacturer and cut sheets of equipment to be used on the project. Provide shop drawings for metering equipment, panelboards, luminaires, wiring devices, lighting controls, enclosed switches, surge protection devices, and fire detection and alarm systems, including fully engineered drawings, voltage drop calculations, and battery calculations. Fire detection and alarm drawings shall bear the review stamp of the Authority Having Jurisdiction. Approval shall not relieve the Contractor from responsibility for errors on the shop drawings.

1.08 QUALITY ASSURANCE

A. All components shall be listed and classified by Underwriters Laboratories, Inc. as suitable for the purpose and free of all rust/corrosion or any visible damage. All items not complying with this requirement shall be replaced without any change in the Contract amount.

B. Unless otherwise specified, all equipment, devices, luminaires, and materials of the same type or classification and used for the same purpose shall be products of the same manufacturer. Use only new, un-deteriorated, and unused material, except as specifically noted.

C. Equipment performance and accessories shall be as indicated on the Drawings and/or specified herein. Inclusion in both locations is not a prerequisite to inclusion in the Contract; equipment and accessories specified in either location shall be included in this Contract. Provide all necessary accessories and connections as required for a complete, functional system, including all required components reasonably inferred to as necessary although such components may or may not be specifically indicated in the Contract Documents.

1.09 DELIVERY, STORAGE, AND HANDLING: Accept all materials on site and inspect for damage and protect from corrosion and entrance of debris. Handle all materials in accordance with manufacturer's instructions to avoid damage to internal components, enclosures, and finishes.

1.10 WARRANTY AND GUARANTEE: Provide a complete parts and labor warranty and guarantee on all systems for a period of one year from Owner acceptance of the completed facility. This warranty and guarantee shall cover all failures unless such failure is directly attributable to vandalism or causes other than defects in material or workmanship.

PART 2 PRODUCTS

2.01 CONDUCTOR TERMINATIONS: Provide conductor terminations rated at a minimum of 75 degrees C in all equipment.

2.02 SUBSTITUTIONS: The products specified in the Contract Documents constitute the Basis of Design for the Construction Documents and set minimum standards for quality, design, and functionality. Other products are permitted to be submitted, at the Contractor's option, during the shop drawing review unless indicated otherwise. Any substitute products shall meet or exceed all requirements specified. Any costs and coordination issues arising out of any substitution, including coordination with all other contractors and subcontractors and any associated costs, is the substituting contractor's sole responsibility.

PART 3 EXECUTION

3.01 COORDINATION OF WORK

A. Work lines and established heights shall be in strict accordance with architectural drawings and specifications. Verify all dimensions shown and establish all elevations and detailed dimensions not shown prior to rough-in.

B. Promptly report any difficulties encountered in the installation of the work which might prevent prompt and proper installation. Failure to report shall constitute an acceptance of other trades work as suitable for fit and proper for the execution of this work.

C. Coordinate the work with all trades so that it proceeds without delay and minimizes interference to work that is in progress or has not been completed. Conflicts arising from lack of coordination shall be this Contractor's responsibility. The Electrical Contractor shall pay for all extra cutting and patching necessary by any lack of coordination.

D. Arrange all conduit runs in a manner that it does not interfere with grilles, diffusers, outlet boxes, luminaires, or other items while providing for maximum headroom. Maintain access to equipment requiring service when selecting mounting elevations.

E. Afford other trades reasonable opportunity for the execution of their work and connect the work of other trades as to not delay or interfere with their work.

F. Explicitly follow all manufacturer's instruction instructions and promptly report any conflicts between the manufacturer's installation instructions and the Contract Documents.

G. Provide all supplementary or miscellaneous items, appurtenances, and devices incidental to or necessary for a sound, secure and complete installation.

H. Verify and coordinate all requirements and installation details of all materials and equipment prior to rough-in. Obtain and review shop drawings, product data, manufacturer's wiring diagrams, and manufacturer's instructions for equipment furnished under other Sections. Determine connection locations and requirements, sequence rough-in of electrical connections to coordinate with installation of equipment, sequence electrical connections to coordinate with start-up of equipment, and verify that proper power supply is available prior to subcontractor's ordering equipment. Verify proper voltage, phase, and current rating of power supply and report any discrepancies prior to order, connection of equipment, or start-up. Responsibility for verification of proper power supply voltage and any damage resulting from incorrect connections shall rest with this Contractor and any conflicts arising from lack of coordination shall be this Contractor's responsibility.

3.02 ACCESS TO EQUIPMENT: Install all equipment, starters, switches, receptacles, and boxes so that all parts are easily accessible for inspection, operation, maintenance, and repair. Provide access doors, fire rated where required, for concealed equipment.

3.03 CUTTING, PATCHING, AND PIERCING

A. Cut all openings in a neat workmanlike manner, only as large as required for the installation, and leave surfaces around openings smooth and finished to match surrounding surface.

B. Patch existing finished surfaces and building components using new materials matching existing materials.

C. Fire and/or Smoke Rated Assemblies: Become familiar with all fire and/or smoke rated construction and install work to maintain the integrity of those ratings.

D. Roof Penetrations: Coordinate with the Roofing Contractor to provide any required roof penetrations.

3.04 FIELD QUALITY CONTROL

A. Install all equipment, devices, luminaires, and materials plumb, level, securely, and in a neat and workmanlike manner in accordance with NFPA 70 and all applicable NECA and NEMA standards.

B. Adjust all flush mounted equipment, boxes, cabinets, and enclosures such that they are flush with finished wall or flooring material.

C. Replace or refinish damaged equipment, devices, luminaires, materials, and surfaces where marring or disfigurement has occurred.

D. Clean electrical parts to remove harmful materials. Clean exposed surfaces of all equipment, devices, luminaires, and materials and the interior of all boxes, enclosures, and cabinets of all foreign materials.

E. Paint all electrical equipment not factory finished on exterior walls, on the roof where exposed to view, where visible from 6'-0" above grade from any property line, and all exposed conduit to match the surrounding surfaces. Coordinate paint color with the Architect.

3.05 TESTING AND INSPECTION

A. Testing: Test the entire system under operating conditions over a sufficient period of time to establish the adequacy, quality, safety, completed status, and suitable operation of all equipment, devices, systems, etc.

B. Inspection: Obtain all required certificates of inspection and approval.

3.06 PROJECT CLOSEOUT

A. Project Record Documents: Provide one printed copy and one electronic copy of project record drawings to the Owner. Project record drawings shall reflect the actual "as-built" conditions and shall include locations of all equipment, devices, and luminaires, circuiting arrangements, routing of all underfloor conduits, routing of conduits larger than 2 inches, locations and mounting heights of all outlet, pull, and junction boxes, locations of all items requiring maintenance and their locations, and all changes or deviations and circuiting and switching arrangements of lighting controls.

B. Operation and Maintenance Data: Provide one printed copy and one electronic copy of operation and maintenance data for all equipment, devices and luminaires to the Owner. Operation and maintenance data shall include manufacturer's cut sheets, maintenance procedures, recommended maintenance intervals, wiring diagrams, parts lists, manufacturers' warranties, certificates, and test reports for all items installed.

C. Maintenance Materials: Provide to the Owner two keys for each different enclosure and cabinet, including panelboards, two spare fuses of each type and size, and one fuse puller.

D. Test Reports: Provide one printed copy and one electronic copy of all completed test reports to the Engineer.

END OF SECTION

SECTION 260502 – TRENCHING AND BACKFILL FOR ELECTRICAL

PART 1 GENERAL

1.01 DEFINITIONS

A. Subgrade Elevations: 4 inches below finish grade unless directed otherwise.

B. Finish Grade Elevations: 4 inches above subgrade unless directed otherwise.

1.02 PROJECT CONDITIONS

A. Provide sufficient quantities of fill and store materials on site in advance of need. Separate differing materials with sufficient stockpile separately and protect stockpiles from erosion and deterioration of materials.

B. Verify all survey bench marks and intended elevations for the work.

C. Protect all existing landscaping, hardscaping, existing structures, benchmarks, survey control points, and other features to remain from excavating equipment and vehicular traffic.

PART 2 PRODUCTS

2.01 FILL MATERIALS

A. General Fill: Subsoil excavated from site and free of lumps larger than 3 inches, rough larger than 6 inches, and debris.

B. Granular Fill: Natural stone pea gravel free of clay, shale, and organic matter.

C. Topsoil: Select topsoil excavated from site and free of roots, rocks larger than 1/2 inch, subsoil, debris, large weeds and foreign matter.

PART 3 EXECUTION

3.01 EXAMINATION

A. Identify required lines, levels, contours, and datum locations.

B. Locate and identify all utilities and protect same from damage.

3.02 TRENCHING

A. Report any unexpected subsurface conditions and discontinue effected work in area until notified to resume.

B. Do not interfere with 45 degree bearing splay of foundations.

C. Cut trenches side enough to allow inspection of installed utilities. Slope banks of excavations deeper than 4 feet to angle of repose or less until shored.

D. Hand trim excavations and remove loose matter, large stones, and other hard matter which could damage utilities or impede consistent backfilling or compaction.

3.03 PREPARATION FOR UTILITY PLACEMENT

A. Replace soft areas of subgrade not capable of compaction with general fill.

B. Compact subgrade to density equal to or greater than requirements for subsequent backfill.

C. Maintain excavations and prevent loose soil from falling into excavation until ready for backfill.

3.04 BEDDING AND FILL

A. Backfill to contours and elevations required using unfrozen materials and a placement method that does not disturb or displace other work.

B. Unless indicated otherwise, use granular fill bedding covered with general fill up to finished grade elevation and compact all fill materials in equal continuous layers not exceeding 8 inches compacted depth to 97 percent of maximum dry density.

C. Fill thrust bearing surfaces with concrete.

3.05 FIELD QUALITY CONTROL

A. Perform compaction density testing every 2 feet on compacted fill in accordance with ASTM D1556, ASTM D2167, ASTM D2922, or ASTM D3017. Evaluate results in relation to compaction curves in accordance with ASTM 1557, ASTM D1557, or AASHTO T 180. Remove, replace, and retest fill if tests indicate work does not meet specified requirements.

END OF SECTION

SECTION 260519 – CONDUCTORS AND CABLES

PART 1 GENERAL – NOT USED

PART 2 PRODUCTS

2.01 BUILDING WIRE AND CABLES

A. Provide single conductor building wire installed in raceway unless indicated otherwise, otherwise permitted, or otherwise required.

B. All conductors shall be copper conductors with 600V insulation; type THHN for dry and damp locations and type THWN-2 for wet locations.

C. Metal Clad Cable (Type MC): Permitted only for branch circuits in concealed locations and only when approved by applicable codes and amendments and the Authority Having Jurisdiction. Exposed MC Cable is not permitted, no exceptions.

1. All MC Cable sheaths shall be listed and identified for grounding.
2. All MC Cable shall be equipped with copper equipment grounding conductor. No exceptions.

D. Nonmetallic–Sheathed Cable (Type NM): Type NM–B permitted only for branch circuits in concealed locations within individual dwelling units and only when approved by applicable codes and amendments and the Authority Having Jurisdiction. Exposed NM Cable and NM Cable used outside individual dwelling units is not permitted, no exceptions.

E. All conductors 12 AWG and smaller shall be solid. Conductor size 10 AWG is permitted to be solid or stranded. Use stranded conductors for all conductors 8 AWG and larger.

F. Use 12 AWG conductors, minimum, for all circuits unless indicated otherwise or as modified as follows:

1. 20A, 120V circuits longer than 75 feet: 10 AWG to offset voltage drop.
2. 20A, 120V circuits longer than 150 feet: 8 AWG to offset voltage drop.
3. 20A, 277V circuits longer than 150 feet: 10 AWG to offset voltage drop.

2.02 CONTROL CABLES

A. All control cable conductor sizes, quantities, stranding, and shielding as recommended by the manufacturer and required for the installation but no smaller than 18 AWG.

B. Horizontal Applications in Conduit: Type CL2 unless otherwise required.

C. Horizontal Applications not in Conduit: Type CL2P unless otherwise required.

D. Riser Applications: Type CL2R unless otherwise required.

2.03 COMMUNICATIONS CABLES: See Section 271005.

2.04 WIRING CONNECTORS

A. Use twist–on insulated spring connectors, mechanical connectors, or compression connectors for conductor sizes 8 AWG and smaller. Do not use push–in wire connectors as a substitute for twist–on insulated spring connectors.

B. Use mechanical connectors or compression connectors for conductor sizes 6 AWG and larger.

C. Use crimped terminals for all control circuit conductor connections.

PART 3 EXECUTION

3.01 PREPARATION: Clean raceways thoroughly to remove foreign materials before installing conductors and cables.

3.02 COLOR CODING

A. Color code conductors as follows and maintain consistent color coding throughout project including branch circuit conductors.

1. 208Y/120, 3, 3 phase, 4 Wire System
   a. Phase A: Black
   b. Phase B: Red
   c. Phase C: Blue
   d. Neutral/Grounded: White
2. Equipment Ground: Green with yellow stripe
3. Isolated Ground: Green with yellow stripe

3.03 INSTALLATION

A. Circuit routing indicated is diagrammatic. Arrange circuiting to minimize splices and include circuiting required to install connected devices within 10 feet of location shown.

B. Combining branch circuits in a single raceway is permitted under the following conditions:

1. Provide no more than six current–carrying conductors in a single raceway. Dedicated neutral conductors are considered current–carrying conductors.
2. Increase size of conductors as required to account for ampacity derating.
3. Size raceways, boxes, etc. to accommodate conductors.

C. Neutral Conductors:

1. Provide separate neutral conductors for:
   a. Branch circuits protected by ground fault circuit interrupter (GFCI) circuit breakers.
   b. Branch circuits protected by arc fault circuit interrupter (AFCI) circuit breakers.
   c. Branch circuits protected by shunt trip circuit breakers.
   d. Branch circuits fed from feed–through protection of GFCI receptacles.
   e. Branch circuits with dimming controls.
   f. Branch circuits that serve emergency lighting equipment such as emergency batteries or emergency lighting unit equipment.
   g. Where indicated by the wire counts shown on the Drawings.
2. Multiwire branch circuits (shared neutrals) are permitted where not otherwise indicated.
   a. Locate all multiwire branch circuits in vertically adjacent panelboard pole spaces and provide circuit breaker handle ties to simultaneously disconnect all ungrounded circuit conductors.

D. Pull all conductors together into raceway at same time, do not damage conductors or exceed manufacturer's recommended maximum pulling tension or sidewall pressure, and use suitable wire pulling lubricant where recommended by the manufacturer.

E. Secure and support conductors and cables in accordance with NFPA 70 using supports and methods approved by the Authority Having Jurisdiction. Provide independent support from building structure; do not support from raceways, piping, ductwork, existing ceiling support systems, or other systems and do not allow conductors or cables to lay on ceiling tiles.

F. Cut all cables per the manufacturer's recommendations and terminate using suitable connectors including grounding and bonding connectors as applicable.

G. Provide a minimum of 12 inches of slack at each outlet. Provide a minimum of 5 feet of slack where conductors are installed in enclosures for future termination by others.

H. Neatly train and bundle conductors inside boxes, wireways, panelboards and other equipment enclosures.

I. Make wiring connections using specified wiring connectors and make splices and taps only in accessible boxes. Do not pull splices into raceways or make splices in conduit bodies.

J. Do not remove conductor strands to facilitate insertion into connector. Provide connectors suitable for reducing to appropriate size, but not less than required for the rating of the overcurrent protective device, where conductors are larger than the equipment terminations can accommodate.

K. Install solid conductors for use this–bonds to present neat appearance with adequate strength and rigidity. Provide lock washers under all nuts.

L. Provide supports for all low voltage wiring not routed in conduit.

END OF SECTION

SECTION 260526 – GROUNDING AND BONDING

PART 1 GENERAL

1.01 MAXIMUM GROUNDING SYSTEM RESISTANCE: 5 ohms.

PART 2 PRODUCTS

2.01 ROD ELECTRODES: Copper, 3/4 inch diameter, 10 foot long solid rods. Sectional rods are not permitted.

2.02 CONCRETE ENCASED ELECTRODES: 4 AWG, 20 foot long bare copper wire.

2.03 WIRE: Copper wire sized to meet NFPA 70 requirements.

2.04 CONNECTORS AND ACCESSORIES: Copper, copper alloy, or bronze mechanical connectors.

PART 3 EXECUTION

3.01 INSTALLATION OF GROUNDING ELECTRODE SYSTEM

A. As applicable to the project, provide all components required for a complete grounding electrode system including bonding of metal underground water pipe, metal frame of the building, concrete-encased electrode, metal aboveground water piping system, metal aboveground gas piping system, and rod electrode(s) per NFPA 70 requirements.

3.02 INSTALLATION OF EQUIPMENT GROUNDING SYSTEM

A. Without exception, provide equipment grounding conductor sized per NFPA 70 requirements within each feeder and branch circuit raceway and terminate each end on suitable lug, bus, or bushing.

3.03 INSTALLATION OF ISOLATED GROUNDING SYSTEM

A. Provide an additional isolated grounding conductor for circuits serving isolated ground receptacles. Isolated grounding conductors shall be isolated from the isolated grounding receptacle to the isolated ground bus in the upstream panelboard.

3.04 TESTING

A. Measure grounding resistance using a 3 point Megger test. Provide additional rod electrodes as required to reduce grounding resistance to less than the specified maximum permitted value.

END OF SECTION

SECTION 260529 – HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS

PART 1 GENERAL – NOT USED

PART 2 PRODUCTS

2.01 HANGER AND SUPPORTS

A. Corrosion–resistant materials of size and type adequate to carry the supported weight, including the weight of wire in conduit; do not use perforated pipe straps as a means of support.

2.02 ANCHORS AND FASTENERS

A. Use precast inserts, preset inserts, expansion anchors, or self–drilling anchors as approved by the Structural Engineer for concrete elements.

B. Use beam clamps, steel spring clips, steel ramset fasteners, or welded fasteners for steel elements.

C. Use toggle bolts or hollow wall fasteners for hollow masonry, plaster, and gypsum board partitions.

D. Use expansion anchors or preset inserts for solid masonry walls.

E. Use sheet metal screws for sheet metal elements and wood screws for wood elements.

PART 3 EXECUTION

3.01 INSTALLATION

A. Provide all required blocking and supplemental framing required to securely support all materials.

B. Fasten supports to building structure and surfaces only. Do not fasten supports to pipes, ducts, mechanical equipment, conduit, or ceiling suspension wires.

C. Obtain permission from Structural Engineer before drilling or cutting structural members or before using power–actuated anchors.

D. Rigidly weld support members for use this–bonds to present neat appearance with adequate strength and rigidity. Provide lock washers under all nuts.

E. Install surface–mounted cabinets and panelboards with minimum of four anchors.

F. Provide steel channel supports behind all cabinets and panelboards located in damp or wet locations to stand enclosures 1 inch off wall.

G. Provide supports for all low voltage wiring not routed in conduit.

END OF SECTION

SECTION 260534 – CONDUIT AND WIREWAYS

PART 1 GENERAL – NOT USED

PART 2 PRODUCTS

2.01 CONDUIT

A. Size: As required by NFPA 70 for the conductors installed but no smaller than trade size 3/4.

B. Underground: 3/4 inch minimum rigid metal conduit, intermediate metal conduit, Schedule 80 PVC, or Schedule 40 PVC. Metal conduits shall be galvanized or PVC coated.

C. Outdoor Locations above Grade: 1/2 inch minimum rigid metal conduit or intermediate metal conduit. Use of electrical metallic tubing is not permitted above grade. Conduits shall be galvanized or PVC coated.

D. Within Slabs above Grade: 3/4 inch minimum rigid metal conduit, intermediate metal conduit, or Schedule 80 PVC. Metal conduits shall be galvanized or PVC coated. Coordinate with the Structural Engineer restrictions and limitations on conduits installed in slabs above grade.

E. Exposed Wet and Damp Locations: 1/2 inch minimum rigid metal conduit or intermediate metal conduit. Conduits shall be galvanized or PVC coated.

F. Connections to Vibrating Equipment and Luminaires in Dry Locations: 1/2 inch minimum flexible metal conduit.

G. Connections to Vibrating Equipment and Luminaires in Damp and Wet Locations: 1/2 inch minimum liquidtight flexible metal conduit.

H. All Other Dry Locations: 1/2 inch minimum rigid metal conduit, intermediate metal conduit, or electrical metallic tubing.

2.02 FITTINGS: Provide listed fittings identified for use with the conduit.

2.03 WIREWAYS: Square D Class 5100 Type LDB for dry locations or Square D Class 5100 Type LDR for damp and wet locations unless indicated otherwise; size as required by NFPA 70 based on conductor fill and bending radius requirements.

PART 3 EXECUTION

3.01 INSTALLATION

A. Conceal all conduit in all interior and exterior areas, including exposed structure areas, unless the Architect provides specific approval permitting the use of exposed conduit.

B. Route any exposed conduit parallel and perpendicular to walls.

C. Subject to the Architect's approval, conduit located above ceilings is permitted to be routed point–to–point provided it is secured and supported per NFPA 70 requirements and complies with all applicable Codes and other requirements of the specifications.

D. Do not embed conduit in slabs–on–grade. Locate conduit a minimum of 2 inches below the bottom surface of the slab to avoid future damage from cutting of the floor slab.

E. Route conduit in slabs–over–grade from point–to–point. Do not cross conduits embedded in slabs.

F. Route underground conduit from point–to–point and at a burial depth in compliance with NFPA 70, local code, and utility company requirements.

G. Arrange conduit to maintain headroom and present neat appearance and arrange supports to prevent misalignment during wiring installation.

H. Secure and support all conduit in compliance with NFPA 70 requirements and group adjacent conduits on steel channel racks and trapezes.

I. Provide 12 inches of clearance between conduit and piping or surfaces with temperatures exceeding 104 degrees F.

J. Install no more than the equivalent of three 90 degree bends between boxes.

K. Provide sleeves when penetrating footings, masonry walls and floors and seal all penetrations through footings and floors water tight.

L. Provide suitable fittings to accommodate expansion and deflection where conduit crosses seismic, control, and expansion joints.

M. Provide suitable pull string in each empty conduit except sleeves and nipples.

N. Provide caps to protect installed conduit against entrance of dirt and moisture.

O. Secure wireway to building surfaces and close ends of wireway and unused conduit openings.

P. Ground and bond conduit and wireways as required by NFPA 70.

END OF SECTION

SECTION 260537 – BOXES

PART 1 GENERAL – NOT USED

PART 2 PRODUCTS

2.01 ALL BOXES

A. Nonmetallic boxes are not permitted unless indicated otherwise or without specific written approval from the Architect.

B. Provide all required box hangers and supports, extension rings, mud rings, etc. for a complete and secure installation.

C. Use gang boxes where more than one device is mounted together; do not use sectional boxes.

2.02 OUTLET AND SMALL JUNCTION BOXES

A. Dry and Damp Locations: Galvanized NEMA OS 1 stamped steel box rated for the weight of the equipment supported and sized per NFPA 70 requirements for the device(s) and conductors installed within.

B. Wet Locations: Galvanized cast metal NEMA FB 1 Type FD box with gasketed cover and threaded hubs and sized per NFPA 70 requirements for the device(s) and conductors installed within.

2.03 PULL AND LARGE JUNCTION BOXES

A. Dry and Damp Locations: Galvanized NEMA OS 1 stamped steel box sized per NFPA 70 requirements for the conductors installed within.

B. Wet Locations: Galvanized NEMA 250 Type 4 cast iron or cast aluminum box with gasket flange, neoprene gasket, and stainless steel cover screws and sized per NFPA 70 requirements for the conductors installed within.

2.04 FLOOR BOXES

A. All Floor Boxes: All floor boxes located in slabs on grade shall be cast metal. Stamped steel floor boxes are only permitted in slabs above grade.

B. Indoor Flush Floor Boxes for Concrete Floors: Wiremold 880 OmniBox Series unless indicated otherwise with number of gangs as required for the devices installed within.

C. Indoor Flush Floor Boxes for Wood Floors: Wiremold 880W Series unless indicated otherwise with number of gangs as required for the devices installed within.

D. Indoor Recessed Floor Boxes: Wiremold RFB Series unless indicated otherwise with number of compartments as required for the devices installed within.

E. Exterior Floor Boxes: NEMA 3R while–in–use square exterior floorbox as manufactured by Combined Utilities Box Systems (CUBS) unless indicated otherwise with wiring devices indicated.

PART 3 EXECUTION

3.01 INSTALLATION

A. Install in locations indicated and as required for splices, taps, wire pulling, equipment connections, and as required by NFPA 70.

B. Install pull boxes and junction boxes in accessible ceilings and in unfinished areas only.

C. Install outlet boxes for all wall–mounted wiring devices at heights indicated in Section 262726 unless indicated otherwise. Coordinate mounting heights and locations of outlets mounted above counters, benches, and backsplashes prior to rough–in.

D. Use flush boxes in finished areas. Do not install flush boxes back–to–back in walls; provide a minimum 6 inches and one stud separation.

E. Locate flush boxes in masonry walls to require cutting of masonry unit corner only. Coordinate masonry cutting to achieve neat opening.

F. Install all wall–mounted boxes plumb and level.

G. Install all ceiling–mounted boxes level and oriented parallel with building lines and ceiling grid tees where applicable.

H. Install all floor boxes level and oriented parallel with building lines and tile grout lines where applicable.

I. Vertically align adjacent wall mounted outlet boxes for switches, thermostats, and similar devices.

J. Install concealed boxes within 6 inches from ceiling access panels, air distribution diffusers, or removable return grilles.

K. Support boxes independently of conduit; do not support boxes from ceiling support wires.

L. Install knockout closures in unused box openings.

M. Install cover plates on boxes; see Section 262726 for cover plate specifications.

N. Ground and bond boxes as required by NFPA 70.

END OF SECTION

SECTION 260553 – IDENTIFICATION FOR ELECTRICAL SYSTEMS

PART 1 GENERAL – NOT USED

PART 2 PRODUCTS

2.01 NAMEPLATES: Engraved laminated plastic with 1/8 inch letters on contrasting background.

2.02 LABELS: As required by regulatory agencies.

2.03 WIRE MARKERS: Cloth, tape, split sleeve, or tubing type.

PART 3 EXECUTION

3.01 NAMEPLATES: Provide nameplates with the unique equipment designation at each electrical distribution and control equipment enclosure, communication cabinet, and service station.

3.02 WARNING LABELS: Provide all regulatory required and industry standard warning labels on access doors to equipment, including high–voltage, variable series rated combination, and arc flash hazard labeling.

3.03 WIRE MARKERS: Provide wire and cable markers at panelboard gutters, pull boxes, outlet boxes, and junction boxes for each load connection. Indicate branch circuit or feeder number indicated on Drawings and control wire number indicated on shop drawings.

3.04 COLOR CODE LEGEND: Provide identification label identifying conductor color codes at each piece of feeder or branch–circuit distribution equipment.

3.05 INSTALLATION

A. Install nameplates and labels parallel to equipment lines.

B. Secure nameplates for distribution equipment visible to the public to the inside surface of door.

C. Secure nameplates for distribution equipment not visible to the public to the front of the enclosure using screws, rivets, or adhesive.

1. Use pressure sensitive adhesive only for nameplates and labels.

END OF SECTION

SECTION 260595 – FIRE STOPPING

PART 1 GENERAL

1.01 PREPARATION: Examine the complete set of Drawings and identify all fire rated partitions, floors and assemblies. Identify and coordinate firestopping method for each penetration.

PART 2 PRODUCTS

2.01 FIRESTOPPING ASSEMBLIES: Use only systems listed by UL or FM or tested in accordance with ASTM E 814 or ASTM E 119 that have F Rating equal to fire rating of assembly and minimum T Rating Equal to F Rating.

2.02 MATERIALS: Elastomeric silicone firestopping, foam firestopping, fibered compound firestopping, fire rated caulking materials, mechanical firestop devices, intumescent putty, and firestop pillows are permitted.

PART 3 EXECUTION

3.01 INSTALLATION

A. Comply with firestopping manufacturer's recommendations for temperature and other environmental conditions before, during, and after installation. Provide ventilation in areas where solvent–cured materials are being installed.

B. Install firestopping to provide fire ratings indicated as well as those required by the local building and fire regulations.

C. Clean substrate surfaces of dirt, dust, grease, oil, loose material, or other matter which may affect bond of firestopping material. Remove incompatible materials which may affect bond. Install backing materials to arrest liquid material leakage.

D. Apply the appropriate fire stopping materials and systems to maintain the fire rating of the partition, floor, or ceiling assembly being penetrated.

E. Install fire stopping materials in accordance with fire test report and in accordance with manufacturer's instructions, completely closing openings.

F. Do not cover installed firestopping until inspected by Authority Having Jurisdiction.

G. Install any labeling required by Code.

H. Clean adjacent surfaces of firestopping materials.

END OF SECTION

SECTION 260918 – REMOTE CONTROL SWITCHING DEVICES

PART 1 GENERAL

1.01 PREPARATION

A. Hold meeting with the Owner prior to commencing work.

1. Review zoning and make adjustments requested by the Owner.
2. Determine all timeclock settings such as On and OFF times for each day of the week, holiday settings, latitude and longitude of the project site for astronomic features, etc.
3. Determine all control settings such as on and off triggers, blink warnings, sweep settings, switch programming, etc.
4. Determine all desired switch engraving.

PART 2 PRODUCTS

2.01 PROGRAMMABLE RELAY PANELS

A. Master Units: Lighting Control & Design GR2400 series with digital clock and modem unless indicated otherwise.

B. Slave Units: Lighting Control & Design GR2400 series unless indicated otherwise.

2.02 RELAYS

A. Normally closed latching rated at 20 amps at 120/277 volts unless indicated otherwise.

B. Provide lighting contactor controlled by relay in panel when load requires more than 20 amps.

2.03 LOW VOLTAGE WALL SWITCHES: Lighting Control & Design digital Chelsea switch with buttons indicated or otherwise required.

2.04 PHOTOSENSORS

A. Outdoor: Lighting Control & Design #GR2400 PCC1 2WO photosensor with control card.

B. Indoor: Lighting Control & Design #PCELL 2WI with #PCC3 control card.

2.05 PROGRAMMING SOFTWARE: Lighting Control & Design Unity software.

PART 3 EXECUTION

3.01 GENERAL INSTALLATION REQUIREMENTS

A. Install relay panels, photosensors, and switches where indicated or otherwise required.

B. Provide all control wiring and communications cabling, whether or not shown on the Drawings, per manufacturer's recommendations and as required for a complete and operational system.

C. Program wiring system established in meeting with the Owner and provide written report of program settings to the Owner.

D. Engrave all switch buttons as established in meeting with the Owner.

3.02 INSTALLATION OF OUTDOOR PHOTOSENSORS

A. Install photosensor facing north with unobstructed view.

B. Install such that photosensor does not face artificial light sources including light sources controlled by the photosensor itself.

C. Weatherproof all connections. Do not install photosensor with conduit stem facing up to prevent infiltration of water.

D. Adjust external sliding shields under optimum lighting conditions to achieve desired turn–on and turn–off activation.

3.03 INSTALLATION OF INDOOR PHOTOSENSORS

A. Location Adjustments: Locations indicated are diagrammatic and only intended to indicate which rooms or areas require devices. Provide quantity and locations as required for complete coverage of respective room or area based on manufacturer's recommendations for installed devices.

B. Install closed–loop photosensors to accurately measure the light level at the designated task location while minimizing the measured amount of direct light from natural or artificial sources.

C. Install open–loop photosensors to accurately measure the level of daylight coming into the space while minimizing the measured amount of lighting from artificial sources.

D. Calibrate dimming photosensors such that 100% artificial light output is provided only when completely dark outside and the controlled lighting dims commensurately with the amount of natural daylight contribution to the satisfaction of the Owner. Calibration shall occur after all room finishes, furniture, and window treatments have been installed.

3.04 CLOSEOUT

A. Demonstrate proper operation of system to the Owner and correct deficiencies or make adjustments as directed.

B. Train Owner's personnel on operation, adjustment, programming, and maintenance of the system.

C. Provide a written report of all program settings and photosensor settings to the Owner.

END OF SECTION

SECTION 260919 – CONTACTORS AND RELAYS

PART 1 GENERAL – NOT USED

PART 2 PRODUCTS

2.01 CONTACTORS

A. Description: Square D Class 8903, Type L or Type S unless indicated otherwise or otherwise required.

B. Contacts:

1. Provide with quantity of normally open and normally closed contacts as required and a minimum of two spare poles.
   a. Provide multiple contactors connected in parallel with one another when the number of contacts required exceeds the maximum capability of a single contactor.
2. Coordinate contact rating to match branch circuit overcurrent protection, considering derating for continuous loads, but no less than 30 amps.

C. Coil: Coordinate with the voltage of the control circuit.

D. Enclosure: Manufacturer's standard enclosure suitable for the environment in which the contactor is installed.

2.02 RELAYS

A. Description: Square D Class 8501 Type C unless indicated otherwise or otherwise required.

B. Contacts: Form C contacts rated at 30 amperes unless indicated otherwise.

C. Coil: Coordinate with the voltage of the control circuit.

D. Enclosure: Manufacturer's standard enclosure suitable for the environment in which the relay is installed.

PART 3 EXECUTION

3.01 INSTALLATION

A. Install individual controls and relays in enclosures adjacent to panelboard serving controlled circuits and make electrical wiring interconnections.

B. Provide all relays, contactors, interposing relays, and controls that are required but may not