

PAUL DHANENS • ARCHITECT

ARCHITECT



5100 CALIFORNIA AVE., SUITE 107  
BAKERSFIELD, CALIFORNIA 93309  
TELEPHONE: (661) 326-8936  
FACSIMILE: (661) 326-8037

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, graphic or electronic form, nor adapted in any third party without the expressed written consent of PAUL DHANENS ARCHITECT.

NOTICE TO CONTRACTORS:  
Written dimensions on these drawings shall take precedence over noted dimensions. Contractors shall verify and be responsible for confirming all dimensions and shall notify the architect immediately of any discrepancies or field variations discovered.

PROJECT

TENANT IMPROVEMENT  
FOR



1966 WEST AVE L  
LANCASTER, CA

DATE ISSUED FOR

8-24-18 BUILDING DEPT SUBMITTAL

6-26-19

NO. REVISIONS




PLUMBING

FILE NAME: 2366A2-0


SHEET

P-401




ARRANGEMENT SHOWN IS SCHEMATIC. ADJUST TO SUIT ACTUAL CONDITIONS. MAKE FINAL CONNECTION TO EQUIPMENT AS RECOMMENDED BY MANUFACTURER. PROVIDE WELDED FITTINGS/JOINTS IN ANY CONCEALED, UNSLEEVED LOCATION.


6 KITCHEN GAS EQUIPMENT DETAIL  
NOT TO SCALE



5 DOMESTIC WATER SERVICE DETAIL  
NOT TO SCALE




3 ICE MACHINE CONNECTION DETAIL  
NOT TO SCALE



2 AUTOMATIC WATER SOFTENER  
NOT TO SCALE

INSTALL PER PDI  
STANDARDS AND  
MANUFACTURER'S  
INSTRUCTIONS




SINGLE FIXTURE

PDI SIZE	PIPE SIZE	FIXTURE UNIT LOAD
A	1 1/2"	1-11
B	3/4"	12-32
C	1"	33-60
D	1-1/4"	61-113
E	1-1/2"	114-154
F	2"	155-330

FIXTURE UNIT TABULATION		
FIXTURE	COLD	HOT
VALVE WATER CLOSET	10	--
TANK WATER CLOSET	5	--
URINAL	5	--
LAVATORY/SINK	1.5	1.5
JANITOR'S SINK	3	3
SHOWER/BATHTUB	2	2


IF HORIZONTAL BRANCH IS LESS THAN 20'  
LONG, PROVIDE ONE WHA AT END OF LINE

IF BRANCH IS GREATER THAN 20' LONG,  
PROVIDE ANOTHER WHA IN MIDDLE, EACH  
SIZED FOR HALF THE FIXTURE UNITS



PLUMBING CONTRACTOR SHALL PROVIDE WATER HAMMER ARRESTERS BY SIOUX CHIEF, PRECISION PLUMBING PRODUCTS, WATTS OR APPROVED EQUIVALENT WITH PISTON AND O-RING CONSTRUCTION, HAVING PDI #WH-201, ASSE #1010 AND ANSI #A112.26.1M CERTIFICATION. INSTALL IN HORIZONTAL OR VERTICAL POSITION, BUT NEVER UPSIDE DOWN. INSTALL IN LINE WITH WATER FLOW DIRECTION IF POSSIBLE. SIZE THE UNITS AS SHOWN ON THE DRAWINGS AND/OR PER THE TABLES SHOWN ABOVE.

4 WATER HAMMER ARRESTERS  
NOT TO SCALE



1 WATER HEATER HOOK-UP  
NOT TO SCALE