


ARCHITECT



5100 CALIFORNIA AVE., SUITE 107
BAVERGRIEDEL, CALIFORNIA 93309
TELEPHONE: (916) 326-8532
FACSIMILE: (916) 326-8537

CONSULTANT

COPYRIGHT

PAUL DHANENS ARCHITECT expressly reserves its copyright and other property rights in these documents which are not to be reproduced, changed or copied in any written, printed or electronic form, nor adapted, modified or otherwise used in any way without the prior written consent of Paul Dhanens Architect. Only first party without the expressed written consent of Paul Dhanens Architect may make variations discovered.

PROJECT

TENANT IMPROVEMENT FOR



1966 WEST AVE L
LANCASTER, CA

DATE	ISSUED FOR
9-24-18	BUILDING DEPT SUBMITTAL
6-28-19	

NO. REVISIONS



MECHANICAL

FILE NAME: 2366A2-0

SHEET

M-302

- the Drawings.
- B. Perform all required regulatory duct leakage and weld tests in the presence of the code official, including but not limited to light tests and smoke tests, to demonstrate the integrity of the duct construction prior to the installation of any insulation that prevents visual inspection of the ductwork on all sides.
- C. Install fireproofing on entire surface of ducts indicated, except where Contract Documents explicitly indicate 3-sided or 2-sided installation.
- D. At penetrations of ducts through fire rated assemblies (walls, floors, roofs), extend fireproofing through the opening and seal annular space between fireproofing and edge of opening with firestop.
- E. Fasten fireproofing to ducts using either banding or insulation pins welded directly to surface of duct; do not use adhesives.
- F. Install fireproofing on supports and hangers unless hanger rods are at least 3/8 inch in diameter, spaced not more than 80 inches on center along length of duct, and horizontal supports are at least 2 by 2 by 1/4 inch steel angle or equivalent SMACNA support system.
- G. Access Panels: Do not block access; install fireproofing so that panel can be removed and reinstalled without damaging fireproofing.
- H. Seal all cut edges and ends and repair tears in facing using aluminum foil tape.

END OF SECTION

SECTION 233100 – HVAC DUCTS AND CASINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Metal ductwork.
- B. Nonmetal ductwork.
- C. Round spiral ductwork.
- D. Double wall insulated round ductwork.
- E. UL Composite ductwork, Type 1 grease hoods.
- F. Duct cleaning.

1.02 PERFORMANCE REQUIREMENTS

- A. No variation of duct configuration or sizes permitted except by written permission. Size round ducts installed in place of rectangular ducts in accordance with ASHRAE table of equivalent rectangular and round ducts, only after approval of the Engineer. Sizes shown on design drawings are air dimensions. Contractor may increase duct size without engineer approval, provided all ceiling and shaft clearances can be maintained. Additional charges for increased duct size will not be accepted by the Owner.
- B. Report all conflicts with structure or other obstructions, prior to fabrication of any ductwork. Suitable adjustments in the sizes of ducts shall be accommodated without any additional expense to the Owner.

1.03 SUBMITTALS

- A. Shop Drawings: Indicate duct fittings, particulars such as gages, sizes, welds, and configuration prior to start of work for all systems. No ductwork shall be fabricated until engineer approved shop drawings have been received by the Contractor. Shop drawings shall include details of ductwork and duct shapes made necessary by the obstructions of other trades.
- B. Test Reports: Indicate pressure tests performed, include date, section tested, test pressure, and leakage rate, following SMACNA (LEAK) HVAC Air Duct Leakage Test Manual.

1.04 REGULATORY REQUIREMENTS

- A. Construct ductwork to NFPA 90A, NFPA 90B, and NFPA 96 standards.
- B. Code or utility company requirements shall supersede any conflicting requirements of this Section.

1.05 FIELD CONDITIONS

- A. Do not install duct sealants when temperatures are less than those recommended by sealant manufacturers.
- B. Maintain temperatures within acceptable range during and after installation of duct sealants.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Galvanized Steel Ducts: Hot-dipped galvanized steel sheet, ASTM A 653/A 653M FS Type B, with G90/Z275 coating.
- B. Steel Ducts: ASTM A 1008/A 1008M, Designation CS, cold-rolled commercial steel.
- C. Aluminum Ducts: ASTM B 209 (ASTM B 209M); aluminum sheet, alloy 3003-H14.
- D. Aluminum Connectors and Bar Stock: Alloy 6061-T651 or of equivalent strength.
- E. Insulated Flexible Ducts:
- The Contractor may use any of the following ductwork materials, at his option, provided the selected material meets with the approval of all State, local authorities and utility company requirements. Verification of compliance of the selected ductwork material is the sole responsibility of the installing Contractor.
 - Two ply vinyl film supported by helically wound spring steel wire; fiberglass insulation; aluminumized vapor barrier film.
 - Pressure Rating: 10 inches WG positive and 1.0 inches WG negative.
 - Maximum Velocity: 4000 fpm.
 - Temperature Range: -20 degrees F to 175 degrees F.
 - Minimum R-Value: 4.2 or greater as required by the applicable energy codes.
3. Black polymer film supported by helically wound spring steel wire; fiberglass insulation; aluminumized vapor barrier film.
- Pressure Rating: 4 inches WG positive and 0.5 inches WG negative.
 - Maximum Velocity: 4000 fpm.
 - Temperature Range: -20 degrees F to 175 degrees F.
 - Minimum R-Value: 4.2 or greater as required by the applicable energy codes.
4. Multiple layers of aluminum laminate supported by helically wound spring steel wire; fiberglass insulation; aluminumized vapor barrier film.
- Pressure Rating: 10 inches WG positive and 1.0 inches negative.
 - Maximum Velocity: 4000 fpm.
 - Temperature Range: -20 degrees F to 210 degrees F.
 - Minimum R-Value: 4.2 or greater as required by the applicable energy codes.
5. UL 181, Class 1, aluminum laminate and polyester film with latex adhesive supported by helically wound spring steel wire; fiberglass insulation; aluminumized vapor barrier film.
- Pressure Rating: 10 inches WG positive and 1.0 inches WG negative.
 - Maximum Velocity: 4000 fpm.
 - Temperature Range: -20 degrees F to 210 degrees F.
 - Minimum R-Value: 4.2 or greater as required by the applicable energy codes.
6. UL 181, Class 0, interlocking spiral of aluminum foil; fiberglass insulation; aluminumized vapor barrier film.
- Pressure Rating: 8 inches WG positive or negative.
 - Maximum Velocity: 5000 fpm.
 - Temperature Range: -20 degrees F to 250 degrees F.
 - Minimum R-Value: 4.2 or greater as required by the applicable energy codes.

E. Joint Sealers and Sealants: Non-hardening, water resistant, mildew and mold resistant.

- Type: Heavy mastic or liquid used alone or with tape, suitable for joint configuration and compatible with substrates and recommended by manufacturer for pressure class of ducts.
- VOC Content: Not more than 250 g/L, excluding water.
- Surface Burning Characteristics: Flame spread of zero, smoke developed of zero, when tested in accordance with ASTM E 84.
- For Use With Flexible Ducts: UL labeled.
- Ductwork Exposed to the Weather: Hard cast VersiDrip 102, (VG-102), UL 181-AM compliant duct joint sealer, as manufactured by Corliss, with fiberglass scrim tape reinforcement on all seams and joints, lateral and longitudinal.

F. Hanger Rod: ASTM A 36/A 36M; steel; threaded both ends, threaded one end, or continuously threaded.

2.02 DUCTWORK FABRICATION

- A. Fabricate, support and seal in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and as indicated. Provide gaskets, gages, reinforcing, and sealing for operating pressures indicated.
- B. Construct T's, bends, and elbows with radius of not less than 1-1/2 times width of duct on centerline. Where not possible and where rectangular elbows must be used, provide turning vanes. Where acoustical lining is indicated, provide turning vanes of perforated metal with glass fiber insulation.
- C. Increase duct sizes gradually, not exceeding 15 degrees divergence wherever possible; maximum 30 degrees divergence upstream of equipment and 45 degrees convergence downstream.
- D. Fabricate continuously welded round and oval duct fittings two gages heavier than duct gages indicated in SMACNA Standard. Joints shall be minimum 4 inch cemented slip joint, brazed or electric welded. Prime and paint exterior surfaces.
- E. Provide standard 45 degree lateral wye takeoffs unless otherwise indicated where 90 degree conical tee connections may be used.
- F. Where ducts are connected to exterior wall louvers and duct outlet is smaller than louver frame, provide blank-out panels sealing lower area around duct. Use same material as duct, painted black on exterior side; seal to louver frame and duct.

2.03 DUCT MANUFACTURERS

- A. Metal-Fab, Inc.; SEMCO Incorporated; United McGill Corporation.

2.04 MANUFACTURED METAL DUCTWORK AND FITTINGS

- A. Manufacture in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and as indicated. Provide duct material, gages, reinforcing, and sealing for operating pressures indicated.
- B. Round Spiral Ducts: Machine made from round spiral lockseam duct with light reinforcing corrugations; fittings manufactured of at least two gages heavier metal than duct.
- C. Double Wall Insulated Round Ducts: Round spiral lockseam duct with galvanized steel outer wall, 1 inch thick fiberglass insulation, perforated galvanized steel inner wall; fitting with solid inner wall, 18 x 18 inch size for shoulder access, and as indicated. Provide 4 x 4 inch for balancing dampers only. Review locations prior to fabrication.
- D. Transverse Duct Connection System: "SMACNA TE" rated rigidly class connection, interlocking angle and duct edge connection system with sealant, gasket, cleats, and corner clips.

2.05 KITCHEN HOOD EXHAUST DUCTWORK, TYPE 1

- A. Fabricate in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and NFPA 96.
- B. Construct of 16 gage carbon steel or 18 gage stainless steel, using continuous external welded joints.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine drawings for the Architectural, Structural, Electrical and all other trades prior to preparation of ductwork shop drawings and prior to the fabrication of any ductwork.
- B. Resolve any conflicts encountered with the Engineer prior to fabrication.
- C. Identify on ductwork shop drawings any deviations in sizes or shapes made necessary by the obstructions of other trades.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Duct sizes indicated are inside clear dimensions. For lined ducts, maintain sizes inside lining.
- C. Install and seal metal and flexible ducts in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible.
- D. Provide openings in ductwork where required to accommodate thermometers and controllers. Provide pilot tube openings where required for testing of systems, complete with metal cap with strap or screw to ensure against air leakage. Where openings are provided in insulated ductwork, install insulation material inside a metal ring.
- E. Locate ducts with sufficient space around equipment to allow normal operation and maintenance activities.
- F. Use crimp joints with or without bead for joining round duct sizes 8 inch and smaller with crimp in direction of air flow.
- G. Use double nuts and lock washers on threaded rod supports.
- H. Connect flexible ducts to metal ducts with draw bands.
- I. Support flexible duct runs every five feet in the horizontal direction to avoid dips and sags.
- J. Connect terminal units to supply ducts with one foot maximum length of flexible duct. Do not use flexible duct to change direction.
- K. Connect diffusers to low pressure ducts directly or with 5 feet maximum length of flexible duct held in place with strap or clamp. Longer duct lengths are acceptable if depicted on the design drawings and allowed per local code. A maximum of one 90 degree bend, or equivalent, will be allowed in flexible duct runs.
- L. During construction provide temporary closures of metal or taped polyethylene on open ductwork to prevent construction dust from entering ductwork system.
- M. All exposed ducts in finished areas must be completely free from all dents or imperfections in the galvanized coating and shall be sealed CAREFULLY AND NEATLY with duct sealer completely contained within the joint. Duct wrap will not be permitted in exposed locations. If round duct is indicated in exposed locations, it must be spiral. No exposed duct sealer, tape or longitudinal joints will be accepted in exposed finished areas. Line all exposed supply air ductwork.
- N. Kitchen hood exhaust, Type 1: Use stainless steel for ductwork exposed to view and stainless steel or carbon steel for ducts where concealed.
- O. For all hood systems perform required regulatory duct leakage and weld tests in the presence of the code official, including but not limited to light tests and smoke tests, to demonstrate the integrity of the duct construction prior to the installation of any insulation that prevents visual inspection of the ductwork on all sides.
- P. Provide residue traps in kitchen hood exhaust ducts at base of vertical risers with provisions for clean out.
- Q. All roofing penetrations shall be flashed and weather sealed by the roofing manufacturer's authorized roofing contractor at this Contractor's expense. This Contractor shall contract with the factory authorized roofing contractor for the specific roofing system applicable to this Project. The use of an unauthorized roofing contractor may result in removal and replacement of the penetration systems at this Contractor's expense.

3.03 CLEANING

- A. Clean duct system and force air at high velocity through duct to remove accumulated dust or clean with high power vacuum machines. To obtain sufficient air, clean half the system at a time. Protect equipment which may be harmed by excessive dirt with temporary filters, or bypass during cleaning.

3.04 SCHEDULES

- A. Ductwork Material:
- B. The Contractor shall use any of the following ductwork materials, at his option, provided the selected material meets with the approval of all State, local authorities and utility company requirements. Verification of compliance of the selected piping material is the sole responsibility of the installing Contractor.
- Low Velocity Supply (Heating Systems): Galvanized Steel, Aluminum.
 - Low Velocity Supply (System with Cooling Coils): Galvanized Steel, Aluminum.
 - Return and Relief: Galvanized Steel, Aluminum.
 - General Exhaust: Galvanized Steel, Aluminum.
 - Return and Relief: Galvanized Steel, Aluminum.
 - Kitchen Hood Exhaust, Type 1: Carbon Steel, Stainless Steel, Constructed per NFPA 96.
- C. Ductwork Pressure Class:
- Low Velocity Supply (Heating Systems): Scheduled System ESP+0.25", round up to next higher pressure class.
 - Low Velocity Supply (Systems with Cooling): Scheduled System ESP +0.5", round up to next higher pressure class.
 - Return and Relief: 1 inch.
 - General Exhaust: Scheduled System ESP +1.0", round up to next higher pressure class.
 - Outdoor Air Intake: 1 inch.
 - Grid core exhaust and return grilles.
- D. Grid core exhaust and return grilles.
- E. Provide drawings for maximum fan static pressure plus 50% additional.

END OF SECTION

SECTION 233300 – AIR DUCT ACCESSORIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Air turning devices/extractors.
- B. Volume control dampers.
- C. Flexible duct connections.
- D. Duct access doors.

PART 2 PRODUCTS

2.01 AIR TURNING DEVICES/EXTRACTORS

- A. Manufacturers: Krueger; Price Industries; Nalor Industries Inc.; Ruskin Company; Tilus.
- B. Multi-blade device with blades aligned in short dimension; steel or aluminum construction; with individually adjustable blades, mounting straps.

2.02 VOLUME CONTROL DAMPERS

- A. Manufacturers: Louvers & Dampers, Inc.; Nalor Industries Inc.; Ruskin Company; Prefco Inc.
- B. Fabricate in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and as indicated.
- C. Single Blade Dampers: Fabricate for duct sizes up to 6 x 30 inch.
- D. Multi-Blade Dampers: Fabricate with maximum blade pattern with maximum blade sizes 8 x 72 inch. Assemble center and edge crimped blades in prime coated or galvanized channel frame with suitable hardware.
- E. End Bearings: Except in round ducts 12 inches and smaller, provide end bearings. On multiple blade dampers, provide oil-impregnated nylon or sintered bronze bearings.
- F. The contractor shall provide either a mechanical or electrical cable operated system wherever dampers are located in non-accessible areas.
- Mechanical cable operator system shall be similar and equal to Young Regulator Company, "Bowden Cable" system including damper, flexible cable with casing and concealed ceiling regulator control.
 - Electrically operated damper control system shall be similar and equal to United Enertech Corporation, "Power Balance" system including motor operated damper, RJ-11 plenum rated cabling and flush ceiling or wall mounted RJ-11 jack in remote plate. Include one hand held battery pack operator rack to be delivered to the Owner upon completion of the balancing.

2.03 FLEXIBLE DUCT CONNECTIONS

- A. Fabricate in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and as indicated.
- B. Flexible Duct Connections: Fabric crimped into metal edging strip.
- C. Fabricate UL listed fire-retardant neoprene coated woven glass fiber fabric to NFPA 90A, minimum density 30 oz per sq yd.
- D. Net Fabric Width: Approximately 2 inches wide.
- E. Metal: 3 inches wide, 24 gage thick galvanized steel.

2.04 DUCT ACCESS DOORS

- A. Manufacturers: Acudor Products Inc.; Nalor Industries Inc.; Ruskin Company; SEMCO Incorporated.
- B. Fabricate in accordance with SMACNA HVAC Duct Construction Standards – Metal and Flexible, and as indicated.
- C. Fabrication: Rigid and close-fitting of galvanized steel with sealing gaskets and quick fastening locking devices. For insulated ducts, install minimum 1 inch thick insulation with sheet metal cover.
- Less Than 12 inches Square: Secure with sash locks.
 - Up to 18 inches Square: Provide two hinges and two sash locks.
- D. Access doors with sheet metal screw fasteners are not acceptable.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install accessories in accordance with manufacturer's instructions, NFPA 90A, and follow SMACNA HVAC Duct Construction Standards – Metal and Flexible. Duct construction and pressure class.
- B. Provide duct access doors for inspection and cleaning before and after filters, coils, fans, automatic dampers, at fire dampers, combination fire and smoke dampers, and elsewhere as indicated. Provide minimum 8 x 8 inch size for hand access, 18 x 18 inch size for shoulder access, and as indicated. Provide 4 x 4 inch for balancing dampers only. Review locations prior to fabrication.
- C. Locate all dampers and control elements in accessible areas wherever possible to avoid access doors. Provide ceiling access doors for access to all dampers and control elements located above inaccessible ceiling areas. Provide minimum 12 x 12 inch size for hand access, 18 x 18 inch size for shoulder access, and as indicated. Provide 4 x 4 inch for balancing dampers only. Review locations prior to fabrication.
- D. Provide balancing dampers at points on supply, return, and exhaust systems where

- branches are taken from larger ducts as required for air balancing. Install minimum 2 inch duct widths from duct take-off.
- E. Provide balancing dampers on duct take-off to diffusers, grilles, and registers, regardless of whether dampers are specified as part of the diffuser, grille, or register assembly. Do not locate dampers closer than 5 feet or 10 duct diameters from the air terminal device, whichever is greater.
- F. At fans and motorized equipment associated with ducts, provide flexible duct connections immediately adjacent to the equipment.
- G. At equipment supported by vibration isolators, provide flexible duct connections immediately adjacent to the equipment.

END OF SECTION

SECTION 233423 – HVAC POWER VENTILATORS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Roof exhausters.
- B. Kitchen range hood exhausters.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Greenheck; Loren Cook Company; PennBarry; CaptiveAire.
- B. POWER VENTILATORS – GENERAL

- A. Performance Ratings: Determined in accordance with AMCA 210 and bearing the AMCA Certified Rating Seal.
- B. Sound Ratings: AMCA 301, tested to AMCA 300, and bearing AMCA Certified Sound Rating Seal.
- C. Fabrication: Conform to AMCA 99.
- D. UL Compliance: UL listed and labeled, designed, manufactured, and tested as suitable for the purpose specified and indicated.

2.03 ROOF EXHAUSTERS AND VENTILATORS

- A. Fan Unit: V-Bar or direct driven as indicated, with spun aluminum housing; resilient mounted motor; 1/2 inch mesh, 0.62 inch thick aluminum wire birdscreen; square base to suit roof curb with continuous curb gaskets.
- B. Roof Curb: 20 inch high above the finished roof surface (compensate for roof insulation thickness of fan location) self-flashing of galvanized steel or aluminum construction with continuously welded seams, built-in cant strips, insulation and curb bottom, and factory installed roller strip.
- C. Disconnect Switch: Factory wired, non-fusible, in housing for thermal overload protection.
- D. Backdraft Damper: Motor actuated (or gravity damper if depicted on design drawings), aluminum multiple blade construction, felt edged with offset hinge pin, nylon bearings, blades linked, and line voltage motor drive, power open, spring return.
- E. Sheaves: Cast iron or steel, dynamically balanced, bored to fit shafts and keyed; variable and adjustable pitch motor sheave selected so required rpm is obtained with sheaves set at mid-position; fan shaft with self-aligning pre-lubricated ball bearings.
- F. Kitchen hood exhausters shall be upblast with grease tray, ventilated double wall curb and hinged curb adapter base for cleaning. Hood exhausters shall comply with requirements of NFPA 96.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Provide sheaves required for final air balance at no additional expense to the project.
- C. Secure roof and wall exhausters with cadmium plated steel lag screws to roof curb or structure.
- D. Extend ducts to roof and wall exhausters into roof curb or wall structure.
- E. Counterflash duct to roof or wall opening.
- F. Install backdraft dampers (gravity or motorized as depicted on design drawings) on inlet to roof and wall exhausters.
- G. All roofing penetrations shall be flashed and weather sealed by the roofing manufacturer's authorized roofing contractor at this Contractor's expense. This Contractor shall contract with the factory authorized roofing contractor for the specific roofing system applicable to this project. The use of an unauthorized roofing contractor may result in removal and replacement of the penetration systems at this Contractor's expense.

END OF SECTION

SECTION 233700 – AIR OUTLETS AND INLETS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Round ceiling diffusers.
- B. Rectangular ceiling diffusers.
- C. Perforated face ceiling diffusers.
- D. Grid core exhaust and return grilles.

1.02 SUBMITTALS

- A. Product Data: Provide data for equipment required for this project. Review outlets and inlets as to size, finish, and type of mounting prior to submission.
- B. Submit schedule of outlets and inlets showing type, size, location, application, accessories, and noise level.

1.03 QUALITY ASSURANCE

- A. Test and rate air outlet and inlet performance in accordance with ASHRAE Std 70.
- B. Test and rate lower performance in accordance with AMCA 500-L.
- C. Code requirements shall supersede any conflicting requirements of this Section.

1.04 QUALIFICATIONS

- A. Manufacturer: Qualifications: Company specializing in manufacturing the type of products specified in this Section, with minimum five years of documented experience.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Tilus; Krueger; Price Industries; Nalor Industries Inc.; Hart & Cooley; Ruskin.

2.02 ROUND CEILING DIFFUSERS

- A. Type: Round, adjustable pattern, stamped or spun, multi-core, or architectural plaque diffuser to discharge air in 360 degree pattern, with sectorizing baffles where indicated. Diffuser collar shall project not more than 1 inch above ceiling. In plaster ceilings, provide plaster ring and ceiling plaques.
- B. Fabrication: Steel with baked enamel off-white finish.
- C. Accessories: Opposed blade damper and multi-louvered equalizing grid with damper adjustable from diffuser face.

2.03 RECTANGULAR CEILING DIFFUSERS

- A. Type: Square, adjustable blade pattern, stamped, multi-core, or architectural plaque diffuser to discharge air in 360 degree pattern with sectorizing baffles where indicated.
- B. Frame: Inverted T-bar type. In plaster ceilings, provide plaster frame and ceiling frame. (To allow lift-out removal of the diffuser without removal of the plaster frame).
- C. Fabrication: Steel with baked enamel off-white finish.
- D. Accessories: Opposed blade damper and multi-louvered equalizing grid with damper adjustable from diffuser face.

2.05 GRID CORE EXHAUST AND RETURN GRILLES

- A. Type: Fixed grilles of 1/2 x 1/2 x 1 inch louvers.
- B. Fabrication: Aluminum with factory off-white enamel finish.
- C. Frame: 1-1/4 inch margin with countersunk screw mounting.
- D. Frame: Channel loy-in-frame for suspended grid ceilings where face size exceeds 18 x 18 inch.
- E. Damper (if specified on drawings): Integral, gong-operated, opposed blade type with removable key operator, operable from face.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Check location of outlets and inlets and make necessary adjustments in position to conform with architectural features, symmetry, and as indicated.
- C. Install diffusers to ductwork with air light connection.
- D. Provide balancing dampers on duct take-off to diffusers, and grilles and registers, despite whether dampers are specified as part of the diffuser, or grille and register assembly.
- E. Paint ductwork visible behind air outlets and inlets matte black.

END OF SECTION

SECTION 237413 – PACKAGED OUTDOOR ROOF TOP UNITS – GAS FIRED

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Packaged roof top units.
- B. Thermostat controls.
- C. Roof mounting curb and base.
- D. Economizer.
- E. Power exhaust.

PART 2 PRODUCTS