

1 SECOND FLOOR REFLECTED CEILING PLAN
SCALE: 1/8"=1'-0"

GENERAL NOTES

- GRIDLINES ARE FOR LOCATION OF CENTERLINES OF STRUCTURAL STEEL COLUMNS, CENTERLINES OF STRUCTURAL WALLS AND EDGE OF WALL, U.N.O.
- DIMENSIONS (EXCEPT GRIDLINES) ARE: EXTERIOR WALLS TO FACE OF SHEATHING AT EXTERIOR SIDE, AND FACE OF FINISH AT INTERIOR U.N.O.
- SEE STRUCTURAL FOR ALL SHEATHING INFO.
- ALL RAIN WATER LEADERS, OVERFLOW PIPES AND PLUMBING PIPING, ELEC. CONDUIT ETC. SHALL BE CENTERED IN WALL FRAMING U.N.O.
- ALL EXTERIOR SURFACE MOUNTED PLUMBING PIPES SHALL BE GALVANIZED SHEET METAL U.N.O. RE: PLUMBING FOR ADDITIONAL INFORMATION
- FLOOR PLANS COMMUNICATE BUILDING INFORMATION ONLY. SEE CIVIL & LANDSCAPE DRAWINGS FOR ALL SITE WORK INFORMATION. NOTIFY ARCHITECT IMMEDIATELY IF DISCREPANCIES OCCUR PRIOR TO COMMENCEMENT OF WORK.

RCP NOTES

- NOTIFY THE ARCHITECT OF ANY DISCREPANCIES BETWEEN ARCHITECTURAL AND ELECTRICAL OR MECHANICAL DRAWINGS. OBTAIN CLARIFICATION FROM THE ARCHITECT IN WRITING BEFORE PROCEEDING WITH THE WORK IN QUESTION OR RELATED WORK.
- WHEN CEILING INTERRUPTIONS OCCUR, SUCH AS PARTITIONS, FURR DOWNS, ETC. CONTRACTOR SHALL CHECK AND VERIFY THAT WORK IS BUILDABLE AS SHOWN BEFORE PROCEEDING WITH CONSTRUCTION.
- ALL NEW CEILING FIXTURES, SWITCHES, AND MOTION SENSORS SHALL MATCH BUILDING STANDARD, U.N.O.
- LOCATE LIGHT FIXTURES, SPEAKERS, ACCESS PANELS, SPRINKLERS, LIFE-SAFETY FIXTURES, ETC. IN STRAIGHT LINES AND SHALL CENTER IN CEILING TILES WHERE POSSIBLE.
- ALL NEW CONDUITS, BOXES, DUCTWORK, HVAC UNITS, PIPES, ETC. SHALL BE INSTALLED AS HIGH AS POSSIBLE.
- PROVIDE EMERGENCY LIGHTING LEVELS AS REQUIRED BY CODE.
- REFER TO ELECTRICAL DRAWINGS FOR LOCATIONS OF EMERGENCY LIGHTING AND EXIT SIGNS.

KEYED NOTES

NOTE: NOT ALL KEY NOTES ARE USED ON THIS SHEET

- EXPOSED DUCTING RE: MECHANICAL
- PROVIDE ACCESS TO VARIABLE REFRIGERANT FLOW (VRF) UNIT. LOCATION IS ABOVE CEILING LINE AND BELOW FLOOR FRAMING. SHOWN FOR REFERENCE.
- NOT USED
- LOCATION OF MECHANICAL SHAFT ABOVE
- EXHAUST FAN, RE: MECHANICAL
- NEW BULKHEAD, SEE DETAIL 22/A-9.0
- CENTER CEILING IN ROOM
- "SOLAR READY" AREA RE: ELECTRICAL PLANS

WALL/SYMBOLS LEGEND

NOTE: NOT ALL SYMBOLS ARE USED ON THIS SHEET
WALL TAGS WITH 1HR TAG INDICATE THE WALL IS A 1 HR RATED WALL EXTENDING FULL HEIGHT TO THE UNDERSIDE OF STRUCTURE ABOVE WALL TO BE FIRE TAPED AND PENETRATIONS TO BE FIRE CAULKED AND COMPLY WITH CBC 714.3.1 THROUGH 714.3.3. SEE A-9.1 FOR DETAILS. TYP. FOR UL U485

- EXISTING EXTERIOR CMU WALL WITH EXISTING INTERIOR FURRED WALL:
 - (E) 8" CMU WALL
 - (E) 7/8" HAT TRACK
 - (E) FOAM INSULATION BETWEEN TRACKS
 - (E) 5/8" GYP. BD. ON INTERIOR (PROVIDE NEW GYP. BD. AS REQUIRED)
 - RE: 1/A-9.1
- EXISTING CMU SHEAR WALL AND EXISTING INTERIOR FURRING TO REMAIN; 8" CMU WALL RE: 2/A-9.1
- INTERIOR FULL HEIGHT METAL STUD WALL:
 - 3-5/8" 20 GA. MTL. STUDS @ 24" O.C.
 - ONE LAYER 5/8" TYPE 'X' GYP. BD. EACH SIDE RE: 3/A-9.1
- INTERIOR FULL HEIGHT METAL STUD WALL:
 - 6" 20 GA. MTL. STUDS @ 24" O.C.
 - ONE LAYER 5/8" TYPE 'X' GYP. BD. EACH SIDE
 - ONE HOUR RATED RE: 4/A-9.1
- INTERIOR FULL HEIGHT METAL STUD WALL:
 - 6" 20 GA. MTL. STUDS @ 24" O.C.
 - ONE LAYER 5/8" TYPE 'X' GYP. BD. EACH SIDE RE: 5/A-9.1
- INTERIOR FULL HEIGHT METAL STUD WALL:
 - 3-5/8" 20 GA. MTL. STUDS @ 24" O.C.
 - ONE LAYER 5/8" TYPE 'X' GYP. BD. EACH SIDE RE: 6/A-9.1
- INTERIOR FULL HEIGHT METAL STUD WALL:
 - 7-1/4" 20 GA. MTL. STUDS @ 24" O.C.
 - ONE LAYER 5/8" TYPE 'X' GYP. BD. EACH SIDE RE: 7/A-9.1
- NEW DOOR PER DOOR SCHEDULE 1/A-6.0

RCP SYMBOL LEGEND

- 2'x2' LED LIGHT; RE. ELEC.
- SOLID HATCH REPRESENTS EMERGENCY LIGHT RE. ELEC.
- SELF-ILLUMINATED EXIT SIGN; RE. ELEC.
- RECESSED CAN LIGHTS; RE. ELEC.
- SOLID HATCH REPRESENTS EMERGENCY LIGHT RE. ELEC.
- CEILING HEIGHT FROM FINISHED FLOOR
- 2'x2' CEILING GRID; CHICAGO METALLIC SYSTEM 1200, 15/16" METAL GRID, WHITE FINISH, STANDARD CEILING TILES 2'x2'x5/8"
- MANUF: USG CEILINGS
- TYPE: RADAR BASIC
- COLOR: WHITE
- EDGE: SLT
- RE: 1/A-9.0 FOR DETAILS
- 5/8" TYPE 'X' GYP. BD. CEILING PER DETAIL 8/A-9.0
- DRAFTSTOPPING TO BE PROVIDED IN COMBUSTIBLE CONCEALED AREAS. FLOOR CAVITY; AREAS NOT TO EXCEED 3,000 SF AND 100' MAX HORIZONTAL DISTANCE. ATTIC SPACE; AREAS NOT TO EXCEED 9,000 SF AND 100' MAX HORIZONTAL DISTANCE. GO TO VERIFY IF EXISTING DRAFTSTOPS ARE PRESENT OR INSTALL NEW DRAFTSTOPS. DRAFTSTOP MATERIAL SHALL BE NOT LESS THAN 1/2" GYPSUM BOARD. ATTACH TO FLOOR/ROOF JOISTS.

REVISIONS

DATE/DELTA	REMARKS
10/29/19	PLAN CHECK
02/10/20	OWNER REVISIONS
04/10/20	PLAN CHECK
11/06/20	BIDDING RT'S
05/06/21	COORDINATION
11/29/21	PLAN REVISIONS

LANCASTER BAPTIST CHURCH



NORTH AUDITORIUM "KID CITY"

IMPROVEMENTS

4020 LANCASTER BLVD.

LANCASTER, CALIFORNIA

BICKEL GROUP
ARCHITECTURE
BICKEL GROUP INCORPORATED
3600 BIRCH STREET, SUITE 120
NEWPORT BEACH, CA 92660
P: 949.757.0411 F: 949.757.0511
www.bickelgroup.com



The plans, specs, arrangements and designs indicated or represented by this drawing are owned by, and are the property of, BICKEL GROUP, and are made available for the project and site only. No part of this drawing shall be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without written permission from BICKEL GROUP. © 2019

SHEET TITLE:

SECOND FLOOR
REFLECTED CEILING
PLAN

SUB DATE 07/08/19

BID DATE

DATE: 03/19/19

DRAWN BY: KCC

JOB NO: 11761

CHECKED BY: KAJ

SHEET NUMBER:

A-2.1